



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 East Dania Beach Blvd.

Suite 338

Dania Beach, FL 33004

954.399.8478 PH

954.744.4738 FX

contact@buildingdrops.com

## Product Evaluation Report

of

**Croft, LLC.**

**Series 4400/4440 Picture Windows  
(Non-HVHZ) (Non-Impact)**

for

**Florida Product Approval**

**FL# FL11345**

**Report No. 7639**

### Current Florida Building Code

<b>Method:</b>	<b>1 – A (Certificate)</b>
<b>Category:</b>	<b>Windows</b>
<b>Sub – Category:</b>	<b>Fixed</b>
<b>Product:</b>	<b>Series 4400/4440 Picture Windows</b>
<b>Material:</b>	<b>6063-T5 Aluminum</b>
<b>Product Dimensions:</b>	<b>See Installation Instructions, CRF010</b>

**Prepared for:**

**Croft, LLC.**

**P.O. Box 826**

**McComb, MS 39649**

**Prepared by:**

**Hermes F. Norero, P.E.**


Florida Professional Engineer # 73778

Date: 06/25/2021

Contents:

Evaluation Report

Pages 1 – 3



Hermes F. Norero, P.E.

Florida P.E. No. 73778



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: **FL11345**

Date: 06/25/2021

Report No: 7639

---

<b>Manufacturer:</b>	<b>Croft, LLC.</b>
<b>Product Category:</b>	Windows
<b>Product Sub-Category:</b>	Fixed
<b>Compliance Method:</b>	State Product Approval Method (1)(a)
<b>Product Name:</b>	<b>Series 4400/4440 Picture Windows (Non-HVHZ) (Non-Impact)</b>

**Scope:** This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Croft, LLC.** based on Method 1a of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions on **CRF010**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

## Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does** require an impact resistant covering.
4. Site conditions that deviate from the details of Installation Instructions **CRF010** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions on **CRF010** for size and design pressure limitations.

Hermes F. Norero, P.E.

Florida P.E. No. 73778

Page 2 of 3



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: **FL11345**

Date: 06/25/2021

Report No: 7639

- 
- Certification Agency:** The manufacturer has demonstrated compliance of manufacture of products in accordance with the Florida Building Code for manufacturing under an approved certification agency through **American Architectural Manufacturers Association** (FBC Organization # CER1498).
- Performance Standards:** The product described herein has been evaluated per:
- AAMA/WDMA/CSA 101/I.S.2/A440-17
- Referenced Data:**
1. Product Testing performed by **PRI Construction Materials Technologies, LLC** (FBC Organization #TST5878)  
Report #: 2189T0014, Report Date: 05/24/21
  2. Certification Agency  
**American Architectural Manufacturers Association**  
(FBC Organization # CER1498)
- Installation Method:** Please refer to Installation instructions, **CRF010**, for anchor methods, selection, spacing, edge distances, embedments and further details of installation.
- Design Pressure:** Please refer to Installation instructions, **CRF010**, for sizes, configurations and design pressures.