

Evaluation Report "Englert® Series 1100" Metal Roof Assembly

Manufacturer:

Englert, Inc.

1200 Amboy Avenue
Perth Amboy, NJ 08862

for

Florida Product Approval

FL 11698.5 R7

Florida Building Code 8th Edition (2023)

Method: 1 - D

Category: Roofing

Sub - Category: Metal Roofing

Product: "Series 1100" Roof Panel

Material: Aluminum

Panel Thickness: 0.032"

Panel Width: 16"

Panel Seam: Snap-Lock

Support: Wood Deck

Prepared by:

James L. Buckner, P.E., SECB

Florida Professional Engineer # 31242

Florida Evaluation ANE ID: 1916


Project Manager: Diana Galloway

Report No. 23-555-S1100-A3W-ER.2

(Revises 20-234-S1100-A3W-ER, FL11698.5 R6)

Date: 08/16/2023

This item has been electronically signed and sealed by James L. Buckner, P.E., on this date using a Digital Signature. Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.



Contents:

Evaluation Report

Pages 1 – 8

Date: 2023.08.16
'10:53:44 -04'00

Manufacturer:	Englert, Inc. 1200 Amboy Avenue Perth Amboy, NJ 08862 (732) 826-8614 https://www.englertinc.com/
Product Name:	"Series 1100"
Product Category:	Roofing
Product Sub-Category	Metal Roofing
Compliance Method:	State Product Approval Rule 61G20-3.005 (1) (d)
Product/System Description:	"Series 1100" Standing Seam Roof Panel 0.032" Aluminum Snap-Lock roof panel mechanically attached to Wood Deck with fixed panel clips & screws.
Product Assembly as Evaluated:	Refer to Page 4 of this report for product assembly components/materials & standards: 1. Roof Panel 2. Panel Clip 3. Fasteners 4. Seam Adhesive 5. Underlayment 6. Insulation (Optional)
Support:	Type: Wood Deck (Design of support and its attachment to support framing is outside the scope of this evaluation.) Description: • 15/32" or 19/32" or greater plywood, (Per Table A) • or Wood plank (min. specific gravity of 0.42)
Slope:	Minimum slope shall be: 3 : 12 or greater In compliance with FBC Chapter 15 based on the type of roof covering, applicable code sections and in accordance with manufacturer's recommendations.
Performance:	Wind Uplift Resistance: • Design Uplift Pressure: Refer to Table A (Refer to "Table A" attachment details herein)

Performance Standards:	The product described herein has demonstrated compliance with: • UL580-06 – <i>Test for Uplift Resistance of Roof Assemblies</i> • TAS 125-03 – <i>Standard Requirements for Metal Roofing Systems</i>
Standards Equivalency:	The UL 580-94 standard version used to test the evaluated product assembly is equivalent with the prescribed standards in UL 580-06 adopted by the Florida Building Code 8th Edition (2023).
Code Compliance:	The product(s) described herein have demonstrated compliance with the performance standards listed above as referenced in the Florida Building Code 8th Edition (2023).
Evaluation Report Scope:	This product evaluation is limited to compliance with the structural requirements of the Florida Building Code, as related to the scope section to Florida Product Approval Rule 61G20-3.001.
Limitations and Conditions of Use:	• This evaluation report for “Optional Statewide Approval” contains technical documentation, specifications and installation method(s) which include “Limitations and Conditions of Use” throughout the report in accordance with Rule 61G20-3.005. Per Rule 61G20-3.004, the Florida Building Commission is the authority to approve products under “Optional Statewide Approval”. • Option for application outside “Limitations and Conditions of Use” • Rule 61G20-3.005(1)(e) allows engineering analysis for “project specific approval by the local authorities having jurisdiction in accordance with the alternate methods and materials authorized in the Code”. Any modification of the product as evaluated in this report and approved by the Florida Building Commission is outside the scope of this evaluation and will be the responsibility of others. • This report is a building code product evaluation per FLPE rule (FAC) 61G15-36 to comply with Florida product approval rule (FAC) 61G20-3. This evaluation report is part of the Florida Building Commission approval for the listed code related criteria. This report by James Buckner, P.E. and CBUCK Engineering is not a design certification of code compliance construction submittal documentation, per FBC section 107, for any individual structure, site specific or permit design. • Deck shall be in compliance with applicable building code. • Design of support system is outside the scope of this report. • Fire Classification is outside the scope of Rule 61G20-3, and is therefore not included in this evaluation. • This evaluation report does not evaluate the use of this product for use in the High Velocity Hurricane Zone code section. (Dade & Broward Counties)
Quality Assurance:	The manufacturer has demonstrated compliance of roof panel products in accordance with the Florida Building Code and Rule 61G20-3.0005 (3) for manufacturing under a quality assurance program audited by an approved quality assurance entity through Keystone Certifications, Inc. (FBC Organization ID# QUA 1824).

**Components/Materials
(by Manufacturer):**

Roof Panel:
Material: Englert Series 1100 Aluminum
Thickness: 0.032" (min.)
Panel Widths: 16" (max.) Coverage
Rib Height: 1-1/4"
Alloy Type: 3105-H14 (in compliance with ASTM B 209)
Corrosion Resistance: Per FBC Section 1507.4.3

Roof Panel Clips:

Product Name: Englert "Series 1100 Clip"
Englert Part #: 05079A (Galv. Steel) or 05079F (Stainless Steel)
Type: One-piece, fixed clip
Material: Galvanized Steel or Stainless Steel
Thickness: 24 Gauge min,
Yield Strength: 40 ksi min.
Dimensions: 1-3/16" (tall) x 1-15/16" (long) x 3" (wide)
Corrosion Resistance: Per FBC Section 1506.7

Fastener:

Type: Pancake-Head Wood Screw
Size: #10 x 1"
Corrosion Resistance: Per FBC Section 1506.6 and 1507.4.4
Standard: Per ANSI/ASME B18.6.1

**Components& Materials: Seam Adhesive/Sealant:
(by Others)**

Product Name: Bostik 915
Type: One component, polyurethane adhesive
Application Size: 1/8" bead
Application Location: along female flange the full length of panel
(Refer to drawing Page 7)

Insulation (Optional):

Type: Rigid Insulation Board
Thickness: 3" (max.)
Properties:
Density: 2.25 pcf (lbs/ft³) min.
Or Compressive Strength: 20 psi min.

Insulation Notes:

- Rigid Insulation shall meet minimum density OR compressive strength.
- Insulation shall comply with FBC Section 1508. When insulation is incorporated, fastener length shall conform to penetrate thru bottom of support a minimum of 3/16".

Installation:

Installation Method:

(Refer to "TABLE A" below and drawings at the end of this evaluation report.)

- Clip Spacing: **Refer to "TABLE A" Below**
(along the length of the panel)
- Two (2) fasteners per Clip
- Rib Interlock: Snap-Lock
(Panel ribs shall be fully engaged to form an integral snap-lock.)
- Minimum fastener penetration thru bottom of support, 3/16".
- For panel construction at the end of panels, refer to manufacturer's instructions and any site specific design.

TABLE "A" ALLOWABLE LOADS "Series 1100" (.032" Aluminum) Roof Panel attached to Wood Deck								
#	Panel Width (max.)	Deck Thickness (min.)	Panel Clip	Clip Spacing (max.)	# of Fasteners per Clip	Seam Adhesive	Panel Seam (min.)	Design Pressure (ASD)
1	16"	19/32"	3" Fixed	24"	2	NO	SnapLock	- 37.5 PSF
2	16"	15/32"	3" Fixed	12"	2	YES	SnapLock	- 105 PSF
Note: Allowable design pressure(s) for allowable stress design (ASD).								

Install the "Series 1100" roof panel assembly in compliance with the installation method listed in this report and applicable code sections of FBC 8th Edition (2023). The installation method described herein is in accordance with the scope of this evaluation report. Refer to manufacturer's installation instructions as a supplemental guide for attachment.

Referenced Data:


1. Uplift Class 60 Based on UL580 Uplift Test
By Hurricane Test Laboratories, Inc. (FBC Organization #TST ID: 1527)
Report #0155-0713-04, Specimen #2 (#1) Date: 9/21/04
2. TAS 125 Uplift Test
By Intertek/Architectural Testing, Inc. (FBC Organization ID# TST 1558)
Report No. F5010.01-109-18-r0 (#2) Date: 3/08/16
3. Quality Assurance
Keystone Certifications, Inc. (FBC Organization ID# QUA 1824)
Englert, Inc. Licensee #420
4. Equivalency of Test Standard Certification
By James L. Buckner, P.E. @ CBUCK Engineering
(FBC Organization # ANE 1916)
5. Engineering Analysis
By James L. Buckner, P.E. @ CBUCK Engineering
(FBC Organization # ANE 1916)
6. Certification of Independence
By James L. Buckner, P.E. @ CBUCK Engineering
(FBC Organization # ANE 1916)

Installation Method


Englert, Inc.

"Series 1100" (0.032" Aluminum) Roof Panel attached to Wood Deck

Drawings



Panel Profile



Panel Clip Profile


Englert "Series 1100 Clip"

Part # 05079A (Galv. Steel) or 05079F (Stainless Steel)

Installation Method


Englert, Inc.

"Series 1100" (0.032" Aluminum) Roof Panel attached to Wood Deck



**Typical Assembly Profile View
(Typical Fastening Pattern Across Width)**

Installation Method
Englert, Inc.
“Series 1100” (0.032” Aluminum) Roof Panel attached to Wood Deck



Typical Roof Assembly Isometric View

(Optional) Rigid Insulation Board per Page 4 of this report

TABLE "A" ALLOWABLE LOADS "Series 1100" (.032" Aluminum) Roof Panel attached to Wood Deck								
#	Panel Width (max.)	Deck Thickness (min.)	Panel Clip	Clip Spacing (max.)	# of Fasteners per Clip	Seam Adhesive	Panel Seam (min.)	Design Pressure (ASD)
1	16"	19/32"	3" Fixed	24"	2	NO	SnapLock	- 37.5 PSF
2	16"	15/32"	3" Fixed	12"	2	YES	SnapLock	- 105 PSF

Note: Allowable design pressure(s) for allowable stress design (ASD).