



**NEMO|etc.**

Certificate of Authorization #32455  
353 Christian Street, Unit #13  
Oxford, CT 06478  
(203) 262-9245

ENGINEER

EVALUATE

TEST

CONSULT

**EVALUATION REPORT**

**GAF**

1 Campus Drive  
Parsippany, NJ 07054  
**(800) 766-3411**

**Evaluation Report 01506.01.08-BUR-R18**

**FL11946-R18**

**Date of Issuance: 01/02/2009**

**Revision 18: 12/15/2021**

**SCOPE:**

This Evaluation Report is issued under **Rule 61G20-3** and the applicable rules and regulations governing the use of construction materials in the State of Florida. The documentation submitted has been reviewed by Robert Nieminen, P.E. for use of the product under the Florida Building Code. The product described herein has been evaluated for compliance with the **7<sup>th</sup> Edition (2020) Florida Building Code** sections noted herein.

**DESCRIPTION: GAF Conventional Built-Up Roof Systems for use in FBC non-HVHZ jurisdictions**

**LABELING:** Labeling shall be in accordance with the requirements of the Accredited Quality Assurance Agency noted herein.

**CONTINUED COMPLIANCE:** This Evaluation Report is valid until such time as the named product(s) changes, the referenced Quality Assurance or production facility location(s) changes, or Code provisions that relate to the product(s) change. Acceptance of our Evaluation Reports by the named client constitutes agreement to notify NEMO ETC, LLC of any changes to the product(s), the Quality Assurance or the production facility location(s). NEMO ETC, LLC requires a complete review of its Evaluation Report relative to updated Code requirements with each Code Cycle.

**ADVERTISEMENT:** The Florida Product Approval Number (FL#) preceded by the words **"NEMO Evaluated"** may be displayed in advertising literature. If any portion of the Evaluation Report is displayed, then it shall be done in its entirety.

**INSPECTION:** Upon request, a copy of this entire Evaluation Report shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This Evaluation Report consists of pages 1 through 5, plus a 30-page Appendix.

**Prepared by:**

**Robert J.M. Nieminen, P.E.**

Florida Registration No. 59166, Florida DCA ANE1983



The facsimile seal appearing was authorized by Robert Nieminen, P.E. on 12/15/2021. This does not serve as an electronically signed document.

**CERTIFICATION OF INDEPENDENCE:**

1. NEMO ETC, LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products it evaluates.
2. NEMO ETC, LLC is not owned, operated or controlled by any company manufacturing or distributing products it evaluates.
3. Robert Nieminen, P.E. does not have nor will acquire, a financial interest in any company manufacturing or distributing products for which the evaluation reports are being issued.
4. Robert Nieminen, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.
5. This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this Evaluation Report, or previous versions thereof, is/was used for permitting or design guidance unless retained specifically for that purpose.

**ROOFING SYSTEM EVALUATION:**
**1. SCOPE:**

**Product Category:** Roofing  
**Sub-Category:** Built-Up Roofing Systems  
**Compliance Statement:** **GAF Conventional Built-Up Roof Systems**, as produced by **GAF**, have demonstrated compliance with the following sections of the **7<sup>th</sup> Edition (2020) Florida Building Code** through testing in accordance with the following Standards. Compliance is subject to the Installation Requirements and Limitations / Conditions of Use set forth herein.

**2. STANDARDS:**

Section	Property	Standard	Year
1504.3.1	Wind resistance	FM 4474	2011
1504.7	Impact resistance	FM 4470	2016
1507.10.2	Material standard	ASTM D2178	2015
1507.10.2	Material standard	ASTM D3909	2014
1507.10.2	Material standard	ASTM D4601	2012
1507.10.2	Material standard	ASTM D4897	2009
1507.11.2	Material standard	ASTM D6163	2015
1507.11.2	Material standard	ASTM D6164	2011
1507.11.2	Material standard	ASTM D6222	2011

**3. REFERENCES:**

Entity	Examination	Reference	Date	Entity	Examination	Reference	Date
ERD (TST6049)	ASTM D6222 (GA)	G43190.11.13-1	11/15/13	FM (TST1867)	FM 4470 / 4474	3041769	09/27/12
ERD (TST6049)	ASTM D6163 (GA)	G40630.01.14-1	01/06/14	FM (TST1867)	FM 4470 / 4474	797-09636-267	07/24/14
ERD (TST6049)	ASTM D6164 (GA)	G40630.01.14-2A	01/07/14	FM (TST1867)	FM 4470 / 4474	797-09662-267	07/24/14
ERD (TST6049)	ASTM D6164 (GA)	G40630.01.14-2A-1-R1	01/07/14	FM (TST1867)	FM 4470 / 4474	797-09665-267	07/24/14
ERD (TST6049)	ASTM D6222 (IN)	G43180.03.14	03/03/14	FM (TST1867)	FM 4470 / 4474	797-09934-267	10/23/14
ERD (TST6049)	ASTM D6222 (GA)	G43190.05.14-R1	05/14/14	FM (TST1867)	FM 4470 / 4474	797-09972-267	10/27/14
ERD (TST6049)	ASTM D3909	SC6870.08.14	08/19/14	FM (TST1867)	FM 4470 / 4474	797-09973-267	10/27/14
ERD (TST6049)	ASTM D6163 (GA)	G46160.02.15-2D-1	02/09/16	FM (TST1867)	FM 4470 / 4474	797-10025-267	11/12/14
ERD (TST6049)	ASTM D6164 (GA)	GAF-SC13285.03.17-5	03/23/17	FM (TST1867)	Criticality	3056207 (released)	02/09/16
ERD (TST6049)	ASTM D6164 (GA)	GAF-SC13105.03.17-R1	03/23/17	FM (TST1867)	FM 4470 / 4474	3061784	07/25/18
NEMO (TST6049)	ASTM D6222 (GA)	G40620.07.12-2-R1	07/17/12	FM (TST1867)	FM 4470 / 4474	3055904	10/25/18
NEMO (TST6049)	ASTM D2178 (GA)	4S-GAF-18-001.01.19-1	01/02/19	FM (TST1867)	FM 4470 / 4474	RR215191-267	11/07/18
NEMO (TST6049)	ASTM D6222 (IN)	4S-GAF-18-001.03.19.A	03/13/19	FM (TST1867)	Criticality	PR452971-R1	01/28/20
NEMO (TST6049)	ASTM D6164 (AR)	4q-GAF-19-SSMBB-01A	04/08/19	FM (TST1867)	FM 4474	PR455417	12/23/20
NEMO (TST6049)	ASTM D6163 (AR)	4q-GAF-19-SSMBB-02A	04/08/19	FM (TST1867)	FM 4474	PR458073	04/08/21
NEMO (TST6049)	ASTM D3909	4q-GAF-20-SSMBB-01.A	03/04/21	FM (TST1867)	FM 4470	RR227768	04/09/21
NEMO (TST6049)	ASTM D4601 (AL)	4q-GAF-21-SSMBB-01.A	09/07/21	FM (TST1867)	FM 4470	PR459831	04/21/21
NEMO (TST6049)	ASTM D4897 (AL)	4q-GAF-21-SSMBB-01.B	09/07/21	FM (TST1867)	FM 4474	PR456101	06/24/21
NEMO (TST6049)	ASTM D3909	4q-GAF-21-SSMBB-02.A	12/02/21	IRT (TST7408)	TAS 114	00001	04/05/00
PRI (TST5878)	ASTM D2178 (AL)	MSA-039-02-02	09/27/17	IRT (TST7408)	TAS 114	00002	04/05/00
PRI (TST5878)	ASTM D2178 (AL)	MSA-039-02-01	09/27/17	IRT (TST7408)	TAS 114	01-0136	12/18/01
ACRC (TST4671)	TAS 114	ACRC 11-048	08/10/11	IRT (TST7408)	TAS 114	02-005	01/18/02
ACRC (TST4671)	TAS 114	ACRC 11-049	08/10/11	IRT (TST7408)	TAS 114	02-011	02/26/02
ACRC (TST4671)	TAS 114	ACRC 11-053	08/12/11	IRT (TST7408)	TAS 114	02-014	03/22/02
ERD (TST6049)	TAS 114	01880.09.03	09/10/03	IRT (TST7408)	TAS 114	02-015	03/26/02
ERD (TST6049)	TAS 114/FM4474	GAF-SC16825.12.17-1	12/31/17	IRT (TST7408)	TAS 114	02-026	07/26/02
FM (TST1867)	FM 4470 / 4450	2B8A4.AM	07/02/97	IRT (TST7408)	TAS 114	04-009	01/26/04
FM (TST1867)	FM 4470 / 4450	3B9Q1.AM	01/08/98	NEMO (TST6049)	FM 4470 / 4474	4L-GAF-18-002.05.19.A	05/29/19
FM (TST1867)	FM 4470 / 4450	0Y9Q5.AM	04/01/98	PRI (TST5878)	FM 4470 / 4474	GAF-549-02-01	08/08/14
FM (TST1867)	FM 4470 / 4450	OD0A8.AM	07/09/99	PRI (TST5878)	FM 4470 / 4474	GAF-549-02-02	08/08/14
FM (TST1867)	FM 4470 / 4450	3011140	08/14/01	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-01	10/16/14
FM (TST1867)	FM 4470 / 4450	3014547	05/22/03	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-04	10/16/14
FM (TST1867)	FM 4470 / 4474	3017250	04/05/04	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-05	10/16/14
FM (TST1867)	FM 4470 / 4474	3020703	07/30/04	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-06	10/16/14
FM (TST1867)	FM 4470 / 4474	3025524	03/13/06	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-07	10/16/14
FM (TST1867)	FM 4470 / 4474	3023458	07/18/06	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-08	10/16/14

Entity	Examination	Reference	Date	Entity	Examination	Reference	Date
FM (TST1867)	FM 4470 / 4474	3028478	01/05/07	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-09	10/16/14
FM (TST1867)	FM 4470 / 4474	3029832	05/11/07	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-11	10/16/14
FM (TST1867)	FM 4470 / 4474	Approval Extension	05/07/08	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-12	10/16/14
FM (TST1867)	FM 4470 / 4474	797-05610-267	06/10/10	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-13	10/16/14
FM (TST1867)	FM 4470 / 4474	797-05695-267	07/15/10	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-14	10/16/14
FM (TST1867)	FM 4470 / 4474	797-05748-267	08/10/10	PRI (TST5878)	FM 4470 / 4474	GAF-559-02-18	10/16/14
FM (TST1867)	FM 4470 / 4474	797-05970-267	10/25/10	PRI (TST5878)	Criticality	376T0006-3	09/06/19
FM (TST1867)	FM 4470 / 4474	797-05550-267	10/25/10	PRI (TST5878)	Criticality	376T0006-1	01/18/21
FM (TST1867)	FM 4470 / 4474	3043900	08/16/12	UL (QUA9625)	Quality Control	Service Confirm	06/10/21
FM (TST1867)	FM 4470 / 4474	3046388	09/24/12	UL (QUA9625)	Quality Control	Florida BCIS	Current

#### 4. PRODUCT DESCRIPTION:

This Evaluation Report covers GAF Built-Up Roof Systems (BUR) installed in accordance with GAF published installation instructions and the Limitations / Conditions of Use herein.

TABLE 1: EVALUATED MEMBRANES				
Type	Product	Material Standard		Plant(s)
		Reference	Type	
Base Sheet	GAFGLAS® #75 Base Sheet	ASTM D4601	II	AL
	Tri-Ply® #75 Base Sheet	ASTM D4601	II	AL
	GAFGLAS® #80 Ultima™ Base Sheet	ASTM D4601	II	AL
	GAFGLAS® Stratavent® Nailable Venting Base Sheet	ASTM D4897	II	AL
Venting Base Sheet	GAFGLAS® Stratavent® Perforated Venting Base Sheet	ASTM D4897	II	AL
Ply Sheet	GAFGLAS® Ply 4	ASTM D2178	IV	GA
	GAFGLAS® Ply 4 M	ASTM D2178	IV	AL
	Tri-Ply® Ply 4 Ply Sheet	ASTM D2178	IV	GA
	GAFGLAS® FlexPly™ 6	ASTM D2178	VI	GA
	GAFGLAS® FlexPly™ 6 M	ASTM D2178	VI	AL
Ply Sheet, Modified Bitumen	Ruberoid® 20 Smooth	ASTM D6163	I	AR
	Ruberoid® Mop Smooth	ASTM D6164	I	GA
	Ruberoid® Mop Smooth 1.5	ASTM D6164	I	GA
Cap Sheet	GAFGLAS® Mineral-Surfaced Cap Sheet	ASTM D3909	N/A	AL, CA-F, GA
	Tri-Ply® BUR Granule Cap Sheet	ASTM D3909	N/A	AL, CA-F, GA
	GAFGLAS® EnergyCap™ Mineral-Surfaced Cap Sheet	ASTM D3909	N/A	CA-S
Vapor Barrier Membranes	Ruberoid® 20 Smooth	ASTM D6163	I	AR
	Ruberoid® HW 25 Smooth	ASTM D6163	I	GA
	Ruberoid® 30 Granule	ASTM D6163	I	GA
	Ruberoid® HW Smooth	ASTM D6164	I	GA
	Ruberoid® Mop Smooth	ASTM D6164	I	GA
	Ruberoid® Mop Smooth 1.5	ASTM D6164	I	GA
	Liberty™ SBS Self-Adhering Cap Sheet	ASTM D6164	I	AR, GA, IN
	Ruberoid® Torch Smooth	ASTM D6222	I	GA, IN
	Ruberoid® Torch Granule	ASTM D6222	I	GA, IN

## 5. LIMITATIONS:

- 5.1 This is a Building Code Evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this Evaluation Report, or previous versions thereof, is/was used for permitting or design guidance unless retained specifically for that purpose.
- 5.2 This Evaluation Report is not for use in FBC High Velocity Hurricane Zone jurisdictions (i.e., Broward and Miami-Dade Counties).
- 5.3 This Evaluation Report pertains to above-deck roof components. Roof decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction.
- 5.4 This Evaluation Report does not include evaluation of fire classification. Refer to **FBC 1516** for requirements and limitations regarding roof assembly fire classification. Refer to **FBC 2603** for requirements and limitations concerning the use of foam plastic insulation.
- 5.5 This Evaluation Report does not include evaluation of roof edge termination. Refer to **FBC 1504.5** for requirements and limitations regarding edge securement for low-slope roofs.
- 5.6 Refer to **FBC 1511** for requirements and limitations regarding recover installations.
- 5.6.1 For mechanically attached components over existing roof decks, fasteners shall be tested in the existing deck for withdrawal resistance. A qualified design professional shall review the data for comparison to the minimum requirements for the system. Testing shall be in accordance with **ANSI/SPRI FX-1** or **Testing Application Standard TAS 105**.
- 5.6.2 For bonded insulation or membrane over existing substrates in a re-roof (tear off) or recover installation, the existing deck or existing roof surface shall be examined for compatibility with the adhesive to be installed. If any surface conditions exist that bring system performance into question, field uplift testing in accordance with **ANSI/SPRI IA-1**, **ASTM E907**, **FM Loss Prevention Data Sheet 1-52** or **Testing Application Standard TAS 124** shall be conducted on mock-ups of the proposed new roof assembly.
- 5.6.3 For bonded insulation or membrane over existing substrates in a recover installation, the existing roof system shall be capable of resisting project design pressures on its own merit to the satisfaction of the Authority Having Jurisdiction, as documented through field uplift testing in accordance with **ASTM E907**, **FM Loss Prevention Data Sheet 1-52** or **Testing Application Standard TAS 124**.
- 5.7 Refer to Appendix 1 for system attachment requirements for wind load resistance.
- 5.7.1 “MDP” = Maximum Design Pressure is the result of testing for wind load resistance based on allowable wind loads, and reflects the ultimate passing pressure divided by 2 (the 2 to 1 margin of safety per **FBC 1504.9** has already been applied). Refer to **FBC 1609** for determination of design wind loads.
- 5.7.2 For mechanically attached components or partially-bonded insulation, the maximum design pressure for the selected assembly shall meet or exceed the Zone 1 design pressure determined in accordance with **FBC Chapter 16**. Zones 2 and 3 shall employ an attachment density designed by a qualified design professional to resist the elevated pressure criteria. Commonly used methods are **ANSI/SPRI WD1**, **FM Loss Prevention Data Sheet 1-29**, **Roofing Application Standard RAS 117** and **Roofing Application Standard RAS 137**. Assemblies marked with an asterisk\* carry the limitations set forth in **Section 2.2.10.1 of FM Loss Prevention Data Sheet 1-29 (February 2020)** for Zone 2/3 enhancements.
- 5.7.2 For assemblies with all components fully bonded in place, the maximum design pressure for the selected assembly shall meet or exceed critical design pressure determined in accordance with **FBC Chapter 16**. No rational analysis is permitted for these systems.
- 5.8 All components in the roof assembly shall have quality assurance audit in accordance with **F.A.C. Rule 61G20-3**. Refer to the Product Approval of the component manufacturer for components listed in Appendix 1 that are produced by a Product Manufacturer other than the report holder on Page 1 of this Evaluation Report.

**6. INSTALLATION:**

**GAF Conventional Built-Up Roof Systems** shall be installed in accordance with **GAF** published installation instructions, subject to the Limitations / Conditions of Use herein.

**7. BUILDING PERMIT REQUIREMENTS:**

As required by the Building Official or Authority Having Jurisdiction to properly evaluate the installation of this product.

**8. MANUFACTURING PLANTS:**

Contact the named QA entity for manufacturing facilities covered by **F.A.C. Rule 61G20-3** QA requirements. Refer to Section 4 herein for products and production locations having met codified physical properties specifications.

**9. QUALITY ASSURANCE ENTITY:**

UL, LLC – QUA9625: (613) 371-2765; [Jacob.Stewart@ul.com](mailto:Jacob.Stewart@ul.com)

**- THE 30-PAGES THAT FOLLOW FORM PART OF THIS EVALUATION REPORT -**

**APPENDIX 1: ATTACHMENT REQUIREMENTS FOR WIND UPLIFT RESISTANCE**

TABLE	DECK	APPLICATION	TYPE	DESCRIPTION	PAGE
1A	Wood	New or Reroof (Tear-Off)	A-2	Mech. Attached Anchor Sheet (nails & caps), Bonded Insulation, Bonded Roof Cover	5
1b	Wood	New, Reroof (Tear-Off) or Recover	A-2	Mech. Attached Anchor Sheet (screws & plates), Bonded Insulation, Bonded Roof Cover	6-7
1c	Wood	New, Reroof (Tear-Off) or Recover	B-1	Mech. Attached Base Insulation, Bonded Top Insulation, Bonded Roof Cover	7
1D	Wood	New, Reroof (Tear-Off) or Recover	C-1	Mech. Attached Insulation, Bonded Roof Cover	8
1E	Wood	New, Reroof (Tear-Off) or Recover	D-2	Insulated, Mech. Attached Base Sheet, Bonded Roof Cover	8
1F	Wood	New or Reroof (Tear-Off)	E-2	Non-Insulated, Mech. Attached Base Sheet (nails & caps), Bonded Roof Cover	9
1G	Wood	New, Reroof (Tear-Off) or Recover	E-2	Non-Insulated, Mech. Attached Base Sheet (screws & plates), Bonded Roof Cover	9
2A	Steel or Structural Concrete	New, Reroof (Tear-Off) or Recover	B-1	Mech. Attached Base Insulation, Bonded Top Insulation, Bonded Roof Cover	10-11
2B	Steel or Structural concrete	New, Reroof (Tear-Off), Recover	B-2	Mech. Attached Thermal Barrier, Bonded Vapor Retarder, Bonded Insulation, Bonded Roof Cover	11-12
2c	Steel or Structural Concrete	New, Reroof (Tear-Off) or Recover	C-1	Mech. Attached Insulation, Bonded Roof Cover	12-14
2D	Steel or Structural Concrete	New, Reroof (Tear-Off) or Recover	D-2	Insulated, Mech. Attached Base Sheet, Bonded Roof Cover	14
3A	Structural Concrete	New or Reroof (Tear-Off)	A-1	Bonded Insulation, Bonded Roof Cover	15-17
3B	Structural Concrete	New or Reroof (Tear-Off)	F	Non-Insulated, Bonded Roof Cover	17
4A	Lightweight concrete	New or Reroof (Tear-Off)	A-1	Bonded Insulation, Bonded Roof Cover	18
4b	Lightweight concrete	New or Reroof (Tear-Off)	A-2	Mech. Attached Anchor Sheet, Bonded Insulation, Bonded Roof Cover	18-19
4c	Lightweight concrete	New or Reroof (Tear-Off)	E-2	Non-Insulated, Mech. Attached Base Sheet, Bonded Roof Cover	20
4D	Lightweight concrete	New or Reroof (Tear-Off)	F	Non-Insulated, Bonded Roof Cover	20
5A	Cementitious wood fiber	Reroof (Tear-Off) or Recover	A-2	Mech. Attached Anchor Sheet, Bonded Insulation, Bonded Roof Cover	21
5B	Cementitious wood fiber	Reroof (Tear-Off) or Recover	B-1	Mech. Attached Base Insulation, Bonded Top Insulation, Bonded Roof Cover	22
5C	Cementitious wood fiber	Reroof (Tear-Off) or Recover	C-1	Mech. Attached Insulation, Bonded Roof Cover	23
5D	Cementitious wood fiber	Reroof (Tear-Off) or Recover	D-2	Insulated, Mech. Attached Base Sheet, Bonded Roof Cover	23
5E	Cementitious wood fiber	Reroof (Tear-Off) or Recover	E-2	Non-Insulated, Mech. Attached Base Sheet, Bonded Roof Cover	24
6A	Existing gypsum	Reroof (Tear-Off)	A-2	Mech. Attached Anchor Sheet, Bonded Insulation, Bonded Roof Cover	25-26
6B	Existing gypsum	Reroof (Tear-Off)	B-1	Mech. Attached Base Insulation, Bonded Top Insulation, Bonded Roof Cover	26-27
6C	Existing gypsum	Reroof (Tear-Off)	C-1	Mech. Attached Insulation, Bonded Roof Cover	27
6D	Existing gypsum	Reroof (Tear-Off)	D-2	Insulated, Mech. Attached Base Sheet, Bonded Roof Cover	28
6E	Existing gypsum	Reroof (Tear-Off)	E-2	Non-Insulated, Mech. Attached Base Sheet, Bonded Roof Cover	28
7A	Various	Recover	A-1	Bonded Insulation, Bonded Roof Cover	29-30
7B	Various	Recover	F	Non-Insulated, Bonded Roof Cover	30

**The following notes apply to the systems outlined herein:**

- The roof system evaluation herein pertains to above-deck roof components. Roof decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction.
- Unless otherwise noted, fasteners and stress plates shall be as follows. Fasteners shall be of sufficient length for the following engagements:
  - Wood Deck: Drill-Tec #12 Fastener or Drill-Tec #14 Fastener with Drill-Tec 3" Standard Steel Plate, Drill-Tec 3" Steel Plate or Drill-Tec AccuTrac Flat Plate or Drill-Tec AccuTrac Recessed Plate (insulation only), Drill-Tec ASAP 3S, Drill-Tec Heavy Duty ASAP Roofing Fastener Assembled with a 3" Metal Plate, Drill-Tec #12 DP Fastener or Drill-Tec #14 HD Fastener with Drill-Tec 3" Flat Steel Plate, Drill-Tec #12 DPH Fastener with Drill-Tec 3" Recessed Steel Plate, Drill-Tec 3" ASAP Flat or Drill-Tec 3" ASAP Recessed. Minimum 0.75-inch plywood penetration or minimum 1-inch wood plank embedment.
  - Steel Deck: Drill-Tec #12 Fastener, Drill-Tec #14 Fastener or Drill-Tec XHD Fastener with Drill-Tec 3" Standard Steel Plate, Drill-Tec 3" Steel Plate or Drill-Tec AccuTrac Flat Plate or Drill-Tec AccuTrac Recessed Plate (insulation only); Drill-Tec ASAP 3S; Drill-Tec Heavy Duty ASAP Roofing Fastener Assembled with a 3" Metal Plate; Drill-Tec Extra Heavy Duty ASAP Roofing Fastener -



- Insulation, Drill-Tec #12 DP Fastener, Drill-Tec #14 HD Fastener or Drill-Tec #15 EHD Fastener with Drill-Tec 3" Flat Steel Plate, Drill-Tec #12 DPH Fastener with Drill-Tec 3" Recessed Steel Plate, Drill-Tec 3" ASAP Flat or Drill-Tec 3" ASAP Recessed. Minimum 0.75-inch steel penetration and engage the top flute of the steel deck.
- Structural Concrete: Drill-Tec #14 Fastener or Drill-Tec CD-10 with Drill-Tec 3" Standard Steel Plate, Drill-Tec 3" Steel Plate or Drill-Tec AccuTrac Flat Plate or Drill-Tec AccuTrac Recessed Plate (insulation only), Drill-Tec Heavy Duty ASAP Roofing Fastener Assembled with a 3" Metal Plate, Drill-Tec #14 HD Fastener with Drill-Tec 3" Flat Steel Plate or Drill-Tec 3" ASAP Flat (#14 only). Minimum 1-inch embedment. Fasteners installed with a pilot hole in accordance with the fastener manufacturer's published installation instructions.
- 3 Unless otherwise noted, insulation may be any one layer or combination of FBC Approved (Local or Statewide) board(s) that meet FBC 1505 and, for foam plastic, FBC Chapter 26, when installed with the roof cover.
  - 4 Minimum 200 psi, minimum 2-inch thick FBC Approved lightweight insulating concrete may be substituted for, or installed below, rigid insulation board for System Types B-1, C-1, C-2, D-1 or D-2, whereby fasteners are installed through the lightweight insulating concrete to engage the structural deck. The structural deck shall be of equal or greater type, thickness and strength to the steel and structural concrete deck listings. Roof decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction. This is a wind uplift resistance allowance and does not purport to address non-wind-uplift-related issues, such as deck venting or moisture levels within the LWIC and the potential effect on overlying components.
  - 5 Preliminary insulation attachment for System Type D: Unless otherwise noted, refer to Section 2.2.10.1.3 of FM Loss Prevention Data Sheet 1-29 (February 2020).
  - 6 Unless otherwise noted, insulation adhesive application rates are as follows. Ribbon or bead width is at the time of application; the ribbons/beads shall expand as noted in the manufacturer's published instructions.
    - Hot asphalt (HA): Full Coverage at 25-30 lbs/square. If applying to concrete deck; deck shall be primed with ASTM D41 primer.
    - GAF LRF Adhesive M (LRF-M): Continuous 0.75 to 1-inch wide ribbons, 12-inch o.c.
    - GAF LRF Adhesive XF (LRF-XF): Continuous 0.75 to 1-inch wide ribbons, 12-inch o.c.
    - OlyBond 500 (OB500): Continuous 0.75 to 1-inch wide ribbons, 12-inch o.c. using OMG PaceCart, SpotShot or Canister delivery methods. *Note: OlyBond Classic may be used where OlyBond 500 is referenced*
    - *Note: When multiple layers(s) of insulation and/or coverboard are installed in ribbon-applied adhesive, board joints shall be staggered.*
    - *Note: The maximum edge distance from the adhesive ribbon to the edge of the insulation board shall be not less than one-half the specified ribbons spacing.*
  - 7 Unless otherwise noted, all insulations are flat-stock or taper board of the minimum thickness noted. Tapered polyisocyanurate at the following thickness limitations may be substituted with the following Maximum Design Pressure (MDP) limitations. In no case shall these values be used to 'increase' the MDP listings in the tables; rather if MDP listing below meets or exceeds that listed for a particular system in the tables, then the thinner board listed below may be used as a drop-in for the equivalent thicker material listed in the table.
 

➤ Hot asphalt (HA):	MDP = -240.0 psf (Min. 0.5-inch thick)
➤ GAF LRF Adhesive M (LRF-M):	MDP = -232.5 psf (Min. 0.5-inch thick EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation)
➤ GAF LRF Adhesive XF (LRF-XF) or OlyBond 500 (OB500):	MDP = -292.5 psf (Min. 0.5-inch thick EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation)
➤ OlyBond 500 (OB500):	MDP = -315.0 psf (Min. 0.5-inch thick EnergyGuard RH or RN)
➤ GAF LRF Adhesive XF (LRF-XF) or OlyBond 500 (OB500):	MDP = -487.5 psf (Min. 0.5-inch thick EnergyGuard RA)
  - 8 For adhered roof insulation and board-size: Unless otherwise noted, refer to Section 2.2.10.6.2 of FM Loss Prevention Data Sheet 1-29 (February 2020).
  - 9 For mechanically attached components or partially-bonded insulation, the maximum design pressure for the selected assembly shall meet or exceed at least the Zone 1 PRIME design pressure determined in accordance with FBC Chapter 16. Elevated pressure zones shall employ an attachment density designed by a qualified design professional to resist the elevated pressure criteria. Commonly used methods are ANSI/SPRI WD1, FM Loss Prevention Data Sheet 1-29, Roofing Application Standard RAS 117 and Roofing Application Standard RAS 137. Assemblies marked with an asterisk\* carry the limitations set forth in Section 2.2.10.1 of FM Loss Prevention Data Sheet 1-29 (February 2020) for Zone 2/3 enhancements.
  - 10 For assemblies with all components fully bonded, the maximum design pressure for the selected assembly shall meet or exceed critical design pressure determined in accordance with FBC Chapter 16. No rational analysis is permitted for these systems.
  - 11 For mechanically attached components over existing decks, fasteners shall be tested in the existing deck for withdrawal resistance. A qualified design professional shall review the data for comparison to the minimum requirements for the system. Testing and analysis shall be in accordance with ANSI/SPRI FX-1 or Testing Application Standard TAS 105.
  - 12 For bonded insulation or membrane over existing substrates in a re-roof (tear off) or recover installation, the existing deck or existing roof surface shall be examined for compatibility with the adhesive to be installed. If any surface conditions exist that bring system performance into question, field uplift testing shall be conducted on mock-ups of the proposed new roof assembly. For bonded insulation or membrane

over existing substrates in a recover installation, the existing roof system shall be capable of resisting project design pressures on its own merit to the satisfaction of the Authority Having Jurisdiction, as documented through field uplift testing. Field uplift testing shall be in accordance with ASTM E907, FM Loss Prevention Data Sheet 1-52 or Testing Application Standard TAS 124.

- 13 Refer to FBC 1511 for requirements and limitations regarding recover installations. For Structural Concrete Deck or Recover Applications using System Type C-1, C-2, D-1 or D-2, the insulation is optional. Alternatively, an FBC Approved insulation board or coverboard may be used as a separation layer. Board products shall be preliminarily attached prior to roof cover installation (Note 5 herein). The separator component shall be documented as meeting FBC 1505 and, for foam plastic, FBC Chapter 26, when installed with the roof cover in Recover applications.
- 14 Lightweight insulating concrete (LWIC) shall be cast in accordance with FBC Section 1917 to the satisfaction of the Authority Having Jurisdiction. For systems where specific LWIC is referenced, refer to current LWIC Product Approval for specific deck construction and limitations. Unless otherwise noted, for systems where specific LWIC is not referenced, the minimum design mix shall be 300 psi. In all cases, the minimum top-coat thickness is 2-inches. For LWIC over structural concrete, reference is made to FBC Section 1917.4.1, Point 1. For “pre-existent” LWIC references, listings were established through testing over lightweight concrete cast using only foaming agent (ASTM C896), water and Portland cement (ASTM C150), with no proprietary additives, in accordance with procedures adopted by Miami-Dade BCCO (FBC CER1592). Use of these listings in new construction or re-roof (tear-off) applications is at the discretion of the Designer or Record and Authority Having Jurisdiction.
- 15 For bonded membrane applications, unless otherwise noted, refer to the following.

MEMBRANE / ADHESIVE COMBINATIONS		
REFERENCE	TYPE	APPLICATION
Base Sheet (BS)	Optional base sheet of GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet or GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M	Hot asphalt
Venting Base Sheet (V-BS)	GAFGLAS Stratavent Perforated Venting Base Sheet	Loose-laid
Ply Sheet (PS)	Two or more plies of GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet or GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M	Hot asphalt
Ply Sheet, Modified Bitumen (PS-MB)	One or two plies of GAFGLAS #80 Ultima Base Sheet, Ruberoid 20 Smooth, Ruberoid Mop Smooth or Ruberoid Mop Smooth 1.5	Hot asphalt
Cap Sheet (CS)	Optional cap sheet of GAFGLAS Mineral-Surfaced Cap Sheet, Tri-Ply BUR Granule Cap Sheet or GAFGLAS EnergyCap Mineral-Surfaced Cap Sheet	Hot asphalt

*Note: Systems without a cap sheet shall be surfaced in accordance with GAF requirements, meeting the fire resistance requirements of FBC Section 1505. Refer to FBC Section 1504.8 for limitations in the use of aggregate surfacing.*

- 16 Vapor barrier options for use over structural concrete deck followed by bonded insulation carry the following MDP limitations. The lesser of the MDP listings below vs. those in Table 3A applies.

VAPOR BARRIER OPTIONS; STRUCTURAL CONCRETE DECK; FOLLOWED BY ADHESIVE-APPLIED INSULATION PER TABLE 3A:					
OPTION #	PRIMER	VAPOR BARRIER		ADHESIVE PER TABLE 3A	MDP (PSF)
		TYPE	APPLICATION		
C-VB-1.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	One or two plies, GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet or GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M	Hot asphalt applied	Hot asphalt	-360.0
C-VB-2.	None	GAF SA Vapor Retarder XL	Self-adhering	LRF-M, 12-inch o.c.	-112.5
C-VB-3.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	Ruberoid HW 25 Smooth or Ruberoid HW Smooth	Torch-applied	LRF-M, 12-inch o.c.	-180.0
C-VB-4.	GAF SA Primer	GAF SA Vapor Retarder	Self-adhering	LRF-M, 12-inch o.c.	-202.5
C-VB-5.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	One or two plies, GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet or GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M	Hot asphalt applied	LRF-M, 12-inch o.c.	-495.0
C-VB-6.	None	GAF SA Vapor Retarder XL	Self-adhering	LRF-XF 12-inch o.c.	-112.5
C-VB-7.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	Ruberoid Torch Granule	Torch-applied	LRF-XF, 12-inch o.c.	-169.0
C-VB-8.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	Ruberoid HW 25 Smooth or Ruberoid HW Smooth	Torch-applied	LRF-XF, 12-inch o.c.	-180.0
C-VB-9.	GAF SA Primer	GAF SA Vapor Retarder	Self-adhering	LRF-XF, 12-inch o.c.	-202.5
C-VB-10.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	Liberty SBS Self-Adhering Cap Sheet	Self-adhering	LRF-XF, 12-inch o.c.	-250.0



VAPOR BARRIER OPTIONS; STRUCTURAL CONCRETE DECK; FOLLOWED BY ADHESIVE-APPLIED INSULATION PER TABLE 3A:					
OPTION #	PRIMER	VAPOR BARRIER		ADHESIVE PER TABLE 3A	MDP (PSF)
		TYPE	APPLICATION		
C-VB-11.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	One or two plies, GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet or GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M	Hot asphalt applied	LRF-XF, 12-inch o.c.	-262.5
C-VB-12.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	Ruberoid 30	Hot asphalt applied	LRF-XF, 12-inch o.c.	-270.0
C-VB-13.	None	GAF SA Vapor Retarder XL	Self-adhering	OB500, 12-inch o.c.	-127.5
C-VB-14.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	Ruberoid Torch Smooth	Torch-applied	OlyBond 500, 12-inch o.c.	-165.0
C-VB-15.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	Ruberoid HW 25 Smooth	Torch-applied	OlyBond 500, 12-inch o.c.	-180.0
C-VB-16.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	Liberty SBS Self-Adhering Cap Sheet	Self-adhering	OlyBond 500, 12-inch o.c.	-187.5
C-VB-17.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	Ruberoid 20 Smooth	Matrix 102 SBS Membrane Adhesive at 1.5 gal/square	OlyBond 500, 12-inch o.c.	-202.5
C-VB-18.	GAF SA Primer	GAF SA Vapor Retarder	Self-adhering	OlyBond 500, 12-inch o.c.	-202.5
C-VB-19.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	Ruberoid Torch Granule	Torch-applied	OlyBond 500, 12-inch o.c.	-225.0
C-VB-20.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	Ruberoid HW Smooth	Torch-applied	OlyBond 500, 12-inch o.c.	-232.5
C-VB-21.	Matrix 307 Premium Asphalt Primer or ASTM D41 primer	One or two plies, GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet or GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M	Hot asphalt applied	OlyBond 500, 12-inch o.c.	-352.5

17 Fire barriers of FireOut™ Fire Barrier Coating, VersaShield® Solo™ Fire-Resistant Slip Sheet, SECUROCK Gypsum-Fiber Roof Board or SECUROCK Glass-Mat Roof Board are optional in all wood deck assemblies where overlying components are mechanically fastened.

18 The following products are interchangeable within the scope of this Evaluation Report:

ACCEPTABLE ALTERNATES		
Manufacturer	Listed Product	Alternate
GAF	EnergyGuard Polyiso Insulation	EnergyGuard NH Polyiso Insulation
GAF	EnergyGuard Ultra Polyiso Insulation	EnergyGuard NH Ultra Polyiso Insulation
GAF	EnergyGuard HD Polyiso Insulation	EnergyGuard HD Barrier Polyiso Insulation, EnergyGuard NH HD Polyiso Insulation
GAF	EnergyGuard HD Plus Polyiso Insulation	EnergyGuard NH HD Plus Polyiso Insulation
GAF	GAF SA Vapor Retarder XL	GAF SA Vapor Retarder XL40
Georgia-Pacific Gypsum, LLC	“DensDeck Prime”	“DensDeck StormX Prime Roof Board”

19 “MDP” = Maximum Design Pressure is the result of testing for wind load resistance based on allowable wind loads. Refer to FBC 1609 for determination of design wind loads

**TABLE 1A: WOOD DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)**  
**SYSTEM TYPE A-2: MECHANICALLY ATTACHED ANCHOR SHEET (NAILS & CAPS), BONDED INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Anchor Sheet			Insulation		Roof Cover (Note 15)	MDP (psf)
		Type	Fasteners (Note 11)	Attach	Type	Attach (Notes 6,7,8)		
<b>CONVENTIONAL SYSTEMS:</b>								
W-1.	Min. 15/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	32 ga., 1-5/8-inch dia. tin caps with 11 ga. annular ring shank nails	8-inch o.c. at min. 4-inch laps and 8-inch o.c. in two, equally spaced, staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso followed by Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board, Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15.	-45.0
W-2.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet, GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet, GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M, Ruberoid 20 Smooth	32 ga., 1-5/8-inch diameter tin caps with 11 ga. annular ring shank nails	9-inch o.c. at the 4-inch lap and 12-inch o.c. in two staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso followed by Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board, Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15.	-45.0
W-3.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	32 ga., 1-5/8-inch diameter tin caps with 12 ga. annular ring shank nails	8-inch o.c. at the 4-inch lap and 8-inch o.c. in two staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso followed by Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board, Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15.	-52.5
W-4.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Approved 1.25-inch annular ring shank nails and inverted Drill-Tec 3-inch Galvalume Plates	9-inch o.c. at the 4-inch lap and 9-inch o.c. in two staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso followed by Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board, Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15.	-60.0
<b>VENTING SYSTEMS:</b>								
W-5.	Min. 15/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	32 ga., 1-5/8-inch dia. tin caps with 11 ga. annular ring shank nails	8-inch o.c. at min. 4-inch laps and 8-inch o.c. in two, equally spaced, staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso	HA	V-BS followed by GAF BUR Note 15.	-45.0
W-6.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	32 ga., 1-5/8-inch diameter tin caps with 12 ga. annular ring shank nails	8-inch o.c. at the 4-inch lap and 8-inch o.c. in two staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso	HA	V-BS followed by GAF BUR Note 15.	-52.5

**TABLE 1B: WOOD DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER**  
**SYSTEM TYPE A-2: MECHANICALLY ATTACHED ANCHOR SHEET (SCREWS & PLATES), BONDED INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Anchor Sheet			Insulation		Roof Cover (Note 15)	MDP (psf)
		Type	Fasteners (Note 11)	Attach	Type	Attach (Notes 6,7,8)		
<b>CONVENTIONAL SYSTEMS:</b>								
W-7.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet, GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet, GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M, Ruberoid 20 Smooth	Note 2	12-inch o.c. at the 2-inch lap and 12-inch o.c. in two center staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso followed by Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board, Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15.	-45.0
W-8.	Min. 15/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Note 2 (#14 ONLY)	16-inch o.c. at the min. 4-inch lap and 16-inch o.c. in two, equally spaced, staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso followed by Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board, Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15.	-52.5
W-9.	Min. 15/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Note 2 (#14 ONLY)	12-inch o.c. at the min. 4-inch lap and 12-inch o.c. in two, equally spaced, staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso followed by Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board, Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15.	-60.0
W-10.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Note 2	12-inch o.c. at the 2-inch lap and 12-inch o.c. in three staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso followed by Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board, Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15.	-60.0
W-11.	Min. 15/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Note 2 (#14 ONLY)	8-inch o.c. at the 4-inch lap and 8-inch o.c. in three staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso followed by Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board, Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15.	-75.0*
<b>VENTING SYSTEMS:</b>								

TABLE 1B: WOOD DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER								
SYSTEM TYPE A-2: MECHANICALLY ATTACHED ANCHOR SHEET (SCREWS & PLATES), BONDED INSULATION, BONDED ROOF COVER								
System No.	Deck (Note 1)	Anchor Sheet			Insulation		Roof Cover (Note 15)	MDP (psf)
		Type	Fasteners (Note 11)	Attach	Type	Attach (Notes 6,7,8)		
W-12.	Min. 15/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Note 2 (#14 ONLY)	16-inch o.c. at the min. 4-inch lap and 16-inch o.c. in two, equally spaced, staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso	HA	V-BS followed by GAF BUR Note 15.	-52.5
W-13.	Min. 15/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Note 2 (#14 ONLY)	12-inch o.c. at the min. 4-inch lap and 12-inch o.c. in two, equally spaced, staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso	HA	V-BS followed by GAF BUR Note 15.	-60.0
W-14.	Min. 15/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Note 2 (#14 ONLY)	8-inch o.c. at the 4-inch lap and 8-inch o.c. in three staggered center rows	Min. 1-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso	HA	V-BS followed by GAF BUR Note 15.	-82.5*

TABLE 1C: WOOD DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER								
SYSTEM TYPE B-1: MECHANICALLY ATTACHED BASE INSULATION, BONDED TOP INSULATION LAYER, BONDED ROOF COVER								
System No.	Deck (Note 1)	Base Insulation Layer			Top Insulation Layer		Roof Cover (Note 15)	MDP (psf)
		Type	Fasteners (Note 11)	Attach	Type	Attach (Notes 6,7,8)		
W-15.	Min. 19/32-inch plywood at max. 24-inch span	One or more layers Min. 1.3-inch EnergyGuard RA or RN	Note 2	1 per 3.0 ft <sup>2</sup>	Optional one or more layers Min. 1.3-inch EnergyGuard RA or RN followed by Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous) or Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	HA	GAF BUR. Note 15.	-45.0*
W-16.	Min. 19/32-inch plywood at max. 24-inch span	One or more layers Min. 1.5-inch EnergyGuard Composite	Note 2	1 per 3.0 ft <sup>2</sup>	Optional one or more layers Min. 1.3-inch EnergyGuard RA or RN followed by Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous) or Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	HA	GAF BUR. Note 15.	-45.0*
W-17.	Min. 19/32-inch plywood at max. 24-inch span	One or more layers Min. 1-inch Structodek High Density Fiberboard Roof Insulation	Note 2	1 per 4.0 ft <sup>2</sup>	Optional one or more layers Min. 1.3-inch EnergyGuard RA or RN followed by Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous) or Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	HA	GAF BUR. Note 15.	-45.0*

**TABLE 1D: WOOD DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE C-1: MECHANICALLY ATTACHED INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Insulation Layer (Note 13)	Top Insulation Layer			Roof Cover (Note 15)			MDP (psf)
			Type	Fasteners (Note 11)	Attach	Base	Ply	Cap	
<b>CONVENTIONAL SYSTEMS:</b>									
W-18.	Min. 19/32-inch plywood or wood plank	(Optional) One or more layers, any combination, loose-laid	One or more layers Min. 1.5-inch EnergyGuard Composite (wood fiber)	Note 2	1 per 3.0 ft <sup>2</sup>	BS	GAF BUR. Note 15.	-45.0*	
W-19.	Min. 19/32-inch plywood or wood plank	(Optional) One or more layers, any combination, loose-laid	One or more layers Min. 1.5-inch EnergyGuard Composite (perlite)	Note 2	1 per 3.0 ft <sup>2</sup>	BS	GAF BUR. Note 15.	-45.0*	
W-20.	Min. 19/32-inch plywood or wood plank	(Optional) One or more layers, any combination, loose-laid	One or more layers min. 1-inch Structodek High Density Fiberboard Roof Insulation	Note 2	1 per 4.0 ft <sup>2</sup>	BS	GAF BUR. Note 15.	-45.0*	
W-21.	Min. 19/32-inch plywood or wood plank	(Optional) One or more layers, any combination, loose-laid	Min. 0.25-inch SECUROCK Gypsum Fiber Roof Board	Note 2 (#14 only)	1 per 1.8 ft <sup>2</sup>	BS	GAF BUR. Note 15.	-60.0	
<b>VENTING BASE SYSTEMS:</b>									
W-22.	Min. 19/32-inch plywood or wood plank	(Optional) One or more layers, any combination, loose-laid	One or more layers Min. 1.5-inch EnergyGuard Composite (wood fiber)	Note 2	1 per 3.0 ft <sup>2</sup>	V-BS	GAF BUR. Note 15.	-45.0*	
W-23.	Min. 19/32-inch plywood or wood plank	(Optional) One or more layers, any combination, loose-laid	One or more layers Min. 1-inch Structodek High Density Fiberboard Roof Insulation	Note 2	1 per 4.0 ft <sup>2</sup>	V-BS	GAF BUR. Note 15.	-45.0*	
W-24.	Min. 15/32-inch plywood at max. 24-inch span	(Optional) One or more layers, any combination, loose laid	Min. 1.5-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra	Note 2	1 per 1.3 ft <sup>2</sup>	V-BS	GAF BUR. Note 15.	-60.0*	

**TABLE 1E: WOOD DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE D-2: INSULATED, MECHANICALLY ATTACHED BASE SHEET, BONDED ROOF COVER**

System No.	Deck (Note 1)	Insulation Layer(s) (Note 13)		Base Sheet			Roof Cover (Note 15)	MDP (psf)
		Type	Attach	Base	Fasteners (Note 11)	Attach		
W-25.	Min. 19/32-inch plywood at max. 24-inch span	One or more layers, any combination	Loose Laid	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Note 2	12-inch o.c. at the 2-inch lap and 12-inch o.c. in two equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)	-45.0
W-26.	Min. 23/32-inch plywood at max. 24-inch span	One or more layers, any combination	Loose Laid	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Note 2 (#14 only)	9-inch o.c. at the 2-inch lap and 9-inch o.c. in three equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)	-52.5
W-27.	Min. 19/32-inch plywood at max. 24-inch span	One or more layers, any combination	Loose Laid	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Note 2	12-inch o.c. at the 2-inch lap and 12-inch o.c. in three equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)	-60.0
W-28.	Min. 19/32-inch plywood at max. 24-inch span	One or more layers, any combination	Loose Laid	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Note 2	8-inch o.c. at the 2-inch lap and 8-inch o.c. in three equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)	-75.0

**TABLE 1F: WOOD DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE E-2: NON-INSULATED, MECHANICALLY ATTACHED BASE SHEET (NAILS & CAPS), BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Sheet			Roof Cover (Note 15)	MDP (psf)
		Type	Fasteners (Note 11)	Attach		
W-29.	Min. 15/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	32 ga., 1-5/8-inch dia. tin caps with 11 ga. annular ring shank nails	8-inch o.c. at min. 4-inch laps and 8-inch o.c. in two, equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)	-45.0
W-30.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Eliminator Nailable Venting Base Sheet, Ruberoid 20 Smooth, Ruberoid Mop Smooth, Ruberoid Mop Smooth 1.5	32 ga., 1-5/8-inch dia. tin caps with 11 ga. annular ring shank nails	9-inch o.c. at the 4-inch lap and 12-inch o.c. in two staggered center rows	GAF BUR. Note 15. (No V-BS)	-45.0
W-31.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet, GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M, Ruberoid 20 Smooth	32 ga., 1-5/8-inch dia. tin caps with 11 ga. annular ring shank nails	9-inch o.c. at the 4-inch lap and 9-inch o.c. in two staggered center rows	GAF BUR. Note 15. (No V-BS)	-52.5
W-32.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Approved 1.25-inch annular ring shank nails and inverted Drill-Tec 3-inch Galvalume Plates	9-inch o.c. at the 4-inch lap and 9-inch o.c. in two staggered center rows	GAF BUR. Note 15. (No V-BS)	-60.0
W-33.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #80 Ultima Base Sheet	32 ga., 1-5/8-inch dia. tin caps with 11 ga. annular ring shank nails	7-inch o.c. at min. 4-inch laps and 7-inch o.c. in three, equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)	-82.5
W-34.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	32 ga., 1-5/8-inch dia. tin caps with 11 ga. annular ring shank nails	4-inch o.c. at min. 2-inch laps and 4-inch o.c. in four (4), equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)	-97.5

**TABLE 1G: WOOD DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE E-2: NON-INSULATED, MECHANICALLY ATTACHED BASE SHEET (SCREWS & PLATES), BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Sheet			Roof Cover (Note 15)	MDP (psf)
		Type	Fasteners (Note 11)	Attach		
W-35.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet, GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet, GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M, Ruberoid 20 Smooth	Note 2	12-inch o.c. at the 2-inch lap and 12-inch o.c. in two center staggered center rows	GAF BUR. Note 15. (No V-BS)	-45.0
W-36.	Min. 15/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Note 2 (#14 ONLY)	16-inch o.c. at 4-inch laps and 16-inch o.c. in two, equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)	-52.5
W-37.	Min. 15/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Note 2 (#14 ONLY)	12-inch o.c. at 4-inch laps and 12-inch o.c. in two, equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)	-60.0
W-38.	Min. 19/32-inch plywood at max. 24-inch span	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet, Ruberoid 20 Smooth	Note 2	8-inch o.c. at the 2-inch lap and 8-inch o.c. in three staggered center rows	GAF BUR. Note 15. (No V-BS)	-75.0



**TABLE 2A: STEEL OR STRUCTURAL CONCRETE DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE B-1: MECHANICALLY ATTACHED BASE INSULATION, BONDED TOP INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Insulation Layer			Top Insulation Layer		Roof Cover (Note 15)			MDP (psf)
		Type	Fasteners (Note 11)	Attach	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
<b>CONVENTIONAL SYSTEMS:</b>										
S-1.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch EnergyGuard Polyiso Insulation	Note 2	1 per 4.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or min. 0.75-inch EnergyGuard Perlite Roof Insulation	HA	GAF BUR. Note 15. (No V-BS)		-37.5*	
S-2.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Note 2	1 per 3.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA	GAF BUR. Note 15. (No V-BS)		-45.0*	
S-3.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Note 2	1 per 3.0 ft <sup>2</sup>	Min. 0.5-inch EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous) or Min. 1.5-inch EnergyGuard Composite (perlite)	HA	GAF BUR. Note 15. (No V-BS)		-45.0*	
S-4.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Note 2	1 per 2.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA	GAF BUR. Note 15. (No V-BS)		-45.0*	
S-5.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Note 2	1 per 2.0 ft <sup>2</sup>	Min. 0.5-inch EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous) or Min. 1.5-inch EnergyGuard Composite (perlite)	HA	GAF BUR. Note 15. (No V-BS)		-45.0*	
S-6.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch EnergyGuard Polyiso Insulation	Note 2	1 per 2.7 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or min. 0.75-inch EnergyGuard Perlite Roof Insulation	HA	GAF BUR. Note 15. (No V-BS)		-45.0*	
S-7.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch EnergyGuard Polyiso Insulation	Note 2	1 per 4.0 ft <sup>2</sup>	Min. 0.5-inch EnergyGuard Perlite Recover Board or min. 0.25-inch SECUROCK Gypsum Fiber Roof Board, Dens Deck, Dens Deck Prime	HA	GAF BUR. Note 15. (No V-BS)		-45.0*	
S-8.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 2-inch EnergyGuard Polyiso Insulation	Note 2	1 per 4.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or min. 0.75-inch EnergyGuard Perlite Roof Insulation	HA	GAF BUR. Note 15. (No V-BS)		-45.0*	
S-9.	Min. 22 ga. type B, Grade 80 steel or min. 2,500 psi structural concrete	Min. 2-inch EnergyGuard RA or RN	Note 2 (#14 only for steel deck)	1 per 1.3 ft <sup>2</sup>	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous) or Min. 0.5-inch EnergyGuard Fiberboard	HA	GAF BUR. Note 15. (No V-BS)		-90.0	
S-10.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 2-inch EnergyGuard RA	Note 2	1 per 1.6 ft <sup>2</sup>	Min. 0.25-inch SECUROCK Gypsum-Fiber Roof Board	LRF-XF	GAF BUR. Note 15. (No V-BS)		-60.0	
S-11.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch EnergyGuard RA or RN	Note 2	1 per 2.0 ft <sup>2</sup>	Min. 0.25-inch Dens Deck, Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board, or Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	OB500	GAF BUR. Note 15. (No V-BS)		-45.0*	

**TABLE 2A: STEEL OR STRUCTURAL CONCRETE DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE B-1: MECHANICALLY ATTACHED BASE INSULATION, BONDED TOP INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Insulation Layer			Top Insulation Layer		Roof Cover (Note 15)			MDP (psf)
		Type	Fasteners (Note 11)	Attach	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
S-12.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 2-inch EnergyGuard RA or RN	Note 2	1 per 1.6 ft <sup>2</sup>	Min. 0.25-inch SECUROCK Gypsum-Fiber Roof Board	OB500	GAF BUR. Note 15. (No V-BS)			-60.0
<b>VENTING SYSTEMS:</b>										
S-13.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Note 2	1 per 2.0 ft <sup>2</sup>	Min. 1.0-inch EnergyGuard RA or RN	HA	V-BS	GAF BUR. Note 15		-45.0*
S-14.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Max. 48 x 48-inch x min. 1.5-inch EnergyGuard Polyiso Insulation	Note 2	1 per 4.0 ft <sup>2</sup>	Min. 1.5-inch EnergyGuard Polyiso Insulation	HA	V-BS	GAF BUR. Note 15		-45.0*
S-15.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Note 2	1 per 3.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA	V-BS	GAF BUR. Note 15		-45.0*
S-16.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Note 2	1 per 2.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA	V-BS	GAF BUR. Note 15		-45.0*

**TABLE 2B: STEEL DECKS - NEW CONSTRUCTION, REROOF (TEAR-OFF)  
SYSTEM TYPE B-2: MECHANICALLY ATTACHED THERMAL BARRIER, BONDED VAPOR RETARDER, BONDED TOP INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Thermal Barrier			Vapor Retarder	Insulation Layer(s)		Roof Cover (Note 15)			MDP (psf)
		Type	Fastener (Note 11)	Attach		Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
<b>CONVENTIONAL SYSTEMS:</b>											
S-17.	Min. 22 ga., Type B, Grade 33 steel	0.5-inch DensDeck Prime or SECUROCK Gypsum Fiber Roof Board	Note 2	1 per 2.0 ft <sup>2</sup>	GAF SA Vapor Retarder XL, self-adhering	Base Layer: Min. 1-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra Mid Layer(s): (Optional) Additional layer(s) base insulation, min. 1.5-inch thick Coverboard: Min. 0.25-inch DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board	LRF-M, LRF-XF or OB500	GAF BUR. Note 15			-45.0*
S-18.	Min. 22 ga., Type B, Grade 33 steel	0.5-inch DensDeck Prime or SECUROCK Gypsum Fiber Roof Board	Note 2	1 per 2.0 ft <sup>2</sup>	Primer: GAF SA Primer Vapor Retarder: GAF SA Vapor Retarder, self-adhering	Base Layer: Min. 1-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra Mid Layer(s): (Optional) Additional layer(s) base insulation, min. 1.5-inch thick Coverboard: Min. 0.25-inch DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board	LRF-M, LRF-XF or OB500	GAF BUR. Note 15			-67.5
<b>VENTING SYSTEMS:</b>											

**TABLE 2B: STEEL DECKS - NEW CONSTRUCTION, REROOF (TEAR-OFF)**  
**SYSTEM TYPE B-2: MECHANICALLY ATTACHED THERMAL BARRIER, BONDED VAPOR RETARDER, BONDED TOP INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Thermal Barrier			Vapor Retarder	Insulation Layer(s)		Roof Cover (Note 15)			MDP (psf)
		Type	Fastener (Note 11)	Attach		Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
S-19.	Min. 22 ga., Type B, Grade 33 steel	0.5-inch DensDeck Prime or SECUROCK Gypsum Fiber Roof Board	Note 2	1 per 2.0 ft <sup>2</sup>	Primer: GAF SA Primer Vapor Retarder: GAF SA Vapor Retarder, self-adhering	Base Layer: Min. 1-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra Top Layer(s): (Optional) Additional layer(s) base insulation, min. 1.5-inch thick	LRF-M, LRF-XF or OB500	V-BS	GAF BUR. Note 15	-45.0*	
S-20.	Min. 22 ga., Type B, Grade 33 steel	0.5-inch DensDeck Prime or SECUROCK Gypsum Fiber Roof Board	Note 2	1 per 2.0 ft <sup>2</sup>	GAF SA Vapor Retarder XL, self-adhering	Base Layer: Min. 1-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra Top Layer(s): (Optional) Additional layer(s) base insulation, min. 1.5-inch thick Coverboard (Optional): Min. 0.25-inch DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board	LRF-M, LRF-XF or OB500	V-BS	GAF BUR. Note 15	-45.0*	
S-21.	Min. 22 ga., Type B, Grade 33 steel	0.5-inch DensDeck Prime or SECUROCK Gypsum Fiber Roof Board	Note 2	1 per 2.0 ft <sup>2</sup>	Primer: GAF SA Primer Vapor Retarder: GAF SA Vapor Retarder, self-adhering	Base Layer: Min. 1-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra Top Layer(s): (Optional) Additional layer(s) base insulation, min. 1.5-inch thick Coverboard: Min. 0.25-inch DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board	LRF-M, LRF-XF or OB500	V-BS	GAF BUR. Note 15	-67.5	

**TABLE 2c: STEEL OR STRUCTURAL CONCRETE DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER**  
**SYSTEM TYPE C-1: MECHANICALLY ATTACHED INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Insulation Layer (Note 13)		Top Insulation Layer			Roof Cover (Note 15)			MDP (psf)
		Type	Attach	Type	Fasteners (Note 11)	Attach	Base	Ply	Cap	
<b>CONVENTIONAL SYSTEMS:</b>										
S-22.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 1.5-inch EnergyGuard Composite (iso side down)	Note 2	1 per 4.0 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)			-45.0*
S-23.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 1-inch Structodek High Density Fiberboard Roof Insulation	Note 2	1 per 4.0 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)			-45.0*
S-24.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	Note 2	1 per 3.0 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)			-45.0*
S-25.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Note 2	1 per 2.0 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)			-45.0*
S-26.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 0.5-inch SECUROCK Gypsum-Fiber Roof Board	Note 2	1 per 1.8 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)			-60.0

**TABLE 2c: STEEL OR STRUCTURAL CONCRETE DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE C-1: MECHANICALLY ATTACHED INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Insulation Layer (Note 13)		Top Insulation Layer			Roof Cover (Note 15)			MDP (psf)
		Type	Attach	Type	Fasteners (Note 11)	Attach	Base	Ply	Cap	
<b>VENTING SYSTEMS:</b>										
S-27.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 2-inch EnergyGuard Polyiso Insulation	Note 2	1 per 4.0 ft <sup>2</sup>	V-BS	GAR BUR. Note 15.		-37.5*
S-28.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 2-inch EnergyGuard Ultra	Note 2 (no Drill-Tec 3" Flat Steel Plate or Drill-Tec 3" Recessed Steel Plate)	1 per 4.0 ft <sup>2</sup>	V-BS	GAR BUR. Note 15.		-45.0*
S-29.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 1.5-inch EnergyGuard RA or RN	Note 2	1 per 3.0 ft <sup>2</sup>	V-BS	GAF BUR. Note 15		-45.0*
S-30.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 2-inch EnergyGuard RH	Note 2	1 per 2.9 ft <sup>2</sup>	V-BS	GAR BUR. Note 15.		-45.0*
S-31.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Max. 48 x 48-inch x min. 2-inch EnergyGuard Polyiso Insulation	Note 2	1 per 3.2 ft <sup>2</sup>	V-BS	GAR BUR. Note 15.		-45.0*
S-32.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 1.5-inch EnergyGuard Polyiso Insulation	Note 2	1 per 2.0 ft <sup>2</sup>	V-BS	GAR BUR. Note 15.		-45.0*
S-33.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 1.5-inch EnergyGuard RA or RN	Note 2	1 per 1.45 ft <sup>2</sup>	V-BS	PS-MB	CS	-60.0
S-34.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 2-inch EnergyGuard RA or RN or EnergyGuard Composite (iso side up)	Note 2	1 per 1.45 ft <sup>2</sup>	V-BS	GAF BUR. Note 15		-60.0
S-35.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 2-inch EnergyGuard Ultra	Note 2 (no Drill-Tec 3" Flat Steel Plate or Drill-Tec 3" Recessed Steel Plate)	1 per 1.45 ft <sup>2</sup>	V-BS	PS-MB	CS	-75.0
S-36.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Polyiso Insulation	Loose laid	Min. 0.25-inch Dens Deck	Note 2	1 per 1.0 ft <sup>2</sup>	V-BS	PS-MB	CS	-82.5
S-37.	Min. 22 ga. type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination	Loose laid	Min. 3-inch EnergyGuard Polyiso Insulation	Note 2	1 per 1.6 ft <sup>2</sup>	V-BS	GAF BUR. Note 15		-82.5

**TABLE 2D: STEEL OR STRUCTURAL CONCRETE DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE D-2: INSULATED, MECHANICALLY ATTACHED BASE SHEET, BONDED ROOF COVER**

System No.	Deck (Note 1)	Insulation Layer(s) (Note 13)		Base Sheet			Roof Cover (Note 15)		MDP (psf)
		Type	Attach	Base	Fasteners (Note 11)	Attach	Ply	Cap	
S-38.	Min. 22 ga. type B, Grade 33 steel	One or more layers, any combination	Loose Laid	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Note 2	18-inch o.c. at the 2-inch lap and 18-inch o.c. in three equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)		-45.0*
S-39.	Min. 2,500 psi structural concrete	One or more layers, any combination	Loose Laid	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Note 2 (Drill-Tec #14 only)	18-inch o.c. at the 2-inch lap and 18-inch o.c. in three equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)		-45.0*
S-40.	Min. 22 ga. type B, Grade 33 steel	One or more layers, any combination	Loose Laid	Ruberoid Mop Smooth 1.5	Note 2	24-inch o.c. at the 3-inch lap and 24-inch o.c. in two equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)		-45.0*
S-41.	Min. 2,500 psi structural concrete	One or more layers, any combination	Loose Laid	Ruberoid Mop Smooth 1.5	Note 2 (Drill-Tec #14 only)	24-inch o.c. at the 3-inch lap and 24-inch o.c. in two equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)		-45.0*
S-42.	Min. 2,500 psi structural concrete	One or more layers, any combination	Loose Laid	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Note 2 (Drill-Tec #14 only)	9-inch o.c. at the 2-inch lap and 9-inch o.c. in two equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)		-45.0
S-43.	Min. 22 ga. type B, Grade 33 steel	One or more layers, any combination	Loose Laid	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Note 2	6-inch o.c. at the 3-inch lap and 6-inch o.c. in two equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)		-75.0
S-44.	Min. 2,500 psi structural concrete	One or more layers, any combination	Loose Laid	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Note 2 (Drill-Tec #14 only)	7-inch o.c. at the 3-inch lap and 7-inch o.c. in two equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)		-75.0

**TABLE 3A: STRUCTURAL CONCRETE DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)**  
**SYSTEM TYPE A-1: BONDED INSULATION, BONDED ROOF COVER**  
 SEE NOTE 16 FOR VAPOR BARRIER OPTIONS

System No.	Deck (Note 1)	Prime	Base Insulation Layer		Top Insulation Layer(s)		Roof Cover (Note 15)			MDP (psf)
			Type	Attach (Notes 6,7,8)	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
<b>CONVENTIONAL SYSTEMS:</b>										
C-1.	Min. 2,500 psi structural concrete	ASTM D41	Min. 1.5-inch EnergyGuard RA or RN	HA	Min. 0.25-inch Dens Deck, Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	HA	GAF BUR. Note 15. (No V-BS)			-45.0
C-2.	Min. 2,500 psi structural concrete	ASTM D41	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	None	N/A	GAF BUR. Note 15. (No V-BS)			-137.0
C-3.	Min. 2,500 psi structural concrete	ASTM D41	Min. 1.5-inch EnergyGuard Composite	HA	None	N/A	GAF BUR. Note 15. (No V-BS)			-140.0
C-4.	Min. 2,500 psi structural concrete	ASTM D41	Min. 0.5-inch EnergyGuard Polyiso Insulation	HA	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation, EnergyGuard Perlite Recover Board, min. 0.75-inch EnergyGuard Perlite Roof Insulation, min. 0.25-inch SECUROCK Gypsum-Fiber Roof Board, Dens Deck, Dens Deck Prime	HA	GAF BUR. Note 15. (No V-BS)			-150.0
C-5.	Min. 2,500 psi structural concrete	ASTM D41	Min. 1.3-inch EnergyGuard RA or RN or Min. 1.5-inch EnergyGuard Composite	HA	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15. (No V-BS)			-157.0
C-6.	Min. 2,500 psi structural concrete	ASTM D41	Min. 1.3-inch EnergyGuard RA or RN or Min. 1.5-inch EnergyGuard Composite	HA	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	N/A	GAF BUR. Note 15. (No V-BS)			-162.0
C-7.	Min. 2,500 psi structural concrete	ASTM D41	Min. 1-inch EnergyGuard Perlite Roof Insulation (homogeneous) or Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	HA	None	N/A	GAF BUR. Note 15. (No V-BS)			-270.0
C-8.	Min. 2,500 psi structural concrete	ASTM D41	Min. 1.5-inch EnergyGuard RA or RN	HA	Min. 1.5-inch EnergyGuard Composite	HA	GAF BUR. Note 15. (No V-BS)			-270.0
C-9.	Min. 2,500 psi structural concrete	ASTM D41	Min. 2-inch EnergyGuard RA or RN	HA	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15. (No V-BS)			-322.5
C-10.	Min. 2,500 psi structural concrete	ASTM D41	Min. 1.5-inch EnergyGuard RA or RN	HA	Min. 0.5-inch EnergyGuard Perlite Recover Board	HA	GAF BUR. Note 15. (No V-BS)			-360.0
C-11.	Min. 2,500 psi structural concrete	None	Min. 1.0-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra	LRF-M	Insulation: (Optional) Additional layer(s) base insulation. Coverboard: Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	LRF-M	GAF BUR. Note 15. (No V-BS)			-202.5
C-12.	Min. 2,500 psi structural concrete	None	Min. 1.0-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra	LRF-XF	Insulation: (Optional) Additional layer(s) base insulation. Coverboard: Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	LRF-XF	GAF BUR. Note 15. (No V-BS)			-202.5



**TABLE 3A: STRUCTURAL CONCRETE DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)**  
**SYSTEM TYPE A-1: BONDED INSULATION, BONDED ROOF COVER**  
 SEE NOTE 16 FOR VAPOR BARRIER OPTIONS

System No.	Deck (Note 1)	Prime	Base Insulation Layer		Top Insulation Layer(s)		Roof Cover (Note 15)			MDP (psf)
			Type	Attach (Notes 6,7,8)	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
C-13.	Min. 2,500 psi structural concrete	None	(Optional) Min. 1.5-inch EnergyGuard	LRF-XF	Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	LRF-XF	GAF BUR. Note 15. (No V-BS)			-240.0
C-14.	Min. 2,500 psi structural concrete	None	(Optional) Min. 1.5-inch EnergyGuard RA or RN	OB500	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	OB500	GAF BUR. Note 15. (No V-BS)			-165.0
C-15.	Min. 2,500 psi structural concrete	None	Min. 1.5-inch EnergyGuard RA or RN	OB500	Min. 0.25-inch Dens Deck or Dens Deck Prime	OB500	GAF BUR. Note 15. (No V-BS)			-150.0
C-16.	Min. 2,500 psi structural concrete	None	Min. 1.0-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra	OB500	Insulation: (Optional) Additional layer(s) base insulation. Coverboard: Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	OB500	GAF BUR. Note 15. (No V-BS)			-202.5
C-17.	Min. 2,500 psi structural concrete	None	Min. 1.5-inch EnergyGuard RA or RN	OB500	Min. 0.25-inch SECUROCK Gypsum-Fiber Roof Board	OB500	GAF BUR. Note 15. (No V-BS)			-225.0
<b>VENTING SYSTEMS:</b>										
C-18.	Min. 2,500 psi structural concrete	ASTM D41	Min. 0.5-inch EnergyGuard Polyiso Insulation	HA	(Optional) Additional layer(s) base insulation	HA	V-BS	GAF BUR. Note 15.		-150.0
C-19.	Min. 2,500 psi structural concrete	ASTM D41	Min. 1-inch EnergyGuard RN	HA	(Optional) Additional layers base insulation	HA	V-BS	GAF BUR. Note 15.		-292.5
C-20.	Min. 2,500 psi structural concrete	None	Min. 1.0-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra	LRF-M	Insulation: (Optional) Additional layer(s) base insulation.	LRF-M	V-BS	GAF BUR. Note 15.		-150.0
C-21.	Min. 2,500 psi structural concrete	None	Min. 1.0-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra	LRF-M	Insulation: (Optional) Additional layer(s) base insulation. Coverboard: Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	LRF-M	V-BS	GAF BUR. Note 15.		-202.5
C-22.	Min. 2,500 psi structural concrete	None	Min. 1.0-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra	LRF-XF	Insulation: (Optional) Additional layer(s) base insulation.	LRF-XF	V-BS	GAF BUR. Note 15.		-150.0
C-23.	Min. 2,500 psi structural concrete	None	Min. 1.0-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra	LRF-XF	Insulation: (Optional) Additional layer(s) base insulation. Coverboard: Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	LRF-XF	V-BS	GAF BUR. Note 15.		-202.5
C-24.	Min. 2,500 psi structural concrete	None	Min. 1.0-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra	OB500	Insulation: (Optional) Additional layer(s) base insulation.	OB500	V-BS	GAF BUR. Note 15.		-150.0

**TABLE 3A: STRUCTURAL CONCRETE DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)**  
**SYSTEM TYPE A-1: BONDED INSULATION, BONDED ROOF COVER**  
 SEE NOTE 16 FOR VAPOR BARRIER OPTIONS

System No.	Deck (Note 1)	Prime	Base Insulation Layer		Top Insulation Layer(s)		Roof Cover (Note 15)			MDP (psf)
			Type	Attach (Notes 6,7,8)	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
C-25.	Min. 2,500 psi structural concrete	None	Min. 1.0-inch EnergyGuard Polyiso Insulation or EnergyGuard Ultra	OB500	Insulation: (Optional) Additional layer(s) base insulation. Coverboard: Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	OB500	V-BS	GAF BUR. Note 15.		-202.5

**TABLE 3B: STRUCTURAL CONCRETE DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)**  
**SYSTEM TYPE F: NON-INSULATED, BONDED ROOF COVER**

System No.	Deck (Note 1)	Primer	Roof Cover (Note 15)			MDP (psf)
			Base	Ply	Cap	
C-26.	Min. 2,500 psi structural concrete	ASTM D41	V-BS	GAF BUR. Note 15.		-90.0
C-27.	Min. 2,500 psi structural concrete	Matrix 307 Premium Asphalt Primer	V-BS	GAF BUR. Note 15.		-185.0
C-28.	Min. 2,500 psi structural concrete	ASTM D41	GAF BUR. Note 15. (No V-BS)			-457.5

**TABLE 4A: LIGHTWEIGHT INSULATING CONCRETE DECKS - NEW CONSTRUCTION OR REROOF (TEAR-OFF)  
SYSTEM TYPE A-1: BONDED INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	LWC (Note 14)	Base Insulation Layer		Coverboard		Roof Cover (Note 15)			MDP (psf)
			Type	Attach (Notes 6,7,8)	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
<b>CELCORE, FL2037:</b>										
LWC-1.	Min. 2,500 psi structural concrete	Min. 300 psi Celcore Cellular Concrete	Min. 1.5-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation, EnergyGuard RA Polyiso, EnergyGuard RH Polyiso, EnergyGuard RN Polyiso	OB500	Min. 0.25-inch Dens Deck, Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	OB500	GAF BUR. Note 15.			-150.0
<b>ELASTIZELL, FL4994:</b>										
LWC-2.	Min. 2,500 psi structural concrete	Min. 300 psi Elastizell Lightweight Insulating Concrete	Min. 1.5-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation, EnergyGuard RA Polyiso, EnergyGuard RH Polyiso, EnergyGuard RN Polyiso	OB500	Min. 0.25-inch Dens Deck, Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	OB500	GAF BUR. Note 15.			-150.0
<b>MEARLCRETE, FL13492:</b>										
LWC-3.	Min. 2,500 psi structural concrete	Min. 300 psi Mearlcrete	Min. 1.5-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation, EnergyGuard RA Polyiso, EnergyGuard RH Polyiso, EnergyGuard RN Polyiso	OB500	Min. 0.25-inch Dens Deck, Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	OB500	GAF BUR. Note 15.			-150.0

**TABLE 4B: LIGHTWEIGHT CONCRETE DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)  
SYSTEM TYPE A-2: MECHANICALLY ATTACHED ANCHOR SHEET, BONDED INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	LWC (Note 14)	Anchor Sheet			Insulation		Roof Cover (Note 15)			MDP (psf)
			Type	Fasteners (Note 11)	Attach	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
<b>PRE-EXISTENT LIGHTWEIGHT CONCRETE (NOTE 14):</b>											
<b>CONVENTIONAL SYSTEMS:</b>											
LWC-4.	Min. 22 ga., Type B vented steel or min. 2,500 psi structural concrete	Min. 250 psi pre-existent cellular or aggregate LWIC.	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Base Sheet Fastener (1.7 in.) (Field W/D ≥ 70 lbf)	9-inch o.c. at the 2-inch lap and 9-inch o.c. in two equally spaced, staggered center rows	One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite, Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous), Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.25-inch Dens Deck, Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	HA	GAF BUR. Note 15. (No V-BS)		-45.0	
LWC-5.	Min. 22 ga., Type B vented steel or min. 2,500 psi structural concrete	Min. 250 psi pre-existent cellular or aggregate LWIC.	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Base Sheet Fastener (1.7 in.) (Field W/D ≥ 56 lbf)	12-inch o.c. at the 2-inch lap and 9-inch o.c. in three equally spaced, staggered center rows	One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite, Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous), Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.25-inch Dens Deck, Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	HA	GAF BUR. Note 15. (No V-BS)		-45.0	

**TABLE 4B: LIGHTWEIGHT CONCRETE DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)  
SYSTEM TYPE A-2: MECHANICALLY ATTACHED ANCHOR SHEET, BONDED INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	LWC (Note 14)	Anchor Sheet			Insulation		Roof Cover (Note 15)			MDP (psf)
			Type	Fasteners (Note 11)	Attach	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
LWC-6.	Min. 22 ga., Type B vented steel or min. 2,500 psi structural concrete	Min. 300 psi pre-existent cellular LWIC.	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet	Drill-Tec Base Sheet Fastener (1.7 in.) (Field W/D ≥ 88 lbf)	7-inch o.c. at the 3-inch lap and 7-inch o.c. in two equally spaced, staggered center rows	One or more layers, any combination, Min. 1.5-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso, followed by Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous), Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board or Min. 0.25-inch Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	HA		GAF BUR. Note 15. (No V-BS)		-75.0
<b>VENTING SYSTEMS:</b>											
LWC-7.	Min. 22 ga., Type B vented steel or min. 2,500 psi structural concrete	Min. 250 psi pre-existent cellular or aggregate LWIC.	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Base Sheet Fastener (1.7 in.) (Field W/D ≥ 70 lbf)	9-inch o.c. at the 2-inch lap and 9-inch o.c. in two equally spaced, staggered center rows	One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite (fiberboard), Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 0.25-inch Dens Deck, Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	HA	V-BS	GAF BUR. Note 15.		-45.0
LWC-8.	Min. 22 ga., Type B vented steel or min. 2,500 psi structural concrete	Min. 250 psi pre-existent cellular or aggregate LWIC.	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Base Sheet Fastener (1.7 in.) (Field W/D ≥ 56 lbf)	12-inch o.c. at the 2-inch lap and 9-inch o.c. in three equally spaced, staggered center rows	One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite (fiberboard), Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 0.25-inch Dens Deck, Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	HA	V-BS	GAF BUR. Note 15.		-45.0
LWC-9.	Min. 22 ga., Type B vented steel or min. 2,500 psi structural concrete	Min. 300 psi pre-existent cellular LWIC.	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet	Drill-Tec Base Sheet Fastener (1.7 in.) (Field W/D ≥ 88 lbf)	7-inch o.c. at the 3-inch lap and 7-inch o.c. in two equally spaced, staggered center rows	One or more layers, any combination, Min. 1.5-inch EnergyGuard Polyiso Insulation, EnergyGuard Ultra Polyiso Insulation or EnergyGuard RH Polyiso or Min. 0.25-inch SECUROCK Gypsum-Fiber Roof Board	HA	V-BS	GAF BUR. Note 15.		-75.0

**TABLE 4c: LIGHTWEIGHT CONCRETE DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)  
SYSTEM TYPE E-2: NON-INSULATED, MECHANICALLY ATTACHED BASE SHEET, BONDED ROOF COVER**

System No.	Deck (Note 1)	LWC (Note 14)	Base Sheet			Roof Cover (Note 15)		MDP (psf)
			Type	Fasteners (Note 11)	Attach	Ply	Cap	
<b>PRE-EXISTENT LIGHTWEIGHT CONCRETE (NOTE 14):</b>								
LWC-10.	Min. 22 ga., type B, Grade 33 vented steel or min. 2,500 psi structural concrete	Min. 250 psi pre-existent cellular LWIC.	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet or Stratavent Nailable Venting Base Sheet	Drill-Tec Base Sheet Fastener (1.7 in.) (Field W/D ≥ 70 lbf)	9-inch o.c. at the 2-inch lap and 9-inch o.c. in two equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)		-45.0
LWC-11.	Min. 22 ga., type B, Grade 33 vented steel or min. 2,500 psi structural concrete	Min. 250 psi pre-existent cellular LWIC.	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet or Stratavent Nailable Venting Base Sheet	Drill-Tec Base Sheet Fastener (1.7 in.) (Field W/D ≥ 56 lbf)	12-inch o.c. at the 2-inch lap and 9-inch o.c. in three equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)		-45.0
LWC-12.	Min. 22 ga., type B, Grade 33 vented steel or min. 2,500 psi structural concrete	Min. 300 psi pre-existent cellular LWIC.	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet or Stratavent Nailable Venting Base Sheet	Drill-Tec Locking Impact Nail (1.8-inch) (Field W/D ≥ 88 lbf)	9-inch o.c. at the 4-inch lap and 9-inch o.c. in two equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)		-60.0
LWC-13.	Min. 22 ga., type B, Grade 33 vented steel or min. 2,500 psi structural concrete	Min. 300 psi pre-existent cellular LWIC.	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet or Stratavent Nailable Venting Base Sheet	Drill-Tec Base Sheet Fastener (1.7 in.) (Field W/D ≥ 88 lbf)	7-inch o.c. at the 3-inch lap and 7-inch o.c. in two equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)		-75.0
<b>ELASTIZELL, FL4994:</b>								
LWC-14.	Min. 22 ga., type B, Grade 33 vented steel or min. 2,500 psi structural concrete	Min. 300 psi Elastizell Lightweight Insulating Concrete	GAFGLAS #80 Ultima Base Sheet	Drill-Tec Base Sheet Fastener (1.7 in.)	7-inch o.c. at the 3-inch lap and 7-inch o.c. in two equally spaced, staggered center rows	PS-MB with optional additional layer(s) PS	CS	-82.5
LWC-15.	Min. 22 ga., type B, Grade 33 vented steel or min. 2,500 psi structural concrete	Min. 300 psi Elastizell Lightweight Insulating Concrete	Ruberoid Mop Smooth, Ruberoid Mop Granule, Ruberoid HW Smooth or Ruberoid HW Granule (granule side down)	Note 2 (fastening to structural deck)	<u>Fasten to engage structural deck:</u> 12-inch o.c. at the 4-inch lap and 12-inch o.c. in two equally spaced, staggered center rows	PS-MB with optional additional layer(s) PS	CS	-97.5

**TABLE 4d: LIGHTWEIGHT CONCRETE DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)  
SYSTEM TYPE F: NON-INSULATED, BONDED ROOF COVER**

System No.	Deck (Note 1)	LWC (Note 14)		Primer	Roof Cover (Note 15)			MDP (psf)
		Type	Treatment		Base	Ply	Cap	
<b>ELASTIZELL, FL4994:</b>								
LWC-16.	Min. 22 ga., type BV, Grade 33, G90 steel at max. 5 ft spans	Min. 350 psi Elastizell Cellular/Hybrid LWIC with Zell-crete Fibers cast at 54 pcf wet-cast density with min. 1-inch thick Holey Board and min. 2-inch thick top coat		Elastizell Zell-erater Sealer at 200 ft <sup>2</sup> /gal.	ASTM D41	V-BS	GAF BUR. Note 15.	-112.5

**TABLE 5A: CEMENTITIOUS WOOD FIBER DECKS – REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE A-2: MECHANICALLY FASTENED ANCHOR SHEET, BONDED INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Anchor Sheet			Insulation			Roof Cover (Note 15)			MDP (psf)
		Type	Fasteners (Note 11)	Attach	Base	Top	Attach (Notes 6,7,8)	Base	Ply	Cap	
<b>CONVENTIONAL SYSTEMS:</b>											
CWF-1.	Existing Tectum	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Polymer Gyptec Fastener and Drill-Tec 3" Gyptec Plate	6-inch o.c. at the 4-inch lap and 12-inch o.c. in two equally spaced, staggered center rows	(Optional) One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Min. 1.5-inch EnergyGuard Composite (wood fiber), Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 0.25-inch Dens Deck, Dens Deck Prime	HA		GAF BUR. Note 15. (No V-BS)		-45.0*
CWF-2.	Existing Tectum	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Polymer Gyptec Fastener and Drill-Tec 3" Gyptec Plate	6-inch o.c. at the 4-inch lap and 12-inch o.c. in two equally spaced, staggered center rows	(Optional) One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Min. 1.5-inch EnergyGuard Composite (perlite), Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous), Min. 0.5-inch EnergyGuard Perlite Recover Board or Min. 0.25-inch SECUROCK Gypsum-Fiber Roof Board	HA		GAF BUR. Note 15. (No V-BS)		-45.0*
<b>VENTING SYSTEMS:</b>											
CWF-3.	Existing Tectum	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Polymer Gyptec Fastener and Drill-Tec 3" Gyptec Plate	6-inch o.c. at the 4-inch lap and 12-inch o.c. in two equally spaced, staggered center rows	(Optional) One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Min. 1.5-inch EnergyGuard RA or RN	HA	V-BS	GAF BUR. Note 15		-45.0*
CWF-4.	Existing Tectum	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Polymer Gyptec Fastener and Drill-Tec 3" Gyptec Plate	6-inch o.c. at the 4-inch lap and 12-inch o.c. in two equally spaced, staggered center rows	(Optional) One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Min. 1.5-inch EnergyGuard Composite (wood fiber), Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 0.25-inch Dens Deck, Dens Deck Prime	HA	V-BS	GAF BUR. Note 15		-45.0*



**TABLE 5B: CEMENTITIOUS WOOD FIBER DECKS – REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE B-1: MECHANICALLY ATTACHED BASE INSULATION, BONDED TOP INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Insulation Layer			Top Insulation Layer		Roof Cover (Note 15)			MDP (psf)
		Type	Fasteners (Note 11)	Attach	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
<b>CONVENTIONAL SYSTEMS:</b>										
CWF-5.	Existing Tectum	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 3.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA		GAF BUR. Note 15. (No V-BS)		-45.0*
CWF-6.	Existing Tectum	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 3.0 ft <sup>2</sup>	Min. 0.5-inch EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous) or Min. 1.5-inch EnergyGuard Composite (perlite)	HA		GAF BUR. Note 15. (No V-BS)		-45.0*
CWF-7.	Existing Tectum	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 2.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA		GAF BUR. Note 15. (No V-BS)		-45.0*
CWF-8.	Existing Tectum	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 2.0 ft <sup>2</sup>	Min. 0.5-inch EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous) or Min. 1.5-inch EnergyGuard Composite (perlite)	HA		GAF BUR. Note 15. (No V-BS)		-45.0*
<b>VENTING SYSTEMS:</b>										
CWF-9.	Existing Tectum	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 3.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA	V-BS	GAF BUR. Note 15		-45.0*
CWF-10.	Existing Tectum	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 2.0 ft <sup>2</sup>	Min. 1.0-inch EnergyGuard RA or RN	HA	V-BS	GAF BUR. Note 15		-45.0*
CWF-11.	Existing Tectum	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 2.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA	V-BS	GAF BUR. Note 15		-45.0*

**TABLE 5c: CEMENTITIOUS WOOD FIBER DECKS – REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE C-1: MECHANICALLY ATTACHED INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Insulation Layer (Note 13)		Top Insulation Layer			Roof Cover (Note 15)			MDP (psf)
		Type	Attach	Type	Fasteners (Note 11)	Attach	Base	Ply	Cap	
<b>CONVENTIONAL SYSTEMS:</b>										
CWF-12.	Existing Tectum	(Optional) One or more layers, any combination	Loose laid	Min. 1.5-inch EnergyGuard Composite (iso side down)	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 4.0 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)		-45.0*	
CWF-13.	Existing Tectum	(Optional) One or more layers, any combination	Loose laid	Min. 1-inch Structodek High Density Fiberboard Roof Insulation	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 4.0 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)		-45.0*	
CWF-14.	Existing Tectum	(Optional) One or more layers, any combination	Loose laid	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 3.0 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)		-45.0*	
CWF-15.	Existing Tectum	(Optional) One or more layers, any combination	Loose laid	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 2.0 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)		-45.0*	
<b>VENTING SYSTEMS:</b>										
CWF-16.	Existing Tectum	(Optional) One or more layers, any combination	Loose laid	Min. 1.5-inch EnergyGuard RA or RN	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate	1 per 3.0 ft <sup>2</sup>	V-BS	GAF BUR. Note 15	-45.0*	

**TABLE 5d: CEMENTITIOUS WOOD FIBER DECKS – REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE D-2: INSULATED, MECHANICALLY ATTACHED BASE SHEET, BONDED ROOF COVER**

System No.	Deck (Note 1)	Insulation Layer(s) (Note 13)		Base Sheet			Roof Cover (Note 15)		MDP (psf)
		Type	Attach	Base	Fasteners (Note 11)	Attach	Ply	Cap	
CWF-17.	Existing Tectum	One or more layers, any combination	Loose Laid	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Locking Impact Nail (min. 1.8-inch embedment)	9-inch o.c. at the 2-inch lap and 18-inch o.c. in two equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)		-45.0*

**TABLE 5E: CEMENTITIOUS WOOD FIBER DECKS – REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE E-2: NON-INSULATED, MECHANICALLY ATTACHED BASE SHEET, BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Sheet			Roof Cover (Note 15)		MDP (psf)
		Type	Fasteners (Note 11)	Attach	Ply	Cap	
CWF-18.	Existing Tectum	GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet, GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid Modified Base	Drill-Tec LD Fasteners and Drill-Tec LD Plates	9-inch o.c. at the 4-inch lap and 12-inch o.c. in two, equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)		-30.0
CWF-19.	Existing Tectum	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Polymer Gyptec Fastener and Drill-Tec 3" Gyptec Plate	6-inch o.c. at the 4-inch lap and 12-inch o.c. in two equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)		-45.0*
CWF-20.	Existing Tectum	GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet, GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid Modified Base or Ruberoid 20 Smooth	Drill-Tec LD Fasteners and Drill-Tec LD Plates	7-inch o.c. at the 4-inch lap and 7-inch o.c. in two, equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)		-67.5
CWF-21.	Existing Tectum	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Locking Impact Nail (1.8-inch)	9-inch o.c. at the 4-inch lap and 12-inch o.c. in two equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)		-82.5

**TABLE 6A: GYPSUM DECKS – REROOF (TEAR-OFF)**  
**SYSTEM TYPE A-2: MECHANICALLY FASTENED ANCHOR SHEET, BONDED INSULATION, BONDED ROOF COVER**

System No.	Deck (Note 1)	Anchor Sheet			Insulation			Roof Cover (Note 15)			MDP (psf)
		Type	Fasteners (Note 11)	Attach	Base	Top	Attach (Notes 6,7,8)	Base	Ply	Cap	
<b>CONVENTIONAL SYSTEMS:</b>											
G-1.	Existing sound gypsum or gypsum plank	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet	Min. 1.8-inch Drill-Tec Locking Impact Nail or Drill-Tec Base Sheet Fastener (1.2 in) (Field W/D $\geq$ 105 lbf)	9-inch o.c. at the 2-inch lap and 18-inch o.c. in two, equally spaced, staggered center rows	Min. 1.5-inch EnergyGuard	Min. 0.5-inch EnergyGuard Perlite Recover Board or min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	HA	GAF BUR. Note 15. (No V-BS)		-45.0*	
G-2.	Existing sound gypsum or gypsum plank	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec CR 1.2-inch Base Sheet fasteners (Field W/D $\geq$ 48 lbf)	7-inch o.c. at the 2-inch lap and 7-inch o.c. in three staggered center rows	(Optional) One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Min. 1.5-inch EnergyGuard Composite, Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous), Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board, or Min. 0.25-inch Dens Deck, Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	HA	GAF BUR. Note 15. (No V-BS)		-52.5	
G-3.	Existing sound gypsum or gypsum plank	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Locking Impact Nail (1.8-inch) (Field W/D $\geq$ 140 lbf)	9-inch o.c. at the 2-inch lap and 12-inch o.c. in two staggered center rows	(Optional) One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Min. 1.5-inch EnergyGuard Composite, Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous), Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or EnergyGuard Perlite Recover Board, or Min. 0.25-inch Dens Deck, Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board	HA	GAF BUR. Note 15. (No V-BS)		-75.0	
<b>VENTING SYSTEMS:</b>											
G-4.	Existing sound gypsum or gypsum plank	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec CR 1.2-inch Base Sheet fasteners (Field W/D $\geq$ 48 lbf)	7-inch o.c. at the 2-inch lap and 7-inch o.c. in three staggered center rows	(Optional) One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Min. 1.5-inch EnergyGuard RA or RN, EnergyGuard Ultra or min. 0.25-inch Dens Deck	HA	V-BS	GAF BUR. Note 15	-52.5	

TABLE 6A: GYPSUM DECKS – REROOF (TEAR-OFF)											
SYSTEM TYPE A-2: MECHANICALLY FASTENED ANCHOR SHEET, BONDED INSULATION, BONDED ROOF COVER											
System No.	Deck (Note 1)	Anchor Sheet			Insulation			Roof Cover (Note 15)			MDP (psf)
		Type	Fasteners (Note 11)	Attach	Base	Top	Attach (Notes 6,7,8)	Base	Ply	Cap	
G-5.	Existing sound gypsum or gypsum plank	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Locking Impact Nail (1.8-inch) (Field W/D ≥ 112 lbf)	9-inch o.c. at the 2-inch lap and 12-inch o.c. in two staggered center rows	(Optional) One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Min. 1.5-inch EnergyGuard RA or RN	HA	V-BS	GAF BUR. Note 15		-60.0
G-6.	Existing sound gypsum or gypsum plank	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Locking Impact Nail (1.8-inch) (Field W/D ≥ 140 lbf)	9-inch o.c. at the 2-inch lap and 12-inch o.c. in two staggered center rows	(Optional) One or more layers, any combination, Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Min. 1.5-inch EnergyGuard Ultra or min. 0.25-inch Dens Deck	HA	V-BS	GAF BUR. Note 15		-75.0

TABLE 6B: GYPSUM DECKS – REROOF (TEAR-OFF)											
SYSTEM TYPE B-1: MECHANICALLY ATTACHED BASE INSULATION, BONDED TOP INSULATION, BONDED ROOF COVER											
System No.	Deck (Note 1)	Base Insulation Layer			Top Insulation Layer			Roof Cover (Note 15)			MDP (psf)
		Type	Fasteners (Note 11)	Attach	Type	Attach (Notes 6,7,8)	Base	Ply	Cap		
<b>CONVENTIONAL SYSTEMS:</b>											
G-7.	Existing sound gypsum or gypsum plank	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate (Field W/D ≥ 270 lbf)	1 per 3.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA		GAF BUR. Note 15 (No V-BS)			-45.0*
G-8.	Existing sound gypsum or gypsum plank	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate (Field W/D ≥ 270 lbf)	1 per 3.0 ft <sup>2</sup>	Min. 0.5-inch EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous) or Min. 1.5-inch EnergyGuard Composite (perlite)	HA		GAF BUR. Note 15 (No V-BS)			-45.0*
G-9.	Existing sound gypsum or gypsum plank	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate (Field W/D ≥ 180 lbf)	1 per 2.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA		GAF BUR. Note 15 (No V-BS)			-45.0*
G-10.	Existing sound gypsum or gypsum plank	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3" Gyptec Plate (Field W/D ≥ 180 lbf)	1 per 2.0 ft <sup>2</sup>	Min. 0.5-inch EnergyGuard Perlite Recover Board or Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous) or Min. 1.5-inch EnergyGuard Composite (perlite)	HA		GAF BUR. Note 15 (No V-BS)			-45.0*
<b>VENTING SYSTEMS:</b>											

TABLE 6B: GYPSUM DECKS – REROOF (TEAR-OFF)										
SYSTEM TYPE B-1: MECHANICALLY ATTACHED BASE INSULATION, BONDED TOP INSULATION, BONDED ROOF COVER										
System No.	Deck (Note 1)	Base Insulation Layer			Top Insulation Layer		Roof Cover (Note 15)			MDP (psf)
		Type	Fasteners (Note 11)	Attach	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
G-11.	Existing sound gypsum or gypsum plank	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3” Gyptec Plate (Field W/D ≥ 270 lbf)	1 per 3.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA	V-BS	GAF BUR. Note 15	-45.0*	
G-12.	Existing sound gypsum or gypsum plank	Min. 1.5-inch EnergyGuard RA or RN or EnergyGuard Composite	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3” Gyptec Plate (Field W/D ≥ 180 lbf)	1 per 2.0 ft <sup>2</sup>	Min. 1.0-inch EnergyGuard RA or RN	HA	V-BS	GAF BUR. Note 15	-45.0*	
G-13.	Existing sound gypsum or gypsum plank	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3” Gyptec Plate (Field W/D ≥ 180 lbf)	1 per 2.0 ft <sup>2</sup>	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or Min. 1.5-inch EnergyGuard Composite (wood fiber)	HA	V-BS	GAF BUR. Note 15	-45.0*	

TABLE 6C: GYPSUM DECKS - REROOF (TEAR-OFF)										
SYSTEM TYPE C-1: MECHANICALLY ATTACHED INSULATION, BONDED ROOF COVER										
System No.	Deck (Note 1)	Base Insulation Layer (Note 13)		Top Insulation Layer			Roof Cover (Note 15)			MDP (psf)
		Type	Attach	Type	Fasteners (Note 11)	Attach	Base	Ply	Cap	
<b>CONVENTIONAL SYSTEMS:</b>										
G-14.	Existing sound gypsum or gypsum plank	(Optional) One or more layers, any combination	Loose laid	Min. 1.5-inch EnergyGuard Composite (iso side down)	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3” Gyptec Plate (Field W/D ≥ 180 lbf)	1 per 2.0 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)	-45.0*		
G-15.	Existing sound gypsum or gypsum plank	(Optional) One or more layers, any combination	Loose laid	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3” Gyptec Plate (Field W/D ≥ 180 lbf)	1 per 2.0 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)	-45.0*		
G-16.	Existing sound gypsum or gypsum plank	(Optional) One or more layers, any combination	Loose laid	Min. 0.75-inch EnergyGuard Perlite Roof Insulation (homogeneous)	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3” Gyptec Plate (Field W/D ≥ 180 lbf)	1 per 2.0 ft <sup>2</sup>	GAF BUR. Note 15. (No V-BS)	-45.0*		
<b>VENTING SYSTEMS:</b>										
G-17.	Existing sound gypsum or gypsum plank	(Optional) One or more layers, any combination	Loose laid	Min. 1.5-inch EnergyGuard RA or RN	Drill-Tec Polymer Gyptec Fastener with Drill-Tec 3” Gyptec Plate (Field W/D ≥ 180 lbf)	1 per 2.0 ft <sup>2</sup>	V-BS	GAF BUR. Note 15	-45.0*	



TABLE 6D: GYPSUM DECKS – REROOF (TEAR-OFF)									
SYSTEM TYPE D-2: INSULATED, MECHANICALLY ATTACHED BASE SHEET, BONDED ROOF COVER									
System No.	Deck (Note 1)	Insulation Layer(s) (Note 13)		Base Sheet			Roof Cover (Note 15)		MDP (psf)
		Type	Attach	Base	Fasteners (Note 11)	Attach	Ply	Cap	
G-18.	Existing sound gypsum or gypsum plank	One or more layers, any combination	Loose Laid	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Locking Impact Nail (Field W/D $\geq$ 105 lbf)	9-inch o.c. at the 2-inch lap and 18-inch o.c. in two equally spaced staggered center rows	GAF BUR. Note 15. (No V-BS)		-45.0*

TABLE 6E: GYPSUM DECKS – REROOF (TEAR-OFF)								
SYSTEM TYPE E-2: NON-INSULATED, MECHANICALLY ATTACHED BASE SHEET, BONDED ROOF COVER								
System No.	Deck (Note 1)	Base Sheet			Roof Cover (Note 15)		MDP (psf)	
		Type	Fasteners (Note 11)	Attach	Ply	Cap		
G-19.	Existing sound gypsum or gypsum plank	GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet, GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid Modified Base	Drill-Tec LD Fasteners and Drill-Tec LD Plates (Field W/D $\geq$ 53 lbf)	9-inch o.c. at the 4-inch lap and 12-inch o.c. in two, equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)		-30.0	
G-20.	Existing sound gypsum or gypsum plank	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec CR 1.2-inch Base Sheet fasteners (Field W/D $\geq$ 41 lbf)	7-inch o.c. at the 2-inch lap and 7-inch o.c. in three staggered center rows	GAF BUR. Note 15. (No V-BS)		-45.0	
G-21.	Existing sound gypsum or gypsum plank	GAFGLAS Ply 4, GAFGLAS Ply 4 M, Tri-Ply Ply 4 Ply Sheet, GAFGLAS FlexPly 6, GAFGLAS FlexPly 6 M, GAFGLAS #80 Ultima Base Sheet, GAFGLAS Stratavent Nailable Venting Base Sheet, Ruberoid Modified Base or Ruberoid 20 Smooth	Drill-Tec LD Fasteners and Drill-Tec LD Plates (Field W/D $\geq$ 77 lbf)	7-inch o.c. at the 4-inch lap and 7-inch o.c. in two, equally spaced, staggered center rows	GAF BUR. Note 15. (No V-BS)		-67.5	
G-22.	Existing sound gypsum or gypsum plank	GAFGLAS #75 Base Sheet, Tri-Ply #75 Base Sheet, GAFGLAS #80 Ultima Base Sheet, Stratavent Nailable Venting Base Sheet or Ruberoid 20 Smooth	Drill-Tec Locking Impact Nail (1.8-inch) (Field W/D $\geq$ 140 lbf)	9-inch o.c. at the 2-inch lap and 12-inch o.c. in two staggered center rows	GAF BUR. Note 15. (No V-BS)		-75.0	

**TABLE 7A: RECOVER APPLICATIONS**  
**SYSTEM TYPE A-1: BONDED INSULATION, BONDED ROOF COVER**

<sup>A</sup> The reported MDP documents the allowable maximum design pressure of the new insulation and roof cover when installed atop the substrate, irrespective of the deck type (See Note 1) or performance of the substrate (See Note 12). The deck and substrate shall be capable of resisting the project design pressure requirements, not to exceed the noted MDP, to the satisfaction of the Authority Having Jurisdiction.

System No.	Substrate (Notes 1 & 12)	Base Insulation Layer		Top Insulation Layer		Roof Cover (Note 15)			MDP (psf) <sup>A</sup>
		Type	Attach (Notes 6,7,8)	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
<b>CONVENTIONAL SYSTEMS:</b>									
R-1.	Existing sand- or granule-surface modified bitumen or asphaltic built-up roof; (Optional) ASTM D41 primer	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	HA	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation, EnergyGuard Perlite Recover Board, min. 0.75-inch EnergyGuard Perlite Roof Insulation, min. 0.25-inch SECUROCK Gypsum Fiber Roof Board, Dens Deck, Dens Deck Prime	HA	GAF BUR. Note 15. (No V-BS)			-150.0
R-2.	Existing smooth-surface asphaltic built-up roof	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	LRF-M	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation, EnergyGuard Perlite Recover Board, min. 0.75-inch EnergyGuard Perlite Roof Insulation, min. 0.25-inch SECUROCK Gypsum Fiber Roof Board, Dens Deck, Dens Deck Prime	HA	GAF BUR. Note 15. (No V-BS)			-75.0
R-3.	Existing smooth-surface asphaltic built-up roof	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	LRF-M	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or min. 0.25-inch SECUROCK Gypsum Fiber Roof Board, Dens Deck, Dens Deck Prime	LRF-M	GAF BUR. Note 15. (No V-BS)			-75.0
R-4.	Existing sand- or granule-surface modified bitumen or asphaltic built-up roof	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	LRF-M	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation, EnergyGuard Perlite Recover Board, min. 0.75-inch EnergyGuard Perlite Roof Insulation, min. 0.25-inch SECUROCK Gypsum Fiber Roof Board, Dens Deck, Dens Deck Prime	HA	GAF BUR. Note 15. (No V-BS)			-150.0
R-5.	Existing sand- or granule-surface modified bitumen or asphaltic built-up roof	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	LRF-M	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or min. 0.25-inch SECUROCK Gypsum Fiber Roof Board, Dens Deck, Dens Deck Prime	LRF-M	GAF BUR. Note 15. (No V-BS)			-150.0
R-6.	Existing asphaltic built-up roof	(Optional) Min. 1.5-inch EnergyGuard RA	LRF-XF	Min. 0.25-inch DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board	LRF-XF	GAF BUR. Note 15. (No V-BS)			-240.0
R-7.	Existing asphaltic built-up roof	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	OB500	None	N/A	GAF BUR. Note 15. (No V-BS)			-120.0
R-8.	Existing asphaltic built-up roof	Min. 1.5-inch EnergyGuard RA or RN	OB500	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation	OB500	GAF BUR. Note 15. (No V-BS)			-120.0
R-9.	Existing asphaltic built-up roof	Min. 1.5-inch EnergyGuard RA or RN	OB500	Min. 0.25-inch Dens Deck or Dens Deck Prime	OB500	GAF BUR. Note 15. (No V-BS)			-120.0
R-10.	Existing asphaltic built-up roof	Min. 1.5-inch EnergyGuard RA or RN	OB500	Min. 0.25-inch SECUROCK Gypsum-Fiber Roof Board	OB500	GAF BUR. Note 15. (No V-BS)			-120.0
R-11.	Existing sand-surface APP modified bitumen or asphaltic built-up roof	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	OB500	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation, EnergyGuard Perlite Recover Board, min. 0.75-inch EnergyGuard Perlite Roof Insulation, min. 0.25-inch SECUROCK Gypsum Fiber Roof Board, Dens Deck, Dens Deck Prime	HA	GAF BUR. Note 15. (No V-BS)			-150.0

**TABLE 7A: RECOVER APPLICATIONS**  
**SYSTEM TYPE A-1: BONDED INSULATION, BONDED ROOF COVER**

<sup>A</sup> The reported MDP documents the allowable maximum design pressure of the new insulation and roof cover when installed atop the substrate, irrespective of the deck type (See Note 1) or performance of the substrate (See Note 12). The deck and substrate shall be capable of resisting the project design pressure requirements, not to exceed the noted MDP, to the satisfaction of the Authority Having Jurisdiction.

System No.	Substrate (Notes 1 & 12)	Base Insulation Layer		Top Insulation Layer		Roof Cover (Note 15)			MDP (psf) <sup>A</sup>
		Type	Attach (Notes 6,7,8)	Type	Attach (Notes 6,7,8)	Base	Ply	Cap	
R-12.	Existing sand- or granule-surface modified bitumen or asphaltic built-up roof	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	OB500	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation, EnergyGuard Perlite Recover Board, min. 0.75-inch EnergyGuard Perlite Roof Insulation, min. 0.25-inch SECUROCK Gypsum Fiber Roof Board, Dens Deck, Dens Deck Prime	HA			GAF BUR. Note 15. (No V-BS)	-150.0
R-13.	Existing sand- or granule-surface modified bitumen or asphaltic built-up roof	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	OB500	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or min. 0.25-inch SECUROCK Gypsum Fiber Roof Board, Dens Deck, Dens Deck Prime	OB500			GAF BUR. Note 15. (No V-BS)	-150.0
R-14.	Existing sand-surface APP modified bitumen or asphaltic built-up roof	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	OB500	Min. 0.5-inch Structodek High Density Fiberboard Roof Insulation or min. 0.25-inch SECUROCK Gypsum Fiber Roof Board, Dens Deck, Dens Deck Prime	OB500			GAF BUR. Note 15. (No V-BS)	-150.0
<b>VENTING SYSTEMS:</b>									
R-15.	Existing sand- or granule-surface modified bitumen or asphaltic built-up roof; (Optional) ASTM D41 primer	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	HA	None	N/A	V-BS		GAF BUR. Note 15.	-150.0
R-16.	Existing smooth-surface asphaltic built-up roof	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	LRF-M	None	N/A	V-BS		GAF BUR. Note 15.	-75.0
R-17.	Existing sand- or granule-surface modified bitumen or asphaltic built-up roof	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	LRF-M	None	N/A	V-BS		GAF BUR. Note 15.	-225.0
R-18.	Existing sand- or granule-surface modified bitumen or asphaltic built-up roof	Max. 48 x 48 x min. 0.5-inch EnergyGuard Polyiso Insulation	OB500	None	N/A	V-BS		GAF BUR. Note 15.	-225.0

**TABLE 7B: RECOVER APPLICATIONS**  
**SYSTEM TYPE F: NON-INSULATED, BONDED ROOF COVER**

<sup>A</sup> The reported MDP documents the allowable maximum design pressure of the new roof cover when adhered to the substrate, irrespective of the deck type (See Note 1) or performance of the substrate (See Note 12). The deck and substrate shall be capable of resisting the project design pressure requirements, not to exceed the noted MDP, to the satisfaction of the Authority Having Jurisdiction.

System No.	Substrate (Notes 1 & 12)	Roof Cover (Note 15)			MDP (psf) <sup>A</sup>
		Base	Ply	Cap	
R-19.	Existing asphaltic built-up roof	V-BS	GAF BUR. Note 15.		-60.0