

EVALUATION REPORT

Page 1 of 3

Manufacturer: ABC Supply Outdoor Solutions
400 West McNab Road
Fort Lauderdale, FL 33309

Code: Florida Building Code – Building, 9th Edition (2026)

Product Category: Shutters

Subcategory: Accordion

Compliance Method: Rule 61G20-3 Method 1(d), Evaluation Report by an Architect or Engineer

Product Name: HR Accordion Shutter System


Description: High Rise Aluminum Accordion Shutter System

Purpose: This Evaluation Report is issued in accordance with Rule 61G20-3 pertaining to Product Approvals issued by the Florida Building Commission. This is a building code evaluation. Neither Knezevich Consulting, LLC nor John W. Knezevich, PE is the Designer of Record for any project using this Evaluation Report for permitting unless specifically retained for that purpose.

Compliance: This impact resistant accordion shutter system has been evaluated and found to be in compliance with the referenced Code and is, for the purpose intended, at least equivalent to that required by the Code.
This Evaluation Report is valid provided there are no changes to the product, quality assurance program, or referenced code. A re-evaluation of the product is required following any code changes in order to maintain its validity.

This item has been digitally signed and sealed by John W. Knezevich PE on the date adjacent to the seal.

Signature must be verified on any electronic copies.



07/30/2026

Evaluation Report Prepared by:
Knezevich Consulting, LLC

Digitally signed by
John W. Knezevich

John W. Knezevich, PE
President
FL License No. PE 41961
FL CA No. 27988
FBC Organization ID No. ANE1754

EVALUATION REPORT

Page 2 of 3

1. Evidence Submitted:

1.1. Test Reports:

Construction Testing Corporation (CTC), signed and sealed Test Report No. 000013 dated 06/03/2000. Testing complies with TAS 201-94, TAS 202-94, and TAS 203-94.

1.2. Product Evaluation Document:

Knezevich Consulting, LLC Drawing No. KC26-0714 dated July 30, 2026, Sheets 1 through 9. The Product Evaluation Document is an integral part of this Evaluation Report.

1.3. Structural Calculations:

Calculations prepared by John W. Knezevich, PE verify the system performance based on testing and analysis of tested properties. Calculations also verify the specified anchorage is compliant with allowable anchor capacities.

1.4. Quality Assurance

National Accreditation and Management Institute, Inc. (NAMI) – FBC Organization Number QUA1789.

2. Impact Resistance:

2.1. This HR Accordion Shutter System is large missile impact resistant (9 pound missile D) and is acceptable for use where large or small missile impact resistant coverings are required.

3. Wind Load Resistance:

3.1. This HR Accordion Shutter System is designed and tested to resist wind loads as referenced on the Product Evaluation Documents.

4. Installation:

4.1. Installation, including anchorage to structure, shall be in accordance with the Product Evaluation Document referenced herein.

5. Material Specifications:

5.1. Component materials, anchors, and structural substrates acceptable for use shall be in accordance with the Product Evaluation Documents.

6. Labeling:

6.1. Shutters shall be labeled in compliance with FBC Section 1709.9.

7. Limitations and Conditions of Use:

7.1. This is a building code evaluation report addressing the referenced sections of the Florida Building Code. Neither Knezevich Consulting, LLC nor John W. Knezevich, PE are the Design Professional of Record for any project on which this Evaluation Report is used for permitting or design guidance unless retained specifically for that purpose.

7.2. This evaluation report covers uses as detailed in the referenced Product Evaluation Documents. Conditions outside the scope of those documents are not within the scope of this evaluation.

7.3. This evaluation report is applicable for installations within or outside of the Florida Building Code, High Velocity Hurricane Zone (HVHZ). Reference Sheet 1 for appropriate tables.

EVALUATION REPORT

Page 3 of 3

8. Certificate of Independence

- 8.1. Knezevich Consulting, LLC does not have, nor will it acquire, a financial interest in any company manufacturing or distributing products for which this evaluation report is issued.
- 8.2. Knezevich Consulting, LLC is not owned, operated, or controlled by any company manufacturing or distributing products for which this evaluation report is issued.
- 8.3. John W. Knezevich, PE does not have, nor will acquire, a financial interest in any company manufacturing or distributing products evaluated in this report.
- 8.4. John W. Knezevich, PE does not have, nor will acquire, a financial interest in any other entity involved in the approval process of products for which this evaluation report is issued.