

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 511873C

Manufacturer: Provia Door, Inc.
2150 State Route 39 West
Sugarcreek, OH 44681

Product Line: Reinforced Vinyl Sliding Glass Door – Commercial - Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-01271 Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test Report No.: NCTL-110-13716-1 signed and sealed by Robert H. Zeiders.
National Certified Testing Laboratories, York, PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 50.0 psf
Water penetration resistance: 8.25psf
3. Anchor calculations, report number 511873-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 50.0 psf
- Maximum Size: 96 1/8" x 96"
- Approved configurations: OX and XO
- Units to be glazed per ASTM E 1300 with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame and sash material to be rigid PVC.

Installation: Units must be installed in accordance with approval document, 08-01271 Revision A.

Certification of Independence: Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

