

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 511143C

Manufacturer: Provia Door, Inc.
2150 State Route 39 West
Sugarcreek, OH 44681

Product Line: S-4200 Prestige PVC Fixed Window

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-00671 revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: AI-03288-B1, signed by Jean Miller
AIR – INS Inc., Varennes, Quebec, Canada
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 75.0 psf
Water penetration resistance 15.0psf
3. Anchor calculations, report number 511144-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 75.0 psf
- Unit size: 50" x 106"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-00671, Revision B.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

