

**L. Roberto Lomas P.E.**

208 7th Avenue  
Indialantic, FL 32903  
434-688-0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

**Report No.: 515171**

**Manufacturer:** Krestmark Industries, L.P.  
3950 Bastille Rd., Suite 100  
Dallas, TX 75212

**Product Line:** 200/275 Vinyl Single Hung Tilt Window Non-Impact 44" x 72"

**Compliance:**

The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-03925, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: CCLI 17-159 signed and sealed by Abdol Rezadad, P.E.  
Construction Consulting Laboratory International, Carrollton, TX  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure:  $\pm 50.0$ psf  
Water penetration resistance 7.52psf (with sill extender)
3. Anchor calculations with comparative analysis, report number 515171-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure: Refer to approval drawing
- Unit size: Refer to approval drawing
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Extruded PVC.
- Unit must be installed with sill extender.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03925.

**Certification of Independence:**

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

