

*L. Roberto Lomas P.E.*

208 7th Avenue  
Indialantic, FL 32903  
434-688-0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

**Report No.: 515173**

**Manufacturer:** Krestmark Industries, L.P.  
3950 Bastille Rd., Suite 100  
Dallas, TX 75212

**Product Line:** 200/275 Vinyl Triple Single Hung Window w/Transom Non-Impact

**Compliance:**

The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-03927, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: CCLI 14-067 signed by Abdol Rezadad P.E.  
Construction Consulting Laboratory International, Carrollton, TX  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure:  $\pm 50.0$ psf  
Water penetration resistance 7.5psf
3. Anchor calculations, report number 515173-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure: Refer to approval drawing
- Unit size: Refer to approval drawing
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Extruded PVC.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03927.

**Certification of Independence:**

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

