



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 E. Dania Beach Blvd.  
Suite 338  
Dania Beach, FL 33004  
954.399.8478 PH  
954.744.4738 FX  
contact@buildingdrops.com

## Product Evaluation Report

*of*

**Steelcraft H Series  
Outswing Double Flush Commercial Steel Door**

*for*

**Florida Product Approval**

**FL# FL12400**

**Report No. 5811**

**Current Florida Building Code**

**Method: 1 – D (Engineering Evaluation)**  
**Category: Exterior Doors**  
**Sub – Category: Swinging Exterior Door Assemblies**

**Product: *Steelcraft H Series Outswing Double Flush  
Commercial Steel Door***  
**Material: 16 Ga. Min. Cold Rolled Steel**  
**Product Dimensions: 100" x 100" Max. O.A.**

**Prepared for:**

**Schlage Lock Company, LLC.  
11819 N. Pennsylvania Street  
Carmel, IN 46032**

**Prepared by:**


**Hermes F. Norero**

Florida Professional Engineer # 73778

Date: 07/12/2018

Contents:

Evaluation Report Pages 1 – 4



**Hermes F. Norero, P.E.**  
Florida No. 73778



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: **FL12400**

Date: 07/12/2018

Report No: 5811

---

**Manufacturer:** Schlage Lock Company, LLC.

**Product Category:** Exterior Doors

**Product Sub-Category:** Swinging Exterior Door Assemblies

**Compliance Method:** State Product Approval Method 1(d)

**Product Name:** **Steelcraft H Series Outswing Double Flush Commercial Steel Door**  
(Impact)  
100" x 100" Max. O.A.

**Scope:** This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Schlage Lock Company, LLC.** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Florida Building Code.

See Installation Instructions **IRFD07**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

## Limits of Use:

1. This product has been evaluated and is in compliance with the Florida Building Code, including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the Florida Building Code and does not require an impact resistant covering.
4. Site conditions that deviate from the details of drawing **IRFD07** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **IRFD07** for size and design pressure limitations.

Hermes F. Norero, P.E.

Florida No. 73778

Page 2 of 4



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: **FL12400**

Date: 07/12/2018

Report No: 5811

**Quality Assurance:** The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **UL LLC**. (FBC Organization #: QUA9625)

**Performance Standards:** The product described herein has been tested per:

- TAS 201-94
- TAS 202-94
- TAS 203-94
- ASTM E283-04
- ASTM E330-02
- ASTM E331-00

**Referenced Data:**

1. Product Testing performed by **Certified Testing Laboratories**  
(FBC Organization # TST1577)  
Report #: CTLA-3045W, Report Date: 02/16/15  
Report #: CTLA-776W-1, Report Date: 04/25/02  
Report #: CTLA-975W, Report Date: 01/23/03  
Report #: CTLA-882W, Report Date: 08/29/02  
Report #: CTLA-1035W, Report Date: 05/28/03  
Report #: CTLA-1086W, Report Date: 11/17/03  
Report #: CTLA-1107W-3, Report Date: 06/30/04  
Report #: CTLA-3064W, Report Date: 01/08/16  
Report #: CTLA-3064W-1, Report Date: 01/08/16  
Report #: CTLA-3064W-2, Report Date: 01/08/16  
Report #: CTLA-3064W-3, Report Date: 01/08/16  
Report #: CTLA-3064W-4, Report Date: 01/08/16  
Report #: CTLA-3064W-5, Report Date: 01/08/16  
Report #: CTLA-3064W-6, Report Date: 01/08/16  
Report #: CTLA-3064W-7, Report Date: 01/08/16  
All reports signed and sealed by Ramesh Patel, FL P.E. No 20224
2. Product Testing performed by **National Certified Testing Laboratories, Inc.**  
(FBC Organization # TST1589)  
Report #: NCTL-210-03-0514-11, Report Date: 08/31/04  
Report #: NCTL-210-03-3511-1, Report Date: 04/09/08  
Report #: NCTL-210-03-3549-1, Report Date: 08/26/08  
Report #: NCTL-210-3580-2, Report Date: 03/25/09  
Report #: NCTL-210-3357-1, Report Date: 12/28/06  
Report #: NCTL-210-3645-1, Report Date: 12/28/06  
All reports signed and sealed by Gerard Ferrara, FL P.E. No 11985



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: **FL12400**

Date: 07/12/2018

Report No: 5811

3. Product Testing performed by **Element Materials Technology**  
(FBC Organization # TST2613)  
Report #: ESP011623P, Report Date: 05/14/13  
All reports signed and sealed by Jason Steen, FL P.E. No 67814
4. Product Testing performed by **Intertek**  
(FBC Organization # TST1527)  
Report #: G1447.01-450-18, Report Date: 02/07/17  
Report #: G4839.01-450-18, Report Date: 02/07/17  
All reports signed and sealed by Joseph Reed, FL P.E. No 58920
5. Quality Assurance  
**UL LLC.**  
(FBC Organization # QUA9625)

**Installation:** Refer to Installation Instructions (**IRFD07**) for qualified installation methods and requirements.

**Design Pressure:** Refer to Installation Instructions (**IRFD07**) for design pressures dependent on hardware type, configuration, and size of units.