

W. W. Schaefer Engineering & Consulting, P.A. (CA #6809)

7480 150th Court North
Palm Beach Gardens, FL 33418
Phone (561)744-3424

ENGINEER'S EVALUATION REPORT #WWS-162

Prepared for:

Palm City Millwork, Inc.
3313 SW 42nd Ave.
Palm City, Florida 34990
Phone: (800) 273-5598

Prepared by:

Warren W. Schaefer, P.E.
Florida Professional Engineer #44135

Manufacturer: Palm City Millwork, Inc.

Product Category: Windows

Evaluation Method: 1-D (Engineer's evaluation)

Product model & name: Aluminum Clad Wood Single Hung Window

Documents that must accompany this report:

1. W. W. Schaefer Engineering & Consulting drawing No. 1683

Window size restrictions and assembly requirements:

See drawing NO. 1683

Maximum allowable design pressure:

See drawing NO. 1683

Installation requirements:

See drawing No. 1683

Code compliance:

Code section(s) considered with this evaluation:
FBC Chapters 17 & 24

Wood Coatings:

All wood members shall be of an approved durable species or be treated in an approved method with an approved preservative per applicable codes and standards.

Mullions:

Mullion conditions stated in this approval have been tested in accordance with TAS-201, 202 & 203 and meet the requirements of FBC.

Test Standards applicable to the testing of these windows:
TAS-201, 202 & 203

Test Laboratory: Hurricane Test Lab, Inc.

Test report numbers: 0067-0905-03, 0067-0124-04 & 0067-0505-04

General report notes & system limitations:

1. All size & installation conditions shown in this report and the referenced drawing No. 1683 are based off the referenced test reports and/or engineering analysis in accordance with the Florida Building Code.
2. Windows shall be constructed in accordance with the descriptions in this report, and the manufacturer's state approved quality assurance entity specifications.
3. This product is approved for use in the High Velocity Hurricane Zones (HVHZ).
4. Job required design wind pressure shall be calculated in accordance with the Florida Building Code Chapter 16 and ASCE 7 Minimum Design Loads for Buildings and Other Structures (0.85 directionality factor may apply).
5. These windows are both small & large missile impact rated for use in wind zone 4 & missile level "D" locations and need not be shuttered.

Quality Assurance Entity: Architectural Testing, Inc. (ATI)

JAN 08 2015

Warren W. Schaefer, P.E.
Florida P.E. #44135

