L. Roberto Lomas P.E.
208 7th Ave
Indialantic, FL 32903
434-688-0609
rllomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 514754A

Manufacturer: Krestmark Industries, L.P.
3950 Bastille Rd., Suite 100
Dallas, TX 75212

Product Line: 200/275 Vinyl Picture Window Non-Impact 72" x 84"

Compliance:
The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:
1. Approval document: drawing number 08-03641, revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: CCLI 16-111 signed and signed by Abdol Rezadad, P.E.
   Construction Consulting Laboratory International, Carrollton, TX
   AAMA/WDMA/CSA 101/I.S.2/A440
   Design pressure: ±50.0psf
   Water penetration resistance 7.52psf
3. Anchor calculations with comparative analysis, report number 514754-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:
- Design pressure: Refer to installation drawing
- Unit size: Refer to installation drawing
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Extruded PVC.

Installation:
Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03641, revision A.

Certification of Independence:
Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

LUIS R. LOMAS
LICENSE
No. 62514
STATE OF
FLORIDA
PROFESSIONAL ENGINEER

Luis R. Lomas, P.E.
FL No.: 62514
10/19/2023