

W. W. Schaefer Engineering & Consulting, P.A. (CA #6809)

7480 150th Court North
Palm Beach Gardens, FL 33418
Phone (561)744-3424

ENGINEER'S EVALUATION REPORT #WWS-151

Prepared for:

C.P. Loewen Enterprises
77 Hwy 52 West
Steinbach, MB Canada R5G 1B2
Phone: (204) 326-6446

Prepared by:

Warren W. Schaefer, P.E.
Florida Professional Engineer #44135

Manufacturer: C.P. Loewen Enterprises

Product Category: Windows

Evaluation Method: 1-D (Engineer's evaluation)

Product model & name: Aluminum Clad Wood Fixed Casement Windows

Documents that must accompany this report:

1. W. W. Schaefer Engineering & Consulting drawing No. 1639

Window size restrictions and assembly requirements:

See drawing NO. 1639

Maximum allowable design pressure:

See drawing NO. 1639

Installation requirements:

See drawing No. 1639

Code compliance:

Code section(s) considered with this evaluation:

FBC Chapter 17

Test Standards applicable to the testing of these windows:

TAS-201, 202 & 203

ASTM E1886

ASTM E1996

AAMA/WDMA/CSA 101/I.S.2/A440

Test Laboratory: Architectural Testing, Inc.

Test report numbers: 90622.01-201-44, 90622.02-201-44, 90622.03-201-44, 89969.01-201-44 & 89969.02-201-44. Note: All HVHZ test reports have been signed & sealed by a Florida P.E.

General report notes & system limitations:

1. All size & installation conditions shown in this report and the referenced drawing No. 1639 are based off the referenced test reports and/or engineering analysis in accordance with the Florida Building Code.
2. Windows shall be constructed in accordance with the descriptions in this report, and the manufacturer's state approved quality assurance entity specifications.
3. This product is approved for use in the High Velocity Hurricane Zones (HVHZ).
4. Job required design wind pressure shall be calculated in accordance with the Florida Building Code Chapter 16 and ASCE 7 Minimum Design Loads for Buildings and Other Structures (0.85 directionality factor may apply).
5. These windows are large missile impact rated and need not be shuttered.

Quality Assurance Entity: Window & Door Manufacturers Association (WDMA)

Warren W. Schaefer, P.E. AUG 17 2017
Florida P.E. #44135

