

SWARTZ
CONSULTING ENGINEERS LLC

Project Number:	SCE 25-04017
Project Name:	F-3500 Swinging Door - Opaque
Date:	11/1/2025
Page:	1 of 7

**Product Approval Supporting Calculations
Alternative Anchorage Analysis & Design
R2 - Size Clarification**

Project Number: SCE 25-04017


Drawing Number: D1000184

Reference Test Report: SJW2013-196

Product Name: F-3500 Swinging Door - Opaque 112.125" x 97.938" & 112.125" x 81.938"

Prepared for:

Jeld-Wen Windows & Doors
3737 Lakeport Blvd.
Klamath Falls, OR



11/01/25


Prepared by:
Swartz Consulting Engineers LLC



Micah Swartz, PE
Florida License No. PE 93573
Florida Registry No. 38420

This item has been digitally signed and sealed by Micah Swartz, P.E. on the date adjacent to the seal.

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.



Scope:

Swartz Consulting Engineers LLC is contracted by Jeld-Wen Windows & Doors to evaluate alternative anchorage for the product: F-3500 Swinging Door - Opaque 112.125" x 97.938" & 112.125" x 81.938". This evaluation is based on testing observed by National Certified Testing Laboratories in Klamath Falls, OR, test report no.: SJW2013-196 and dated 09/13/2013.

This evaluation does not include the air infiltration, water resistance or water penetration of the installation method or the installed product. In addition, the design of the building substrate to resist the superimposed loads is by others.

Reference Standards:

Current edition of the Florida Building Code

ANSI/AWC NDS 2018 - National Design Specification (NDS) for Wood Construction

AISI S100-16 (2020) North American Specification for the Design of Cold-Formed Steel Structural Members

ICC-ES Report ESR-1976 ITW Buildex TEKS Self-Drilling Fasteners


ICC-ES Report ESR-2196 Hilti Self Drilling Screws to connect cold-formed steel

NOA 24-0102.06 Tapcon Concrete and Masonry Anchors with Advanced Threadform Technology

Certification of Independence:

In accordance with Rule 61G20-3 Florida Administrative Code, Swartz Consulting Engineers LLC hereby certifies the following:

- (1) Swartz Consulting Engineers LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products tested or labeled by the agency.
- (2) Swartz Consulting Engineers LLC is not owned, operated or controlled by any company manufacturing or distributing products it tests or labels.
- (3) Micah Swartz, P.E. does not have, nor will acquire, a financial interest in any company manufacturing or distributing products for which the reports are being issued.
- (4) Micah Swartz, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.



Design Summary:

The table below summarizes the product: F-3500 Swinging Door - Opaque 112.125" x 97.938" & 112.125" x 81.938" and their corresponding performance levels as established by testing.

Table 1: Summary of Test Results

Series/Model	Test Report Number	Size (W x H)	Performance
F-3500 Swinging Door - Opaque 112.125" x 81.938"	SJW2013-196 (09/13/2013)	112.125" x 81.938"	+50 psf / -50 psf
F-3500 Swinging Door - Opaque 112.125" x 97.938"	SJW2013-196 (09/13/2013)	112.125" x 97.938"	+45 psf / -45 psf

As Tested Design:

Screw Information:

Screw Size: 10 Screw Embed: 1.5 in Edge Distance: 3/4 in (minimum)

Wood Screw Lateral: 149 lbs

Alternative Fasteners:

Screw Information:

Screw Size: 10 Screw Embed: 1.5 in Edge Distance: 3/4 in (minimum)


Wood Screw Lateral: 149 lbs

Tapcon Information:

Tapcon Size: 1/4 Embedment: 1-1/4 in (minimum) Edge Distance: 2-1/2 in (minimum)

Tapcon Lateral (Concrete): 203 lbs

Tapcon Lateral (CMU): 161 lbs



Summary of Test Results - Plastics Checklist


Table 2: Summary of Test Results - Plastics Checklist

Product	Test Report Number	Test Standard	Performance
DYLITE Expandable Polystyrene	3113726SAT-001 R1	ASTM E84	Flame Spread Index: 35
			Smoke Density Index: 450

The testing summarized in the table above was conducted by Intertek ETL SEMKO in Elmendorf, TX dated 03/13/09 and meets the requirements listed in Miami-Dade County Checklist #0445, For the approval of: Plastic and Foam Plastic.

SMC Skin (fiberglass material)	ESP010982P	ASTM D638 (before and after G155)	-2.2% (averaged)
		ASTM D1929	770 °F (410 °C)
		ASTM D2843	62
		ASTM D635	Classification HB

The testing summarized in the table above was conducted by Element Materials Technology in St Paul, MN on 02/26/13 and meets the requirements listed in Miami-Dade County Checklist #0445, For the approval of: Plastic and Foam Plastic.



Subject: As Tested - Wood Screw Lateral Design - Single Shear

Input:

Calculation:

Screw Information:

Screw Size: 10

Root Diameter: 0.152 in

Screw Embed: 1.5 in

Main Member Type: S-P-F

G: 0.42

F_{em}: 3,350 psi

thickness (t_m): 1.5 in

Side Member Type: S-P-F

G: 0.42

F_{es}: 3,350 psi

thickness (t_s): 1 in

Lateral Design Factors - Table 12.3.1A (NDS)

D:	0.152	in	Diameter
F _{yb} :	90	ksi	Dowel Bending Yield Strength
F _{em} :	3,350	psi	Main Member dowel bearing strength
F _{es} :	3,350	psi	Side Member dowel bearing strength
l _m :	1.5	in	Main Member dowel bearing length
l _s :	1	in	Side Member dowel bearing length
R _d :	2.2		Reduction term - Table 12.3.1B (NDS)
R _e :	1		= F _{em} /F _{es}
R _t :	1.5		= l _m /l _s
k ₁ :	0.535		See Table
k ₂ :	1.133		See Table

Reference Lateral Design Values - Table 12.3.1A (NDS)

$$Z_{Im}: 347 \text{ lbs} \quad Z_{Im} = \frac{D l_m F_{em}}{R_d} \text{ (EQ 12.3 - 1)}$$


$$Z_{II}: 124 \text{ lbs} \quad Z_{II} = \frac{k_1 D l_s F_{es}}{R_d} \text{ (EQ 12.3 - 3)}$$

$$Z_{III}: 131 \text{ lbs} \quad Z_{III} = \frac{k_2 D l_m F_{em}}{(1 + 2R_e) R_d} \text{ (EQ 12.3 - 4)}$$

$$Z_{IV}: 105 \text{ lbs} \quad Z_{IV} = \frac{D^2}{R_d} \sqrt{\frac{2F_{em}F_{yb}}{3(1 + R_e)}} \text{ (EQ 12.3 - 6)}$$

$$Z_{MIN}: 105 \text{ lbs}$$

Note: Side member is part of the Jeld-Wen assembly and verified during testing. Modes Z_{Is} and Z_{IIIs} are not applicable to the calculation.



Subject: As Tested - Wood Screw Lateral Design - Single Shear Cont.

Adjusted Lateral Design Values

$$Z' = Z * C_D * C_M * C_t * C_g * C_{\Delta} - \text{As per table 11.3.1 NDS}$$

C_D :	1.6	Load Duration Factor - Table 2.3.2 (NDS)
C_M :	1.0	Wet Service Factor - Table 11.3.3 (NDS)
C_t :	1.0	Temperature Factor - Table 11.3.4 (NDS)
C_g :	1.0	Group Action Factor - Section 11.3.6 (NDS)
C_{Δ} :	1.0	Geometry Factor - Section 12.5.1.1 (NDS)

$$Z': \boxed{168} \text{ lbs}$$

Fastener Bending Across Shim Space

Ω :	1.67	
L:	0.25	in Maximum Shim Gap
D:	0.152	in Diameter
F_{yb} :	90	ksi Dowel Bending Yield Strength

$$\frac{F_{yb}}{\Omega} = \frac{M}{S} = \frac{16ZL}{\pi D^3} \Leftrightarrow Z = \frac{F_{yb} \pi D^3}{16 \Omega L} \quad \text{Where } M = \frac{ZL}{2} \text{ (Guided Bending)}$$


$$Z_n/\Omega: \boxed{149} \text{ lbs}$$

Bearing on Masonry Strap

Ω :	3.00	
F_u :	33	ksi Tensile Strength of strap
t:	20	GA
t:	0.036	in thickness of strap
D:	0.152	in

$$\frac{P_{nv}}{\Omega} = 2.7 * t * D * F_u - (EQ. J4.3.1 - 4, AISI S100)$$

$$P_{nv}/\Omega: \boxed{162} \text{ lbs}$$



Subject: Tapcon Lateral Design

Input:
Calculation:

Tapcon Size:

Size:
D: in Nominal Diameter
D_{sh}: in Shank Diameter

Fastener Shear Capacity - 3,000 psi Concrete

P_{nv}/Ω: lbs See Table 1B of NOA 24-0102.06

Fastener Shear Capacity - Medium-Weight CMU

P_{nv}/Ω: lbs See Table 3 of NOA 24-0102.06

Note:

- Critical anchor spacing is 16D
- Minimum Anchor Embedment is 1-1/4"
- Minimum Edge Distance is 2-1/4"

Fastener Bending Across Shim Space

L: in Maximum Shim Gap
D_{sh}: in Shank Diameter of Tapcon
F_{yb}: ksi Yield Strength of Tapcon

Ω:

$$\frac{F_{yb}}{\Omega} = \frac{M}{S} = \frac{16P_n L}{\pi D^3} \Leftrightarrow P_n = \frac{F_{yb} \pi D^3}{16 \Omega L}$$

Where $M = \frac{P_n L}{2}$ (Guided Bending)

P_n/Ω: lbs

Bearing Strength of Masonry Straps - AISI S100

Size: Tapcon Size
D_{sh}: in Shank Diameter of Tapcon Screw
F_u: ksi Tensile Strength of Masonry Strap
t: GA
t: in Thickness of Masonry Strap

Ω:

$$\frac{P_{nv}}{\Omega} = 2.7 * t * D * F_u - (EQ. J4.3.1 - 3, AISI S100)$$

P_{nv}/Ω: lbs