

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 511521B

Manufacturer: Comfort View Products, LLC
320 Coweta Industrial Parkway
Building 7, Suite C-I
Newnan, GA 30265

Product Line: 1900 Twin Single Hung w/1901 Transom

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-00960, Revision D, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No. AI-03658-A1 signed by Jean Miller
Air-Ins Inc Varennes, Quebec J3X 1P7
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±50psf
Water penetration resistance 7.25psf
3. Anchor calculations, report number 511521-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ±50psf
- Maximum unit size: 72" x 108"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-00960, Revision D.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

