

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

## Engineering Evaluation Report

**Report No.: 511520C**

**Manufacturer:** Comfort View Products  
320 Coweta Industrial Parkway  
Newnan, GA 30265

**Product Line:** 1920/1952 Horizontal Slider window Non-Impact

**Compliance:**

The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-00959 revision D, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: ATI 93154.01-602-44-R1 signed by Wanda Matis.  
Architectural Testing Inc., Schofield, WI  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure: +50.0/-55.0psf  
Water penetration resistance 7.52psf
3. Anchor calculations, report number 511520-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Maximum design pressure: +50.0/-55.0psf
- Maximum unit size: 72" x 48"
- Approved configurations: OX and XO.
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

**Installation:**

Units must be installed in accordance with manufacturer's installation details and approval document, 08-00959 revision D.

**Certification of Independence:**

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

