



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 E Dania Beach Blvd.
Suite 338
Dania Beach, FL 33004
954.399.8478 PH
954.744.4738 FX
contact@buildingdrops.com

Product Evaluation Report

of

Caoba Doors

Aluminum Clad Double Hung Window

for

Florida Product Approval

FL# FL14295

Report No. 5327

Current Florida Building Code

Method:	1 – D (Engineering Evaluation)
Category:	Windows
Sub – Category:	Double Hung
Product:	Aluminum Clad Double Hung Window
Material:	Mahogany (Min. S.G.=0.45)
Product Dimensions:	54" x 84"

Prepared For:

Caoba Doors
4918 Cedar Avenue
Philadelphia, PA 19143

Prepared by:

Hermes F. Norero, P.E.


Florida Professional Engineer # 73778

Date: 11/30/17

Contents:

Evaluation Report Pages 1 – 4

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2017.12.18 20:07:52 -05'00'



Hermes F. Norero, P.E.
Florida No. 73778



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL #: **FL14295**

Date: 11/30/2017

Report No: 5327

Manufacturer: Caoba Doors

Product Category: Windows

Product Sub-Category: Double Hung

Compliance Method: State Product Approval Method (1)(d)

Product Name: **Aluminum Clad Double Hung Window**
54" x 84"
(Impact Rated)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Caoba Doors** based on Method 1d of the State of Florida Product Approval, Florida Department of Business & Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **CAB036**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and does not require an impact resistant covering.
4. Site conditions that deviate from the details of **CAB036** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **CAB036** for size and design pressure limitations.

Hermes F. Norero, P.E.
Florida No. 73778
Page 2 of 4



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL #: **FL14295**

Date: 11/30/2017

Report No: 5327

Certification Agency:

The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by and approved by **National Accreditation & Management Institute** (FBC Organization #: QUA1789).

Performance Standards:

The product described herein has been tested per:

- TAS 201-94
- TAS 202-94
- TAS 203-94

Referenced Data:

1. Product Testing performed by **Certified Testing Laboratories**
(FBC Organization #: TST1577)
Report #: CTLA 1806W-1 Report Date: 03/25/08
2. Quality Assurance
National Accreditation & Management Institute
(FBC Organization #: QUA1789)
3. Material Certification
Miami-Dade County Notice of Acceptance
SentryGlas Interlayer by Kuraray America, Inc. (Previously by DuPont)

Hermes F. Norero, P.E.

Florida No. 73778

Page 3 of 4



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL #: **FL14295**

Date: 11/30/2017

Report No: 5327

Installation:

1. Approved anchor types and substrates are as follows:

- A. For two by (2X) wood frame substrate, use **#10 Wood Screw** type wood frame anchors of sufficient length to achieve minimum embedment of 1-1/2" into wood framing.
- B. For concrete or masonry substrate where wood bucking is NOT employed, use **3/16" ITW Tapcon** type concrete screw anchors of sufficient length to achieve minimum embedment of 1-1/4" into concrete or masonry.
- C. For concrete or masonry substrate where wood bucking is employed, use **3/16" ITW Tapcon** type concrete screw anchors of sufficient length to achieve minimum embedment of 1-1/4" into concrete or masonry.

Refer to manufacturer Installation Instructions **CAB036** for anchor spacing and more details of the installation requirements.

Design Pressure:

<u>Design Pressure</u>
+100/-100 PSF

Hermes F. Norero, P.E.

Florida No. 73778

Page 4 of 4