



Evaluation Report VEL-FPA-LPGS
October 15, 2026

Product Description: Low Profile Skylight

Manufacturer/Distributor: VELUX America, LLC 85 Spencer Drive Wells, ME 04090

Documentation:

1. This evaluation report, prepared by Alan G. Kinne, P.E.
2. Approval drawing VEL-FPA-LPGS, signed and sealed by Alan G. Kinne, P.E.
3. Architectural Testing Report D0614.01-250-44 signed by J.P. McDonald, P.E.
4. Anchor Calculations prepared by Alan G. Kinne, P.E.

Installation: This Product must be installed according to approval drawing VEL-FPA-LPGS.

Limitations of Use:

- This product is approved for use at the size and design pressures shown in approval drawing VEL-FPA-LPGS. Smaller sizes are also approved.
- This product is not approved for use in the High Velocity Hurricane Zone (HVHZ).
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- This product must be glazed per ASTM E1300-16. Refer to approval drawing VEL-FPA-LPGS for glazing details.
- The aluminum frame of this product is 6063-T6 (or better) aluminum.

Statement of Compliance: The product listed within this report was evaluated per the requirements of FAC Product Approval Rule 61G20-3.005 method 1(d). This product complies with the requirements of the 2026 Florida Building Code, 9th Edition.

Certification of Independence: I do not have, nor intend to acquire, a financial interest in any company involved in the approval process of the product listed in this product approval. I do not have, nor do I intend to acquire, a financial interest in any other entity involved in the testing of this product.

Kinne Engineering, LLC
523 S Moon Dr
Venice, FL 34292
941-400-6013

