

L. Roberto Lomas P.E.

233 W. Main St
Danville, VA 24541
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 513450

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave.
Ft. Myers, FL 33912

Product Line: Series 600 Aluminum Sliding Glass Door - XXX

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02675, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: 3507/22/02-311 signed and sealed by Luis Figueredo, P.E.
Fenestration Testing Laboratory, Inc., Hialeah, FL
ANSI/AAMA/NWDA 101/I.S.2-97/AAMA 1303.5-76
Design pressure: ± 60.0 psf
Water penetration resistance 10.0psf
3. Anchor calculations, report number 513450-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 60.0 psf.
- Maximum panel size: 51" x 95"
- Units must be glazed per ASTM E 1300-04, with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Aluminum 6063-T6.

Installation: Units must be installed in accordance with approval document, 08-02675.

Certification of Independence: Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

