

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609

Engineering Evaluation Report

Report No.: 513451A

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave.
Fort Myers, FL 33912

Product Line: Series FWI 6000 Aluminum Impact Rated Sliding Glass Door

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02676, revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: LAB #3751 Report 3 signed and sealed by Joseph Chan P.E..
Fenestration Testing Laboratory, Inc., Hialeah, FL
TAS 201-94 Large Missile Impact Test, Level D, Wind Zone 4
TAS 202 -94 Uniform Static Air Pressure, ± 80.0 psf design pressure, 14.0psf water penetration.
TAS 203-94 Cyclic Pressure loading ± 80.0 psf design pressure
3. Anchor calculations, report number 513451-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 80.0 psf
- Maximum panel size: 51" x 95"
- Approved configurations: OXXO, XXO, OXX, XX, OX, XO,
- Units must be glazed per ASTM E1300-04/09, according to glazing details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be extruded Aluminum.
- Units must be installed with 2 1/4" high riser.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02676, revision A.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

