

L. Roberto Lomas P.E.

233 W. Main St
Danville, VA 24541
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 513466

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave.
Ft. Myers, FL 33912

Product Line: Series 600 Aluminum Sliding Glass Door

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02691, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: 3651/28/02-311 signed and sealed by Joseph Chan, P.E.
Fenestration Testing Laboratory, Inc., Hialeah, FL
ANSI/AAMA/NWDA 101/I.S.2-97
Design pressure: ± 80.0 psf
Water penetration resistance 15.0psf
3. Anchor calculations, report number 513466-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 80.0 psf
- Maximum panel size: 62" x 94"
- Units must be glazed per ASTM E 1300-04, with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be aluminum 6063-T6.
- Units must be installed with 3 3/4" high riser.

Installation: Units must be installed in accordance with approval document, 08-02691.

Certification of Independence: Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

