

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave,
Fort Myers, FL 33912

Product Line: Series FD8100 Aluminum Sliding Glass Door - LMI

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02732, revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test Report No.: NCTL 210-3755-1 signed and sealed by Gerard J. Ferrara, P.E.
National Certified Testing Laboratories, Orlando, FL
TAS 201-94 Large Missile Impact Test, Level D, Wind Zone 4
TAS 202 -94 Uniform Static Air Pressure, ± 60.0 psf design pressure, 9.0psf water penetration.
TAS 203-94 Cyclic Pressure loading ± 60.0 psf design pressure
3. Test report No.: NCTL 210-3755-1A signed and sealed by Gerard J. Ferrara, P.E.
National Certified Testing Laboratories, Orlando, FL
AAMA/WDMA/CSA 101/I.S.2/A440-05
Design pressure: ± 60.0 psf
Water resistance: 9.0psf
ASTM E1886-02 and ASTM E1996-02
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4
ASTM E1886/ E1996 Cyclic Load Test, ± 60.0 psf design pressure
4. Test Report No.: NCTL 210-3756-1 signed and sealed by Gerard J. Ferrara, P.E.
National Certified Testing Laboratories, Orlando, FL
TAS 201-94 Large Missile Impact Test, Level D, Wind Zone 4
TAS 202 -94 Uniform Static Air Pressure, ± 50.0 psf design pressure, 9.0psf water penetration.
TAS 203-94 Cyclic Pressure loading ± 60.0 psf design pressure
5. Test report No.: NCTL 210-3756-1A signed and sealed by Gerard J. Ferrara, P.E.
National Certified Testing Laboratories, Orlando, FL
AAMA/WDMA/CSA 101/I.S.2/A440-05
Design pressure: ± 50.0 psf
Water resistance: 9.0psf
ASTM E1886-02 and ASTM E1996-02
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4
ASTM E1886/ E1996 Cyclic Load Test, ± 60.0 psf design pressure
6. Anchor calculations, report number 513516-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: Refer to installation details.
- Maximum panel size: Refer to installation details.
- Units must be glazed per ASTM E1300-04/09, according to glazing details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be extruded Aluminum 6063-T6

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02732, revision A

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

