

L. Roberto Lomas P.E.

233 W. Main St
Danville, VA 24541
434-688 0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.:513166A

Manufacturer: Eastern Architectural Systems
16341 Domestic Avenue
FT Myers, FL 33912

Product Line: Series 1000 Aluminum Fixed Window – 60" x 48" Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02393, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Lab No. 3418/Report No.: 16/File No. 02-311-16 signed by Joseph Chan P.E.
Fenestration Testing Laboratory, Hialeah, FL
ANSI/AAMA/NWDMA 101/I.S.2-97
AAMA 1302.5-76
Design pressure: ±130.0psf
Water penetration resistance 15.0psf
3. Anchor calculations, report number 513166-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ±130.0psf
- Maximum unit size: 60" x 48"
- Units must be glazed per ASTM E1300-04.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be extruded Aluminum 6063-T5.

Installation: Units must be installed in accordance with approval document, 08-02393.

Certification of Independence: Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

