1432 Woodford Rd. Lewisville, NC 27023 434-688-0609

Engineering Evaluation Report

Report No.: 513453A

Manufacturer: Eastern Architectural Systems 16341 Domestic Ave. Fort Myers, FL 33912

Product Line: Series FWI 1000 Aluminum Horizontal Sliding Window - LMI

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

- 1. Approval document: drawing number 08-02678, revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test report No.: FTL 02-311-25 signed and sealed by Joseph Chan, P.E.
 - Fenestration Testing Laboratory, Inc., Hialeah, FL
 - TAS 201-94 Large Missile Impact Test, Level D, Wind Zone 4
 - TAS 202 -94 Uniform Static Air Pressure, ±80.0psf design pressure, 12.0psf water penetration.
 - TAS 203-94 Cyclic Pressure loading ±80.0psf design pressure
- 3. Anchor calculations, report number 513453-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:


- Maximum design pressure: ±80.0psf
- Maximum unit size: 72" x 60"
- Units must be glazed per ASTM E1300-04/09, according with glass details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be extruded Aluminum 6063-T6.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02678, revision A.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 01/05/2018