

*L. Roberto Lomas P.E.*

233 W. Main St.

Danville, VA 24541

434-688-0609

## Engineering Evaluation Report

Report No.: 513467

**Manufacturer:** Eastern Architectural Systems  
16341 Domestic Ave.  
Fort Myers, FL 33912

**Product Line:** Series 1000 Aluminum Horizontal Sliding Window 112" X 63"

**Compliance:**

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-02692 prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: FTL 5584/W-1499 signed by Manny Sanchez  
Fenestration Testing Laboratory, Inc., Hialeah, FL  
AAMA/WDMA/CSA 101/I.S.2/A440-05  
Design pressure: ±35.0psf  
Water penetration resistance 6.8psf
3. Anchor calculations, report number 513467-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Maximum design pressure: ±35.0psf
- Maximum unit size: 112" x 63"
- Units must be glazed per ASTM E1300-04.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be extruded Aluminum.

**Installation:** Units must be installed in accordance with approval document, 08-02692.

**Certification of Independence:** Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

