## L. Roberto Lomas P.E.

**Engineering Evaluation Report** 

**Report No.: 511353A** 

233 W. Main St.

Danville, VA 24541 434-688-0609

Rllomas@lrlomaspe.com

Manufacturer: Eastern Architectural Systems

3600 23<sup>rd</sup> Avenue South Lake Worth, FL 33461

Product Line: 10300085 Aluminum T Mullion Reinforced LMI Wind Zone 3

## Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

## Supporting Technical Documentation:

- Approval document: drawing number 08-00809, Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Mullion Analysis with anchor calculations, report number 511353-1A, and -2A, per AAMA 450-10 option 3, prepared, signed and sealed by Luis Roberto Lomas P.E.

## Limitations and Conditions of use:

Maximum design pressure: See charts in installation drawing.

Maximum vertical mullion span: 84"Maximum horizontal mullion span: 120"

- This product is not rated to be used in the HVHZ.
- This product is impact resistant up to wind zone 3 and does not require impact protection in wind borne debris regions.
- Mullion material to be extruded Aluminum 6005-T5.
- Steel Mullion Bracket material to be formed Galvanized Steel.
- Mull Clip material to be extruded Aluminum 6005-T5.
- Fenestration units mulled to this product must be manufactured by Eastern Architectural Systems and must have their own separate Product Approval.
- Design pressure of mulled units shall be controlled by the lesser design pressure of the assembly components; the mullion or the individual units.

Installation: Units must be installed in accordance with manufacturer's installation instructions and approval

document, 08-00809, Revision A.

**Certification of Independence:** Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

No. 6251# \*

No. 6251# \*

No. 6251#

STATE OF

ONLY

O

Luis R. Lomas, P.E. FL No.: 62514 04/11/2016