

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 511862D

Manufacturer: VuSafe Industries, LLC
350 Kidds Hill Road
Hyannis, MA 02601

Product Line: Storm Shutter Type A

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-01260 Revision D, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: ETC-07-1089-19072.2 signed and sealed by Joseph Labora Doldan P.E.
ETC Laboratories, Rochester, New York
ASTM E330
Design Pressure: ± 50 psf
ASTM E1886 & ASTM E1996
Large Missile Impact, Level D, Wind Zone 4
Cyclic Load Test, ± 50.0 psf design pressure
3. Anchor calculations, report number 511862-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 50 psf
- Panel Height: 108"
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-01260 Revision D.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

