

Evaluation Report "Englert® Series 3000" Metal Roof Assembly

Manufacturer:

Englert, Inc.

1200 Amboy Avenue
Perth Amboy, NJ 08862
(732) 826-8614

for

Florida Product Approval

FL 14668.4 R7

Florida Building Code 9th Edition (2026)

Method: 1 - D

Category: Structural Components

Sub - Category: Roof Deck

Product: "Series 3000" Roof Panel

Material: Aluminum

Panel Thickness: 0.037"

Panel Width: 15.25"


Panel Seam: Batten Seam

Support: Steel Purlins

Prepared by:

James L. Buckner, P.E., SECB
Florida Professional Engineer # 31242
Florida Evaluation ANE ID: 1916
Project Manager: Diana Galloway
Report No. 26-805-S3000-A37P-ER
(Revises 23-555-S3000-A37P-ER, FL14668.4 R6)
Date: 08/12/2026

This item has been digitally signed and sealed by James L. Buckner, P.E., on this date below. Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.



James L. Buckner, P.E.
FL31242



Contents:

Evaluation Report

Pages 1 – 8

CBUCK, Inc. dba CBUCK Engineering

Phone: (561) 491-9927 · Email: cbuck@cbuckinc.net · Website: www.cbuckinc.net

Business: 1374 Community Dr., Jupiter, FL 33458

2026.08.12 14:13:24 -04'00'

Manufacturer:	Englert, Inc. 1200 Amboy Avenue Perth Amboy, NJ 08862 (732) 826-8614 http://www.englertinc.com/
Product Name:	"Series 3000"
Product Category:	Structural Components
Product Sub-Category	Roof Deck
Compliance Method:	State Product Approval Rule 61G20-3.005 (1) (d)
Product/System Description:	"Series 3000" Standing Seam Roof Panel 2-3/4" Rib Height, 15-1/4" wide, 0.037" Aluminum roof panel attached to 16 gauge Steel Purlins with mechanically seamed fixed panel clips, batten caps and adhesive.
Product Assembly as Evaluated:	Refer to Page 4 of this report for product assembly components/materials & standards: 1. Roof Panel 2. Roof Panel Clips 3. Panel Batten Caps 4. Adhesive 5. Fasteners
Support :	Type: Steel Purlins (Design of support system is outside the scope of this evaluation.) Description: • Steel Purlins, 16 Gauge minimum • Yield Strength: 50 ksi minimum
Slope:	Minimum slope shall be: 1/2 : 12 or greater Minimum slope shall be in compliance with FBC Chapter 15 based on the type of roof covering, applicable code sections and in accordance with manufacturer's recommendations.
Performance:	Wind Uplift Resistance: • Design Uplift Pressure: (Refer to "Table A" attachment details herein) METHOD 1: - 54.4 PSF METHOD 2: - 110 PSF

Performance Standards:

The product described herein has demonstrated compliance with:

- **ASTM E 1592-05(2017)** – *Test Method for Structural Performance of Sheet Metal Roof and Siding Systems By Uniform Static Air Pressure Difference*

Code Compliance:

The product(s) described herein have demonstrated compliance with the performance standards listed above as referenced in the:

Florida Building Code 9th Edition (2026)

Evaluation Report Scope:

This product evaluation is limited to compliance with the structural wind load requirements of the Florida Building Code, as related to the scope section to Florida Product Approval Rule 61G20-3.001.

Limitations and Conditions of Use:

- Diaphragm and axial load capacity is outside the scope of this evaluation.

Scope of "Limitations and Conditions of Use" for this evaluation:

This evaluation report for "Optional Statewide Approval" contains technical documentation, specifications and installation method(s) which include "Limitations and Conditions of Use" throughout the report in accordance with Rule 61G20-3.005. Per Rule 61G20-3.004, the Florida Building Commission is the authority to approve products under "Optional Statewide Approval".

- This report is a building code product evaluation per FLPE rule (FAC) 61G15-36 to comply with Florida product approval rule (FAC) 61G20-3. This evaluation report is part of the Florida Building Commission approval for the listed code related criteria. This report by James Buckner, P.E. and CBUCK Engineering is not a design certification of code compliance construction submittal documentation, per FBC section 107, for any individual structure, site specific or permit design.
- Design of support system is outside the scope of this report. Support shall be structural framing members complying with the FBC Chapter 22 for steel and Chapter 16 for structural loading and shall be designed by others.
- All metal components and fasteners shall be corrosion resistant in accordance with applicable sections of FBC, including but not limited to Sections 1506.5, 1506.6, 1506.7 and 1507.4.4. Installations located within 3000 feet of a saltwater coastline shall comply with Section 1711 in accordance with authorities having jurisdiction.
- Metal roof and hip ridge covers is outside the scope of this evaluation and shall comply with FBC Section 1504.3.1.1.
- Fire Classification is outside the scope of Rule 61G20-3 and is therefore not included in this evaluation.
- This evaluation report does not evaluate the use of this product for use in the High Velocity Hurricane Zone code section. (Dade & Broward Counties)

Option for application outside "Limitations and Conditions of Use"

Rule 61G20-3.005(1)(e) allows engineering analysis for "project specific approval by the local authorities having jurisdiction in accordance with the alternate methods and materials authorized in the Code". Any modification of the product as evaluated in this report and approved by the Florida Building Commission is outside the scope of this evaluation and will be the responsibility of others.

Quality Assurance: The manufacturer has demonstrated compliance of roof panel products in accordance with the Florida Building Code and Rule 61G20-3.0005 (3) for manufacturing under a quality assurance program audited by an approved quality assurance entity through Keystone Certifications, Inc. (FBC Organization ID# QUA 1824).

Components/Materials (by Manufacturer):

Roof Panel:	Englert Series 3000
Material:	Aluminum
Thickness:	0.037" (min.)
Panel Width:	15-1/4" (max.) Coverage
Rib Height:	2-3/4"
Alloy Type:	3105-H14
Corrosion Resistance:	Per FBC Section 1507.4.3

Roof Panel Clips:

Product Name:	Englert "Series 3000 Fixed Clip"
Englert Part #:	05085A or 05085E
Type:	One-piece, fixed clip
Material:	Galvanized Steel (05085A) or Stainless Steel (05085E)
Thickness:	16 gauge
Yield Strength:	40 ksi min.
Dimensions:	4-3/8"(long) x 3-1/4"(tall) x 1-1/2"(wide)
Corrosion Resistance:	Per FBC Section 1506.7

Roof Panel Batten Caps:

Product Name:	Englert "Series 3000 Panel Batten Cap"
Material:	Galvanized Steel
Thickness:	24 gauge
Yield Strength:	40 ksi min.
Dimensions:	1-1/4" x 3/5"
Corrosion Resistance:	Per FBC Section 1506.7

Fastener:

Type:	Truss-Head Self-Drilling Sheet Metal Screw
Size :	#14 x 1-1/4"
Corrosion Resistance:	Per FBC Section 1506.6 and 1507.4.4
Standard:	Per FBC 1507.4.4 and SAE J78-1979

Components& Materials: (by Others)

Seam Adhesive/Seam Sealant:	
Product Name:	Bostik 70-05A
Type:	One component, polyurethane adhesive
Application Size:	(4) 1/4" continuous beads
Application Location:	along male flange the full length of panel (Refer to Table "A" and drawing Page 7)

Installation:

Installation Method:

(Refer to "TABLE A" below and drawings at the end of this evaluation report.)

- Clip/Purlin Spacing: **Refer to "TABLE A" Below**
- Two (2) fasteners per Clip
- Rib Interlock: Batten Cap Mechanically Seamed
- Seam Adhesive: Refer to Table "A" & Drawing Page 7.
(Apply along male flange the full length of the panel.)

TABLE "A" ALLOWABLE LOADS		
	METHOD 1:	METHOD 2:
Design Pressure:	- 54.4 PSF	- 110 PSF
# of Fasteners per Clip:	2	2
Adhesive:	(4) ¼" Beads Refer to Drawing Pg 7	(4) ¼" Beads Refer to Drawing Pg 7
Panel Seam:	Batten Cap	Batten Cap
Clip/Purlin Spacing:	60"	30"
Span Condition:	3 or more	3 or more
Notes: • Allowable design pressure(s) for allowable stress design (ASD). • Fastener Attachment to Steel Supports May Be Designed By A Qualified Design Professional As Required By The Florida Building Code For Site Specific Projects. • Diaphragm and axial load capacity are not included in this evaluation.		

Install the "Series 3000" roof panel assembly in compliance with the installation method listed in this report and applicable code sections of FBC 9th Edition (2026). The installation method described herein is in accordance with the scope of this evaluation report. Refer to manufacturer's installation instructions as a supplemental guide for attachment.

Referenced Data:


1. ASTM E 1592-05 Uplift Test
By ENCON Technology, Inc.
(FBC Organization ID# TST 6485, valid thru 2/10/12)
Report No. C1681-1, Date: 4/23/10
2. Quality Assurance
Keystone Certifications, Inc. (FBC Organization ID# QUA 1824)
Englert, Inc. Licensee #420
3. Certification of Independence
By James L. Buckner, P.E. @ CBUCK Engineering
(FBC Organization # ANE 1916)

Installation Method


Englert, Inc.

"Series 3000" (0.037" Aluminum) Roof Panel attached to Steel Purlins

Drawings



Panel Profile




Panel Clip

Englert "Series 3000 Fixed Clip"
(Part # 05085A or 05085E)

Batten Cap

Englert "Series 3000 Batten Cap"
24 gauge Steel

Installation Method
Englert, Inc.
"Series 3000" (0.037" Aluminum) Roof Panel attached to Steel Purlins



Typical Panel Assembly
Section View


**Installation Method
Englert, Inc.****"Series 3000" (0.037" Aluminum) Roof Panel attached to Steel Purlins****Typical Roof Assembly
Isometric View**

TABLE "A"		
	METHOD 1:	METHOD 2:
Design Pressure:	- 54.4 PSF	- 110 PSF
# of Fasteners per Clip:	2	2
Adhesive:	(4) ¼" Beads Refer to Drawing Pg 7	(4) ¼" Beads Refer to Drawing Pg 7
Panel Seam:	Batten Cap	Batten Cap
Clip/Purlin Spacing:	60"	30"
Span Condition:	3 or more	3 or more