



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 14677

Date: 07/27/2023

Detailed Product Description:

Manufacturer: AMERICAN FIBER CEMENT CORPORATION

Manufacturer Address: 6901 SOUTH PIERCE STREET, STE. #260, LITTLETON, CO 80123

Model Name: FIBER CEMENT RAINSCREEN CLADDING SYSTEM

Maximum Load: +70 PSF, -70 PSF (Non-Impact)

Installation Drawings # 11-02

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.				
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.				
Comparative analysis used ☐ Yes ☒ No				
Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)				
Test	Description	Test Location	Test Report Date	Test Report #
ASTM E330 & TAS 202	Uniform Static Air Press.	Fenestration Testing Laboratory, Inc	6/2/2011	FTL-6453
Supplemental Tests				
Test	Description	Test Location	Test Report Date	Test Report#
TAS 203	Cyclic	Fenestration Testing Laboratory, Inc	6/2/2011	FTL-6453
ASTM C1186	Material Testing	Architectural Testing	11/11/2009	87057.01-106-26
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.				
Evaluation Report Engineer:				
Jalal Farooq Al-Farooq Corporation		PE # 81223 EB # 3538		
		 Sealed: 8/1/2023		