

*L. Roberto Lomas P.E.*

1432 Woodford Rd.  
Lewisville, NC 27023  
434-688-0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

Report No.: 513267B

**Manufacturer:** Nan Ya Plastics Corp. USA  
8989 North Loop East  
Houston, TX 77029

**Product Line:** Series SLPS 12080 OS 3/4 Lite Fiberglass Patio Door – Non-Impact

**Compliance:**

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-02498 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: NCTL-210-3973-03 signed by Mark Bennett  
National Certified Testing Laboratories, Orlando, FL.  
AAMA/WDMA/CSA101/I.S.2/A440-08  
Design pressure: ±50.0psf  
Water penetration resistance 7.5psf
3. Anchor calculations, report number 513267-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Maximum design pressure: ±50.0psf
- Maximum frame size: 143 1/8" x 95 1/2"
- Units must be glazed per ASTM E1300-04/09, with safety glass.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be CO-Extruded PVC Foam.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02498 revision B.

**Certification of Independence:**

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

