

SWARTZ
CONSULTING ENGINEERS LLC

Project Number:	SCE 25-08024
Project Name:	Premium (V-4500) Vinyl Casement Fixed In
Date:	8/19/2025
Page:	1 of 15

Product Approval Supporting Calculations Alternative Anchorage Analysis & Design

Project Number: SCE 25-08024

Drawing Number: D010587

Reference Test Report: SJW2014-029


Product Name: Premium (V-4500) Vinyl Casement Fixed Insash 144.094 x 72.007

Impact: No

Design Pressure: +50 psf / -55 psf

Prepared for:

Jeld-Wen Windows & Doors
3737 Lakeport Blvd.
Klamath Falls, OR



08/18/25

Prepared by:
Swartz Consulting Engineers LLC

Micah Swartz, PE
Florida License No. PE 93573
Florida Registry No. 38420

This item has been digitally signed
and sealed by Micah Swartz, P.E.
on the date adjacent to the seal.

Printed copies of this document
are not considered signed and
sealed and the signature must be
verified on any electronic copies.



Scope:

Swartz Consulting Engineers LLC is contracted by Jeld-Wen Windows & Doors to evaluate alternative anchorage for the product: Premium (V-4500) Vinyl Casement Fixed Insash 144.094 x 72.007. This evaluation is based on testing observed by National Certified Testing Laboratories in Klamath Falls, OR, test report no.: SJW2014-029 and dated 03/31/14 revised 04/22/14.

This evaluation does not include the air infiltration, water resistance or water penetration of the installation method or the installed product. In addition, the design of the building substrate to resist the superimposed loads is by others.

Reference Standards:

Current edition of the Florida Building Code, Building

ANSI/AWC NDS - National Design Specification (NDS) for Wood Construction

AISI S100 North American Specification for the Design of Cold-Formed Steel Structural Members

ICC-ES Report ESR-1976 ITW Buildex TEKS Self-Drilling Fasteners

ICC-ES Report ESR-2196 Hilti Self Drilling Screws to connect cold-formed steel

NOA 24-0102.06 Tapcon Concrete and Masonry Anchors with Advanced Threadform Technology

Certification of Independence:

In accordance with Rule 61G20-3 Florida Administrative Code, Swartz Consulting Engineers LLC hereby certifies the following:

- (1) Swartz Consulting Engineers LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products tested or labeled by the agency.
- (2) Swartz Consulting Engineers LLC is not owned, operated or controlled by any company manufacturing or distributing products it tests or labels.
- (3) Micah Swartz, P.E. does not have, nor will acquire, a financial interest in any company manufacturing or distributing products for which the reports are being issued.
- (4) Micah Swartz, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.



Project Number: SCE 25-08024
Project Name: Premium (V-4500) Vinyl Casement Fixed Insash
Date: 8/19/2025 Page: 3 of 15

Design Summary:

The table below summarizes the product: Premium (V-4500) Vinyl Casement Fixed Insash 144.094 x 72.007 and their corresponding performance levels as established by testing.

Table 1: Summary of Test Results

Series/Model	Test Report Number	Size (W x H)	Performance
Premium (V-4500) Vinyl Casement Fixed Insash 144.094 x 72.007	SJW2014-029 (03/31/14 revised 04/22/14)	144.094 x 72.007	+50 psf / -55 psf

As Tested Design:

Applied Load (psf): 55 psf Width: 144.09 in Height: 72.007 in
Max ULD (along JAMB): 165 plf

Screw Information:

Screw Size: 8 Screw Embed: 1.25 in Edge Distance: 3/4 in (minimum)
qty: 1 Spacing: 4 in O.C. (Nail Fin)

Wood Screw Withdrawal: 164 lbs Per ft. Capacity: 492 plf Unity: 0.34

Alternative Fasteners:

Screw Information:

Screw Size: 8 Screw Embed: 1.25 in Edge Distance: 3/4 in (minimum)
qty: 1 Spacing: 4 in O.C. (Thru Frame)
qty: 1 Spacing: 4 in O.C. (Nail Fin)


Wood Screw Withdrawal: 164 lbs Per ft. Capacity: 492 plf Unity: 0.34
Wood Screw Lateral: 106 lbs Per ft. Capacity: 317 plf Unity: 0.52

Nail Information:

Nail Size: 6d Nail Type: Common Edge Distance: 3/4 in (minimum)
qty: 2 Spacing: 4 in O.C. (Thru Frame)
qty: 1 Spacing: 4 in O.C. (Nail Fin)

*Additional Fastener @ Mull.

Nail Withdrawal: 53 lbs Per ft. Capacity: 160 plf Unity: 1.03
Nail Lateral: 113 lbs Per ft. Capacity: 680 plf Unity: 0.24



Design Summary Continued:

TEK Screw Information:


Screw Size: 10-16 qty: 1 Spacing: 4 in O.C. (Thru Frame)
qty: 1 Spacing: 4 in O.C. (Nail Fin)

TEK Withdrawal: 145 lbs Per ft. Capacity: 435 plf Unity: 0.38
TEK Lateral: 147 lbs Per ft. Capacity: 441 plf Unity: 0.37

Tapcon Information:

Tapcon Size: 3/16 Embedment: 1-1/4 in (minimum) Edge Distance: 2-1/2 in (minimum)
qty: 1 Spacing: 4 in O.C.

Tapcon Lateral (Concrete): 155 lbs Per ft. Capacity: 464 plf Unity: 0.36
Tapcon Lateral (CMU): 135 lbs Per ft. Capacity: 405 plf Unity: 0.41



Subject: As Tested - Wood Screw Withdrawal

Input:

Calculation:

Screw Information:

Screw Size: 8

Root Diameter: 0.131 in

Screw Embed: 1.25 in

Main Member Type: S-P-F

G: 0.42

F_{em}: 3,350 psi

$$W' = W * C_D * C_M^2 * C_t - \text{As per table 11.3.1 NDS}$$

C_D: 1.6 Load Duration Factor - Table 2.3.2 (NDS)

C_M: 1.0 Wet Service Factor - Table 11.3.3 (NDS)

C_t: 1.0 Temperature Factor - Table 11.3.4 (NDS)

W: 82 lbs/in - Table 12.2B (NDS)

W: 103 lbs

W': 164 lbs



Subject: Wood Screw Withdrawal

Input:
Calculation:

Screw Information:

Screw Size: 8
Screw Embed: 1.25 in
Root Diameter: 0.131 in

Main Member Type: S-P-F G: 0.42 F_{em} : 3,350 psi

$$W' = W * C_D * C_M^2 * C_t - \text{As per table 11.3.1 NDS}$$

C_D : 1.6 Load Duration Factor - Table 2.3.2 (NDS)
 C_M : 1.0 Wet Service Factor - Table 11.3.3 (NDS)
 C_t : 1.0 Temperature Factor - Table 11.3.4 (NDS)

W: 82 lbs/in - Table 12.2B (NDS)
W: 103 lbs

W': 164 lbs



Subject: Wood Screw Lateral Design - Single Shear

Input:

Calculation:

Screw Information:

Screw Size: 8

Root Diameter: 0.131 in

Screw Embed: 1.25 in

Main Member Type: S-P-F G: 0.42 F_{em} : 3,350 psi thickness (t_m): 1.5 in

Side Member Type: S-P-F G: 0.42 F_{es} : 3,350 psi thickness (t_s): 1.25 in

Lateral Design Factors - Table 12.3.1A (NDS)

D:	0.131 in	Diameter
F_{yb} :	100 ksi	Dowel Bending Yield Strength
F_{em} :	3,350 psi	Main Member dowel bearing strength
F_{es} :	3,350 psi	Side Member dowel bearing strength
l_m :	1.25 in	Main Member dowel bearing length
l_s :	1.25 in	Side Member dowel bearing length
R_d :	2.2	Reduction term - Table 12.3.1B (NDS)
R_e :	1	$= F_{em}/F_{es}$
R_t :	1.0	$= l_m/l_s$
k_1 :	0.414	See Table
k_2 :	1.158	See Table

Reference Lateral Design Values - Table 12.3.1A (NDS)

$$Z_{Im}: 249 \text{ lbs} \quad Z_{Im} = \frac{D l_m F_{em}}{R_d} \text{ (EQ 12.3 - 1)}$$

$$Z_{II}: 103 \text{ lbs} \quad Z_{II} = \frac{k_1 D l_s F_{es}}{R_d} \text{ (EQ 12.3 - 3)}$$

$$Z_{III_m}: 96 \text{ lbs} \quad Z_{III_m} = \frac{k_2 D l_m F_{em}}{(1 + 2R_e) R_d} \text{ (EQ 12.3 - 4)}$$

$$Z_{IV}: 82 \text{ lbs} \quad Z_{IV} = \frac{D^2}{R_d} \sqrt{\frac{2F_{em}F_{yb}}{3(1 + R_e)}} \text{ (EQ 12.3 - 6)}$$

$$Z_{MIN}: 82 \text{ lbs}$$

Note: Side member is part of the Jeld-Wen assembly and verified during testing. Modes Z_{Is} and Z_{IIs} are not applicable to the calculation.



Subject: Wood Screw Lateral Design - Single Shear Cont.

Adjusted Lateral Design Values

$$Z' = Z * C_D * C_M * C_t * C_g * C_{\Delta} - \text{As per table 11.3.1 NDS}$$

C_D :	1.6	Load Duration Factor - Table 2.3.2 (NDS)
C_M :	1.0	Wet Service Factor - Table 11.3.3 (NDS)
C_t :	1.0	Temperature Factor - Table 11.3.4 (NDS)
C_g :	1.0	Group Action Factor - Section 11.3.6 (NDS)
C_{Δ} :	1.0	Geometry Factor - Section 12.5.1.1 (NDS)

$$Z': \boxed{132} \text{ lbs}$$

Fastener Bending Across Shim Space

Ω :	1.67	
L :	0.25	in Maximum Shim Gap
D :	0.131	in Diameter
F_{yb} :	100	ksi Dowel Bending Yield Strength

$$\frac{F_{yb}}{\Omega} = \frac{M}{S} = \frac{16ZL}{\pi D^3} \Leftrightarrow Z = \frac{F_{yb} \pi D^3}{16 \Omega L}$$

$$\text{Where } M = \frac{ZL}{2} \text{ (Guided Bending)}$$

$$Z_n/\Omega: \boxed{106} \text{ lbs}$$

Bearing on Masonry Strap

Ω :	3.00	
F_u :	33	ksi Tensile Strength of strap
t :	20	GA
t :	0.036	in thickness of strap
D :	0.131	in

$$\frac{P_{nv}}{\Omega} = 2.7 * t * D * F_u - (EQ. J4.3.1 - 4, AISI S100)$$

$$P_{nv}/\Omega: \boxed{140} \text{ lbs}$$



Subject: Nail Withdrawal

Input:

Calculation:

Nail Information:

Nail Size: 6d

Nail Length: 2 in

Nail Type: Common

Nail Diameter: 0.113 in

Nail Embedment: 1.88 in

Main Member Type: S-P-F

G: 0.42

F_{em} : 3,350 psi thickness (t_m): 1.5 in

Side Member Type: PVC

G: N/A

F_{es} : 13,750 psi thickness (t_s): 0.125 in

$$W' = W * C_D * C_M^2 * C_t - \text{As per table 11.3.1 NDS}$$

C_D : 1.6 Load Duration Factor - Table 2.3.2 (NDS)

C_M : 1.0 Wet Service Factor - Table 11.3.3 (NDS)


C_t : 1.0 Temperature Factor - Table 11.3.4 (NDS)

W: 18 lbs/in

$$W = 1380G^{5/2}D - \text{Carbon Steel Nails (EQ. 12.2 - 3, NDS)}$$

W: 33 lbs

W': 53 lbs



Subject: Nail Lateral Design - Single Shear

Input:
Calculation:

Nail Information:

Nail Size: Nail Length: in
Nail Type: Nail Diameter: in Nail Embedment: in

Main Member Type: G: F_{em} : psi thickness (t_m): in

Side Member Type: G: F_{es} : psi thickness (t_s): in

Lateral Design Factors - Table 12.3.1A (NDS)

D:	0.113 in	Diameter
F_{yb} :	100 ksi	Dowel Bending Yield Strength
F_{em} :	3,350 psi	Main Member dowel bearing strength
F_{es} :	13,750 psi	Side Member dowel bearing strength
l_m :	1.625 in	Main Member dowel bearing length
l_s :	0.125 in	Side Member dowel bearing length
R_d :	2.2	Reduction term - Table 12.3.1B (NDS)
R_e :	0.2436	$= F_{em}/F_{es}$
R_t :	13.0	$= l_m/l_s$
k_1 :	1.230	See Table
k_2 :	0.622	See Table

Reference Lateral Design Values - Table 12.3.1A (NDS)

Z_{Im} : lbs $Z_{Im} = \frac{D l_m F_{em}}{R_d}$ (EQ 12.3 - 1)

Z_{II} : lbs $Z_{II} = \frac{k_1 D l_s F_{es}}{R_d}$ (EQ 12.3 - 3)

Z_{III_m} : lbs $Z_{III_m} = \frac{k_2 D l_m F_{em}}{(1 + 2R_e) R_d}$ (EQ 12.3 - 4)

Z_{IV} : lbs $Z_{IV} = \frac{D^2}{R_d} \sqrt{\frac{2F_{em}F_{yb}}{3(1 + R_e)}}$ (EQ 12.3 - 6)

Z_{MIN} : lbs

Note: Side member is part of the Jeld-Wen assembly and verified during testing. Modes Z_{Is} and Z_{IIs} are not applicable to the calculation.



Subject: Nail Lateral Design - Single Shear Cont.

Adjusted Lateral Design Values

$$Z' = Z * C_D * C_M * C_t * C_g * C_{\Delta} - \text{As per table 11.3.1 NDS}$$

C_D :	1.6	Load Duration Factor - Table 2.3.2 (NDS)
C_M :	1.0	Wet Service Factor - Table 11.3.3 (NDS)
C_t :	1.0	Temperature Factor - Table 11.3.4 (NDS)
C_g :	1.0	Group Action Factor - Section 11.3.6 (NDS)
C_{Δ} :	1.0	Geometry Factor - Section 12.5.1.1 (NDS)

$$Z': \boxed{124} \text{ lbs}$$

Fastener Bending Across Shim Space

Ω :	1.67	
L :	0.25	in Maximum Shim Gap
D :	0.113	in Diameter
F_{yb} :	100	ksi Dowel Bending Yield Strength

$$\frac{F_{yb}}{\Omega} = \frac{M}{S} = \frac{16ZL}{\pi D^3} \Leftrightarrow Z = \frac{F_{yb}\pi D^3}{16\Omega L}$$

$$\text{Where } M = \frac{ZL}{2} \text{ (Guided Bending)}$$


$$Z_n/\Omega: \boxed{113} \text{ lbs}$$

Bearing on Masonry Strap

Ω :	3.00	
F_u :	33	ksi Tensile Strength of strap
t :	20	GA
t :	0.036	in thickness of strap
D :	0.113	in

$$\frac{P_{nv}}{\Omega} = 2.7 * t * D * F_u - (EQ. J4.3.1 - 4, AISI S100)$$

$$P_{nv}/\Omega: \boxed{120} \text{ lbs}$$



Subject: TEK Withdrawal

Input:
Calculation:

Shear Strength of Fastener - ESR 1976

Screw Size: 10-16

P_{nv}/Ω : 885 lbs See ESR 2196

Tensile Pullout - ESR 1976

Screw Size: 10-16

F_u : 45 ksi

t: 16 GA

t: 0.0598 in

Tensile Strength of material NOT in contact with screw head

Thickness of material NOT in contact with screw head

P_{nv}/Ω : 145 lbs See ESR 2196

Tensile Pullover

Note: The tensile pullover analysis checks the material IN contact with the screw head. This material is part of the Jeld-Wen assembly and has been verified by testing. Below is a check to ensure the head size of the TEK screw is equal to or larger than the head of the tested fastener, ensuring compliance.


Tested Fastener Head Size:

Screw Size: 8
Head Size: 0.312 in

Tested fastener is a

TEK Screw Head Size:

Screw Size: 10-16
Head Size: 0.365 in



Subject: TEK Lateral Design

Input:
Calculation:

Shear Strength of Fastener - ESR 1976

Screw Size: 10-16

P_{nv}/Ω : 573 lbs See ESR 2196

Bearing Strength of Material NOT in Contact with Screw Head - AISI S100

Screw Size: 10-16

Ω : 3.00

D: 0.138 in Root Diameter of TEK Screw
 F_u : 45 ksi Tensile Strength of material NOT in contact with screw head
t: 18 GA
t: 0.0478 in Thickness of material NOT in contact with screw head

$$\frac{P_{nv1}}{\Omega} = 2.7 * t * D * F_u - (EQ.J4.3.1 - 3, AISI S100)$$

$$\frac{P_{nv2}}{\Omega} = 4.2 \sqrt{t^3 * D} * F_u - (EQ.J4.3.1 - 1, AISI S100)$$

P_{nv1}/Ω : 267 lbs

P_{nv2}/Ω : 245 lbs

P_{nv}/Ω : 245 lbs $\frac{P_{nv}}{\Omega} = \text{smallest of } \frac{P_{nv1}}{\Omega} \text{ and } \frac{P_{nv2}}{\Omega}$

Bearing Strength of Material IN in Contact with Screw Head

Note: Material IN contact with the screw head is part of the Jeld-Wen assembly and has been verified by testing.

Fastener Bending Across Shim Space


L: 0.25 in Maximum Shim Gap
D: 0.138 in Root Diameter of TEK Screw
 F_{yb} : 100 ksi Yield Strength of TEK Screw

Ω : 3.00

$$\frac{F_{yb}}{\Omega} = \frac{M}{S} = \frac{16P_n L}{\pi D^3} \Leftrightarrow P_n = \frac{F_{yb} \pi D^3}{16 \Omega L}$$

$$\text{Where } M = \frac{P_n L}{2} \text{ (Guided Bending)}$$

P_n/Ω : 206 lbs




Bearing Strength of Masonry Straps - AISI S100

Screw Size: **10-16** TEK Screw
D: **0.138** in Root Diameter of TEK Screw
F_u: **33** ksi Tensile Strength of Masonry Strap
t: **20** GA
t: **0.0359** in Thickness of Masonry Strap

Ω: **3.00**

$$\frac{P_{nv}}{\Omega} = 2.7 * t * D * F_u - (EQ.J4.3.1 - 3, AISI S100)$$

P_{nv}/Ω: **147** lbs



Subject: Tapcon Lateral Design

Input:
Calculation:

Tapcon Size:

Size:
D: in Nominal Diameter
D_{sh}: in Shank Diameter

Fastener Shear Capacity - 3,000 psi Concrete

P_{nv}/Ω: lbs See Table 1B of NOA 24-0102.06

Fastener Shear Capacity - Medium-Weight CMU

P_{nv}/Ω: lbs See Table 3 of NOA 24-0102.06

Note:

- Critical anchor spacing is 16D
- Minimum Anchor Embedment is 1-1/4"
- Minimum Edge Distance is 2-1/4"

Fastener Bending Across Shim Space

L: in Maximum Shim Gap
D_{sh}: in Shank Diameter of Tapcon
F_{yb}: ksi Yield Strength of Tapcon

Ω:

$$\frac{F_{yb}}{\Omega} = \frac{M}{S} = \frac{16P_n L}{\pi D^3} \Leftrightarrow P_n = \frac{F_{yb} \pi D^3}{16 \Omega L}$$

Where $M = \frac{P_n L}{2}$ (Guided Bending)

P_n/Ω: lbs

Bearing Strength of Masonry Straps - AISI S100

Size: Tapcon Size
D_{sh}: in Shank Diameter of Tapcon Screw
F_u: ksi Tensile Strength of Masonry Strap
t: GA
t: in Thickness of Masonry Strap

Ω:

$$\frac{P_{nv}}{\Omega} = 2.7 * t * D * F_u - (EQ. J4.3.1 - 3, AISI S100)$$

P_{nv}/Ω: lbs