

Product Evaluation Report**Report No.:** FL-14904.7**Date:** July 12, 2023

Product Category	Sub Category	Manufacturer	Product Name
Windows	Casement	Fleetwood Windows and Doors 1 Fleetwood Way Corona, CA 92879 (951) 279-1070	Series 3800-T w/ Series 350-T Aluminum Casement Window w/ Thermal Break Frame "Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Fleetwood Windows and Doors based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in the "HVHZ" this product complies with Section 1626 of the Florida Building Code and does not require an impact resistant covering.
4. When used in areas outside of the "HVHZ" requiring wind borne debris protection, this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E 1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1.
5. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
6. Site conditions that deviate from the details of drawing FL-14904.7 require further engineering analysis by a licensed engineer or registered architect.
7. This product meets the water infiltration requirements for "HVHZ".
8. Gaskets and setting blocks shall comply with section 2411.3.4 of the FBC.
9. Aluminum components, including fasteners, shall meet the requirements of FBC Section 2003.
10. See drawing FL-14904.7 for size and design pressure limitations.

Supporting Documents:

1. **Test Report No.**
TEL 01990816
TEL 01990818
TEL 01990817
TEL 01991006
TEL 01991007
TEL 01991008
Test Standard
TAS 201, 202, 203-94
ASTM E1886-05/E1996-06
AAMA/WDMA/CSA101/I.S.2/A440-08
TAS 201, 202, 203-94
AAMA/WDMA/101/I.S.2/A440-08
ASTM E 1886-05/E 1996-06
Testing Laboratory
Testing Evaluation Lab., Inc.
Testing Evaluation Lab., Inc.
Testing Evaluation Lab., Inc.
Testing Evaluation Lab., Inc.
Testing Evaluation Lab., Inc.
Testing Evaluation Lab., Inc.
Signed by
William Shelton, P.E.
V. K. Wright
V. K. Wright
William B. Shelton, P.E.
V.K. Wright
V.K. Wright
2. **Dade County NOA**
22-1116.01
Materials Testing
Gaskets by Tremco
Materials Testing
SentryGlas® Interlayer (Kuraray America, Inc.)
Test Standard
ASTM C 864 (Option II) per FBC 2411.3.4
3. **Drawing No.**
No. FL-14904.7
Prepared by
RW Building Consultants, Inc. (#9813)
Signed & Sealed by
Lyndon F. Schmidt, P.E.
4. **Calculations**
Anchoring
ASTM E 1300 Glass Load
Prepared by
RW Building Consultants, Inc. (#9813)
Lyndon F. Schmidt, P.E.
Signed & Sealed by
Lyndon F. Schmidt, P.E.
5. **Quality Assurance**
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Fleetwood Windows and Doors is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.

Digitally signed by Lyndon F Schmidt
Date: 2023.07.12 09:46:47 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 7-12-23.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA