



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 East Dania Beach Blvd.

Suite 338

Dania Beach, FL 33004

954.399.8478 PH

954.744.4738 FX

contact@buildingdrops.com

Product Evaluation Report

of

**AMERICAN CRAFTSMAN WINDOWS
SILVER LINE WINDOWS AND DOORS
70 Series / V3 Series/ (5800) Gliding Patio Door
(NON-IMPACT) (HVHZ)**

for

Florida Product Approval

FL# FL14998

Report No. 7293

Current Florida Building Code

Method:	1 – D (Engineering Evaluation)
Category:	Exterior Doors
Sub – Category:	Sliding Exterior Door Assemblies
Product:	70 Series / V3 Series/ (5800) Gliding Patio Door (NON-IMPACT) (HVHZ)
Material:	Vinyl
Product Dimensions:	See Installation Instructions, SWD041

Prepared for:

**Silver Line Windows and Doors
One Silverline Dr.
North Brunswick, NJ 08902**

Prepared by:

Hermes F. Norero, P.E.


Florida Professional Engineer # 73778

Date: 10/15/2020

Contents:

Evaluation Report

Pages 1 – 3



Hermes F. Norero, P.E.

Florida P.E. No. 73778



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL14998

Date: 10/15/20

Report No: 7293

Manufacturer: Silver Line Windows and Doors

Product Category: Exterior Doors

Product Sub-Category: Sliding Exterior Door Assemblies

Compliance Method: State Product Approval Method (1)(d)

Product Name: 70 Series / V3 Series/ (5800) Gliding Patio Door
(NON-IMPACT) (HVHZ)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Silver Line Windows and Doors** based on Method 1d of the State of Florida Product Approval, Florida Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **SWD041**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **including** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does** require an impact resistant covering.
5. Site conditions that deviate from the details of Installation Instructions **SWD041** require further engineering analysis by a licensed engineer or registered architect.
6. See Installation Instructions **SWD041** for size and design pressure limitations.

Hermes F. Norero, P.E.

Florida P.E. No. 73778

Page 2 of 3



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL14998

Date: 10/15/20

Report No: 7293

Quality Assurance Entity: The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a Quality Assurance Entity through **Window and Door Manufacturers Association** (FBC Organization #QUA2515).

Performance Standards: The product described herein has been evaluated per:

- TAS 202-94

Referenced Data:

1. Product Testing performed by **Testing Evaluation Lab, Inc.**
(FBC Organization # TST4317)
Report #: TEL 01410070 Report Date: 04/06/2015
Signed and Sealed by Lyndon Schmidt, PE # 43409
2. Quality Assurance Entity
Window and Door Manufacturers Association
(FBC Organization #QUA2515)
3. PVC profiles certified by AAMA in accordance with AAMA 303

Installation Method: Please refer to installation instructions, **SWD041**, for anchor methods, selection, spacing, edge distances, embedment's and further details of installation.

Design Pressure: Please refer to installation instructions, **SWD041**, for mull combination grouping, configurations, and corresponding design pressures.