

Product Evaluation Report**Report No.:** FL-15054.18**Date:** July 30, 2020

Product Category	Sub Category	Manufacturer	Product Name
Windows	Fixed	NewSouth Window Solutions 10741 Crossroads Commerce Blvd Tampa, FL 33610 (513) 284.0129	9650 Fixed Window Impact Rated - HVHZ w/ Flange

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for NewSouth Window Solutions, based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Dept. of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 7th Edition (2020) Florida Building Code (FBC) including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in the "HVHZ", this product complies with Section 1626 of the Florida Building Code and does not require an impact resistant covering.
4. When used in areas outside of the "HVHZ" requiring wind borne debris protection, this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E 1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1.
5. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
6. Site conditions that deviate from the details of drawing FL-15054.18 require further engineering analysis by a licensed engineer or registered architect.
7. This product meets water infiltration requirements for "HVHZ".
8. See drawing FL-15054.18 for size and design pressure limitations.

Supporting Documents:

1. Test Report No. ATI C9933.05-401-18 TEL 02031566	Test Standard TAS 201, 202, 203-94 TAS 201, 202, 203-94	Testing Laboratory Architectural Testing, Inc. Testing Evaluation Labs.	Signed by Shawn G. Collins, P.E. William B. Shelton, P.E.
--	--	--	--

2. Dade County NOA 17-0712.05 17-0808.02	Materials Saflex PVB Interlayer (Eastman Chemical Co.) SentryGlas Interlayer (Kuraray)
---	---


3. Drawing No. No. FL-15054.18	Prepared by RW Building Consultants, Inc. (#9813)
--	---

Signed & Sealed by
Lyndon F. Schmidt, P.E.

4. Calculations Anchoring ASTME 1300 Glass Load	Prepared by RW Building Consultants, Inc. (#9813) Lyndon F. Schmidt, P.E.
--	--

Signed & Sealed by
Lyndon F. Schmidt, P.E.

5. Quality Assurance
Certificate of Participation issued by National Accreditation and Management Institute, certifying that NewSouth Window Solutions is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.



Lyndon F. Schmidt, P.E.
FL PE No. 43409
7/30/2020