



EVALUATION REPORT

FLORIDA BUILDING CODE, 7TH EDITION (2020)

Manufacturer: MID-STATES ASPHALT AND CANT STRIP, INC. *Issued December 20, 2022*
 1637 51st Street
 Tuscaloosa, AL 35401
 (800) 489-2391
<http://www.midstatesasphalt.com>

Manufacturing Plants: Tuscaloosa, AL
 Griffin, GA

Quality Assurance: UL LLC (QUA9625)

SCOPE

Category: Roofing
Subcategory: Underlayments
Code Sections: 1507.1.1, 1507.2.9.2, 1507.6.5, 1507.10.2
Properties: Physical properties

REFERENCES

<u>Entity</u>	<u>Report No.</u>	<u>Standard</u>	<u>Year</u>
PRI Construction Materials Technologies (TST5878)	BWR-539-02-01	ASTM D 3909	2014
PRI Construction Materials Technologies (TST5878)	MSA-009-02-01	ASTM D 6757	2016
PRI Construction Materials Technologies (TST5878)	MSA-039-02-04	ASTM D 226	2009
PRI Construction Materials Technologies (TST5878)	MSA-055-02-01	ASTM D 4869	2016
PRI Construction Materials Technologies (TST5878)	WII-008-02-03	ASTM D 226	2009
PRI Construction Materials Technologies (TST5878)	1085T0008	ASTM D 3909	2014
PRI Construction Materials Technologies (TST5878)	1085T0032.1	ASTM D 4869	2016
PRI Construction Materials Technologies (TST5878)	1085T0033	ASTM D 226	2009
PRI Construction Materials Technologies (TST5878)	1085T0041	ASTM D 4869	2016

PRODUCT DESCRIPTION

- MSA MSR** (Tuscaloosa) MSA MSR is an ASTM D 3909 asphalt roll roofing product surfaced with mineral granules for use as a valley liner in asphalt shingle roof systems.
- MSA ASTM D 226 #30** (Tuscaloosa & Griffin) MSA ASTM D 226 #30 is an ASTM D 226, Type II asphalt saturated organic felt underlayment.
- MSA Z-Felt 15** (Tuscaloosa & Griffin) MSA Z-15 is an ASTM D 4869, Type I asphalt saturated organic felt underlayment
- MSA Z-Felt 30** (Griffin) MSA Z-30 is an ASTM D 4869, Type II asphalt saturated organic felt underlayment
- MSA The Grid** (Tuscaloosa) MSA The Grid is an ASTM D 6757 saturated felt underlayment with woven glass fiber reinforcement.



APPLICATION

Deck Type: The roof deck shall be constructed of closely fitted sheathing for new or existing construction. The deck shall be installed in accordance with FBC requirements. Roof decks shall have no more than 1/8" gap at abutting joints.

Attachment method: In accordance with the requirements of FBC Section 1507.1.1, Table 1507.1.1.1 and the current published manufacturing instructions.

Allowable Roof Coverings:

	Asphalt Shingles	Metal Roof Panels and Shingles	Mineral-Surfaced Roll Roofing	Wood Shingles and Shakes	Slate Shingle	Clay and Concrete Tile	Photovoltaic Shingles
MSA MSR	Y ¹	N	Y	N	N	N	N
MSA ASTM D 226 30#	Y	Y	Y	Y	Y	Y	Y
MSA Z-15	N	N	N	N	N	N	N
MSA Z-30	N	N	N	N	N	N	N
MSA The Grid	Y	Y ²	N	N	N	N	Y

Notes: 1) Open valley applications per 1507.2.9.2
2) Allowable with Metal Panels only.


LIMITATIONS

- 1) This evaluation report is not use in the HVHZ.
- 2) Fire Classification is not within the scope of this evaluation.
- 3) Wind uplift resistance in not within scope of this evaluation.
- 4) Installation of the evaluated product shall comply with this report, the FBC, and the manufacturer's published application instructions. Where discrepancies exist between these sources, the more restrictive and FBC compliant installation detail shall prevail.
- 5) Deck substrates shall be clean, dry, and free from any irregularities and debris. All fasteners in the deck shall be checked for protrusion and corrected prior to underlayment application.
- 6) Roof slope limitations shall be in accordance with FBC requirements.
- 7) All underlayments shall be installed with the roll length parallel to the eave, starting at the eave, and lapped in success courses installed up the deck in a manner that effectively sheds water from the deck. End laps shall be staggered between courses in accordance with the manufacturer's application instructions.
- 8) Underlayments may be used as described in other current FBC product approval documents.
- 9) Roof coverings shall not be adhered directly to the underlayment. Roof coverings shall be mechanically fastened through the underlayment to the roof deck.
- 10) The underlayment shall be exposed on the roof deck for a maximum 30 days unless otherwise stated.
- 11) All products listed in this report shall be manufactured under a quality assurance program in compliance with Rule 61G20-3.



COMPLIANCE STATEMENT

The products evaluated herein by Zachary R. Priest, P.E. have demonstrated compliance with the Florida Building Code, 7th Edition (2020) as evidenced in the referenced documents submitted by the named manufacturer.



This item has been digitally signed and sealed by Zachary R. Priest, PE, on 12/20/2022.

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Zachary R. Priest, P.E.
Florida Registration No. 74021
Organization No. ANE9641

CERTIFICATION OF INDEPENDENCE

CREEK Technical Services, LLC does not have, nor will it acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

CREEK Technical Services, LLC is not owned, operated, or controlled by any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.

END OF REPORT