

R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry
P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197

Florida Board of Professional Engineers Certificate of Authorization No. 9813

Product Evaluation Report

Report No.:

FL-15099.10

Date:

June 29, 2015

Product Category	Sub Category	Manufacturer	Product Name
Windows	Fixed	Doers Window Manufacturing, LLC 4901 Oak Fair Blvd Tampa, FL 33610 (513) 284.0129	4600 Fixed Window w/ Flange "Non-Impact"

Scope:

Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Doers Window Manufacturing, LLC, based on Rule Chapter No. 61G20-3, Method 1A of the State of Florida Product Approval, Dept. of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

- This product anchoring drawing has been evaluated and is in compliance with the 5th Edition (2014) Florida Building Code (FBC)
 excluding the "High Velocity Hurricane Zone" (HVHZ). See the Certification Agency Certificate for sizes, specifications & ratings.
- 2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- 3. When used in areas requiring wind borne debris protection, this product is required to be protected with an impact resistant covering that complies with Section 1609.1.2 of the FBC.
- 4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
- 5. Site conditions that deviate from the details of drawing FL-15099.10 require further engineering analysis by a licensed engineer or registered architect.
- 6. See drawing FL-15099.10 for size and design pressure limitations.

Supporting Documents:

1.	Test Report No.			
	ATI C0574 02 504 47			

Test Standard
AAMA/WDMA/CSA101/I.S2/A440-(05)(08)

Testing Laboratory
Architectural Testing, Inc.

Signed by Lynn George

2. <u>Drawing No.</u> No. FL-15099.10

Prepared by

RW Building Consultants, Inc. (CA #9813)

Signed & Sealed by Lyndon F. Schmidt, P.E.

3. Calculations

Prepared by

Signed & Sealed by

Anchoring

RW Building Consultants, Inc. (CA #9813)

Lyndon F. Schmidt, P.E.

STATE OF

Lyndon F. Schmidt, P.E. FL PE No. 43409

9/17/2015