R W B C

R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197

Florida Board of Professional Engineers Registry License No. 9813

Product Evaluation Report

Report No.: ***FL-15146.7***

Date: ***October 7, 2026***

Product Category	Sub Category	Manufacturer	Product Name
Sky Lights	**Skylight**	**Gammans Skylight Systems, Inc.** **10 Beavers St.** **Newnan, GA 30263** **Phone - 770.254.1992**	**Series 350,400, 500 & 700** **Aluminum Fixed Skylight System** **"Large Missile Impact"**

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Gammans Skylight Systems, Inc., based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 9th Edition (2026) Florida Building Code (FBC) structural requirements including the "High Velocity Hurricane Zone" (HVHZ).
2. When used in the "HVHZ", this product complies with Section 1626 of the FBC as a large missile impact resistant product and does not require an impact resistant covering.
3. The system detailed herein is generic and does not provide information for a specific site. A licensed engineer or registered architect shall prepare site specific documents (including framing support and connections) to be used in conjunction with this document.
4. Permit holder shall verify the adequacy of the existing structure to withstand new superimposed loads.
5. This product meets the water infiltration requirements for "HVHZ".
6. All steel shall be protected as specified in FBC Section 2222.6
7. Glazing > 36" wide requires two (2) setting blocks conforming to FBC Section 2411.3.3.1.
8. See drawing FL-15146.7 for size and design pressure limitations.

Supporting Documents:

	Test Report No.	Test Standard	Testing Laboratory	Signed by
1.	ATLNC 0630.1-04	TAS 202-94	American Test Lab., Inc.	David Johnson, P.E.
	TEL 01690236	TAS 202-94	Testing Evaluation Lab., Inc.	L.F. Schmidt, P.E. (2010)
	TEL 01690272	TAS 201 & 203-94	Testing Evaluation Lab., Inc.	L.F. Schmidt, P.E. (2010)

	Miami-Dade NOA	Materials Testing
2.	26-0625.02	SentryGlas Interlayer (Kuraray America)
	26-0625.16	Saflex Storm Interlayer (Eastman Chemical Co.)

	Drawing No.	Prepared by	Signed & Sealed by
3.	No. FL-15146.7	RW Building Consultants, Inc. (#9813)	Lyndon F. Schmidt, P.E.

	Calculations	Prepared by
4.	ASTM E 1300 Glass Load	RW Building Consultants, Inc. (#9813)

5. **Quality Assurance**
   Certificate of Participation issued by National Accreditation and Management Institute, certifying that Gammans Skylight Systems, Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.

Digitally signed by Lyndon F Schmidt
Date: 2026.10.08 07:32:14 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by **L. F. Schmidt** on **10-08-26**.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA