

Product Evaluation Report

Report No.: FL-15210.14

Date: August 17, 2023

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	Plastpro, Inc. 5200 W. Century Blvd. Los Angeles, CA 90045 Phone 440.969.9773	Smooth / Wood Grain / White Wood Grain Rustic / Mahogany Series O Fiberglass Door Outswing - "Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Plastpro Inc., based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

- This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code structural requirements including the "High Velocity Hurricane Zone".
- Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- When used in the "HVHZ" this product complies with Section 1626 of the Florida Building Code and does not require an impact resistant covering.
- When used in areas outside of the "HVHZ" requiring wind borne debris protection this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E 1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1.
- For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
- Site conditions that deviate from the details of drawing FL-15210.14 require further engineering analysis by a licensed engineer or registered architect.
- Outswing configurations meet water infiltration requirements for "HVHZ".
- See drawing FL-15210.14 for size and design pressure limitations.

Supporting Documents:

- | | | |
|---|--|---|
| <ol style="list-style-type: none"> Test Report No.
TEL 01390568
TEL 01391846
ETC-05-255-16776.0

ETC-06-255-17412.0
ETC-07-209-19303.0
ETC-08-209-20609.1 Drawing No.
No. FL-15210.14 Calculations
Anchoring Quality Assurance
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Plastpro, Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | <ol style="list-style-type: none"> Test Standard
TAS 201-94, 202-94 & 203-94
TAS 201-94, 202-94 & TAS 203-94
ASTM D 635-98, 638-03, 1929-96 & 2843-99
ASTM G 26-95
ASTM E 84-05
ASTM D 635-98, 1929-96 & 2843-99
ASTM D 638-03 & G 155-05a Prepared by
RW Building Consultants, Inc. (#9813) Prepared by
RW Building Consultants, Inc. (#9813) | <ol style="list-style-type: none"> Testing Laboratory
Testing Evaluation Lab., Inc.
Testing Evaluation Lab., Inc.
ETC Laboratories

ETC Laboratories
ETC Laboratories
ETC Laboratories Signed by
William Shelton, P.E.
William Shelton, P.E.
Joseph L. Doldan, P.E.

Joseph L. Doldan, P.E.
Ben Meunier
Gurjinder Dhami Signed & Sealed by
Lyndon F. Schmidt, P.E. Signed & Sealed by
Lyndon F. Schmidt, P.E. |
|---|--|---|

Digitally signed by
Lyndon F Schmidt
Date: 2023.08.21
19:29:05 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 8-21-23.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA