

Product Evaluation Report**Report No.:** FL-15213.5**Date:** August 24, 2023

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	Plastpro Inc. 5200 W. Century Blvd. Los Angeles, CA Phone 440.969.9773	Smooth / Wood Grain / White Wood Grain Rustic / Mahogany Series Fiberglass Door Inswing/Outswing - "Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Plastpro Inc., based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1. The sidelite must be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of this drawing require further engineering analysis by a licensed engineer or registered architect.
6. See drawing FL-15213.5 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|---|---|---|---|
| 1. <u>Test Report No.</u>
TEL 2005-02-21-001
CTLA 900 W3-10
CTLA 924W | <u>Test Standard</u>
ASTM E330-02, ASTM E1996/1886-02
101/I.S.2-97
TAS 201, 202, 203-94 | <u>Testing Laboratory</u>
Testing Evaluation Lab., Inc.
Certified Testing Lab.
Certified Testing Lab. | <u>Signed by</u>
Wendell W. Haney, P.E.
Ramesh Patel, P.E.
Ramesh Patel, P.E. |
| 2. <u>Drawing No.</u>
No. FL-15213.5 | <u>Prepared by</u>
RW Building Consultants, Inc. (#9813) | <u>Signed & Sealed by</u>
Lyndon F. Schmidt, P.E. | |
| 3. <u>Calculations</u>
Anchoring
ASTM E 1300 Glass Load | <u>Prepared by</u>
RW Building Consultants, Inc. (#9813)
RW Building Consultants, Inc. (#9813) | <u>Signed & Sealed by</u>
Lyndon F. Schmidt, P.E. | |
| 4. <u>Quality Assurance</u>
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Plastpro Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | | | |

Digitally signed by
 Lyndon F Schmidt
 Date: 2023.08.24
 11:08:46 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
 This item has been digitally signed and sealed by L. F. Schmidt on 8-24-23.
 Printed copies of this document are not considered signed and sealed and the
 signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA