

Product Evaluation Report

Report No.: FL-15220.4

Date: August 14, 2023

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	Plastpro Inc. 5200 W. Century Blvd. Los Angeles, CA Phone 440.969.9773	Smooth / Wood Grain / White Wood Grain Rustic / Mahogany Series N Fiberglass Door Inswing/Outswing - "Non-Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Plastpro Inc., based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

- This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements including the "High Velocity Hurricane Zone".
- Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- When used in the "HVHZ" this product is required to be protected with an impact resistant covering that complies with Section 1626 of the FBC.
- When used in areas outside of the "HVHZ" requiring wind borne debris protection, this product is required to be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
- For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
- Site conditions that deviate from the details of drawing FL-15220.4 require further engineering analysis by a licensed engineer or registered architect.
- Outswing configurations meet water infiltration requirements for "HVHZ".
- Inswing configurations do not meet the water infiltration requirements for the "HVHZ". Inswing units shall be installed only in non-habitable areas or at habitable locations protected by an overhang or canopy such that the angle between the edge of canopy or overhang to sill is less than 45 degrees.
- See drawing FL-15220.4 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|---|---|--|---|
| <p>1. Test Report No.
TEL 07-0223-2
ETC 07-209-19303.0

ETC 08-209-20609.1
ETC 06-255-17412.0
ETC 05-255-16776.0

TEL 01391846</p> | <p>Test Standard
TAS 202-94
ASTM D2843-99, ASTM D635-98,
ASTM D1929-96
ASTM G155-05a, D638-03
ASTM E84-05
ASTM G26-95, D2843-99, D635-98,
D1929-96, D638-03
TAS 202-94</p> | <p>Testing Laboratory
Testing Evaluation Lab., Inc.
ETC Laboratories

ETC Laboratories
ETC Laboratories
ETC Laboratories

Testing Evaluation Lab., Inc.</p> | <p>Signed by
Wendell Haney, P.E.
Ben Meunier

Gurjinder Dhami
Joe Doldan, P.E.
Joe Doldan, P.E.

William Shelton, P.E.</p> |
| <p>2. FL# Component Approval
FL-29465.3</p> | <p>"HVHZ" Plastics Materials Testing
HP Polypropylene (ODL)</p> | | |
| <p>3. Drawing No.
No. FL-15220.4</p> | <p>Prepared by
RW Building Consultants, Inc. (#9813)</p> | | <p>Signed & Sealed by
Lyndon F. Schmidt, P.E.</p> |
| <p>4. Calculations
Anchoring
ASTM E1300 Glass Load</p> | <p>Prepared by
RW Building Consultants, Inc. (#9813)
Lyndon F. Schmidt, P.E.</p> | | <p>Signed & Sealed by
Lyndon F. Schmidt, P.E.</p> |
| <p>5. Quality Assurance
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Plastpro, Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.</p> | | | |

Digitally signed by
Lyndon F Schmidt
Date: 2023.08.14
12:55:03 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 8-14-23.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA