

L. Roberto Lomas P.E.

233 W. Main St
Danville, VA 24541
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 511866A

Manufacturer: **Comfort View Products, LLC**
 320 Coweta Industrial Parkway
 Newnan, GA 30265

Product Line: H Mullion Vertical

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-01264 Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Mullion Comparative Analysis, report number 511866-1A, in accordance with AAMA 450, Option 3, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: See charts in installation drawing
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions up to wind zone 3.
- Mullion material to be rigid PVC with aluminum reinforcement.
- Mullion reinforcement material to be Aluminum 6063-T6.

Installation: Units must be installed in accordance with approval document, 08-01264 Revision A.

Certification of Independence: Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

