

**Evaluation Report - Narrow Door**  
October 18, 2017

**Product Description:** Narrow Stile Entrance Door, Double Leaf XX, Non-Impact, 75 1/2" x 86 3/4" max. frame size, +/-30 PSF design pressure.

**Manufacturer:** Tubelite Inc., 3056 Walker Ridge DR. NW Suite G, Walker, Michigan 49544

**Statement of Compliance:** This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 6<sup>th</sup> Edition (2017) Florida Building Code for use outside the HVHZ. The product testing standards performed are outlined below.

**Technical Documentation:**

- 1) Approval drawing FPA-NAR-NI, signed and sealed by Lucas A. Turner, P.E.
- 2) Test Reports C2948.01-450-44 and C2166.01-450-44, by Architectural Testing, Inc., with testing performed: ASTM E 283-04, ASTM E330-02, and AAMA 1304-02 (not tested for water infiltration)
- 3) Supplemental Calculations to support FPA-NAR-NI, signed and sealed by Lucas A. Turner, P.E.

**Installation:** Units must be installed according to approval document FPA-NAR-NI.

**Limitations of Use:** This product:

- May be used in X or XX configuration in panel sizes and with max. glass DLO sizes and hardware types as shown in FPA-NAR-NI
- Is non-impact resistant and requires the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires 1/4" Tempered glass
- Requires 6063-T5 aluminum extrusions as indicated in FPA-NAR-NI

**Certification of Independence:** I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Tubelite Inc. or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



22

10/18/2017  
Lucas A. Turner, P.E.  
FL PE #58201