BUILDING DROPS
A Perfect Solution in Every Drop
Certificate of Authorization: 29578

398 E. Dania Beach. Blvd
Suite 338
Dania Beach, FL 33004
954.399.8478 PH
954.744.4738 FX
contact@buildingdrops.com

Product Evaluation Report

of

YKK AP America
"YVS-410TUH/YSW-400T/YVS-400TU/YVS-410TU/YFW-400TU
Series Windows"
Clipped/Unclipped Stacking Mullion - 4652

for

Florida Product Approval

FL# FL15729

Report No. 5035

Current Florida Building Code

Method:	**(1)(d) (Engineering Evaluation)**
Category:	**Windows**
Sub – Category:	**Mullions**

Product:	***Clipped/Unclipped Stacking Mullion - 4652***
Material:	**Aluminum 6063-T5**

Prepared For:
YKK AP America
332 Firetower Road
Dublin, GA 31021

Prepared by:
Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 08/22/17

Contents:

Evaluation Report Pages 1 – 3

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2017.10.11 18:18:00 -04'00'

HERMES F. NORERO
LICENSE
No. 73778
STATE OF
FLORIDA
PROFESSIONAL ENGINEER

Hermes F. Norero, P.E.
Florida No. 73778

Manufacturer: **YKK AP America**

Product Category: Windows

Product Sub-Category: Mullions

Compliance Method: State Product Approval Method (1)(d)

Product Name: Clipped/Unclipped Stacking Mullion – 4652

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **YKK AP America** based on Method (1)(d) of the State of Florida Product Approval, Florida Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Current Florida Building Code.

See Installation Instructions **YKK226**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the 6th Edition Florida Building Code, excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection in Wind Zone 4, this product does require impact protection in compliance with Chapter 16 of the Current Florida Building Code.
4. When used in areas requiring wind borne debris protection up to Wind Zone 3, this product does not require impact protection in compliance with Chapter 16 of the Current Florida Building Code such that adjoining products are equally impact rated.
5. Site conditions that deviate from the details of drawing **YKK226** require further engineering analysis by a licensed engineer or registered architect.
6. See Installation Instructions **YKK226** for size and design pressure limitations.

Quality Assurance:

The manufacturer has demonstrated compliance of manufacture of products in accordance with the Current Florida Building Code Method 1 for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Architectural Testing, Inc.** (FBC Organization #: QUA1844).

Performance Standards: The product described herein has been evaluated per:

- 6th Edition FBC Section 1709.8

Referenced Data:

1. Quality Assurance
   Architectural Testing, Inc.
   (FBC Organization #: QUA1844)

Installation:

1. Approved anchor types and substrates are as follows:

   A. For two by (2X) wood frame substrate, use **#12 Wood Screw** type wood frame anchors of sufficient length to achieve minimum embedment of 1.50" into wood framing.

   B. For concrete or masonry substrate where one by (1X), non-structural, wood bucking is employed, or directly fastened to concrete or masonry, use **1/4" diameter ITW Tapcon** type concrete screw anchors of sufficient length to achieve minimum embedment of 1.25" into concrete or masonry.

   C. For metal stud, use **¼-20 SAE Gr. 5 Self-Tapping or Self-Drilling Screw** type metal stud anchors of sufficient length to achieve 3 threads of minimum penetration beyond metal structure.

Refer to Installation Instructions (**YKK226**) for anchor locations, installation methods, and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions **YKK226, sheets 4 & 5**, for design pressure tables and limitations of use.