

Product Evaluation Report

Report No.: FL-15768.11

Date: July 3, 2023

Product Category	Sub Category	Manufacturer	Product Name
Windows	Fixed	Soft-Lite LLC 10250 Philipp Parkway Streetsboro, OH 44241 (330) 528-3400	"BARCELONA" Model "PW30I" Picture Window "Impact"

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for Soft-Lite LLC based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

- This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements including the "High Velocity Hurricane Zone".
- Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- When used in the "HVHZ", this product complies with Section 1626 of the FBC and does not require an impact resistant covering.
- For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
- Site conditions that deviate from the details of drawing FL-15768.11 require further engineering analysis by a licensed engineer or registered architect.
- This product meets the water infiltration requirements for "HVHZ".
- See drawing FL-15768.11 for size and design pressure limitations.

Supporting Documents:

- Test Report No.**
TEL 03001816, 19, 22
TEL 03001887
TEL 03002044
TEL 03003323
TEL 03003451
TEL 03003454
Test Standard
TAS 201, 202 & 203-94
TAS 201, 202 & 203-94
TAS 201, 202 & 203-94
TAS 201, 202 & 203-94
TAS 201, 202 & 203-94
TAS 201, 202 & 203-94
Testing Laboratory
Testing Evaluation Lab, Inc.
Testing Evaluation Lab, Inc.
Testing Evaluation Lab, Inc.
Testing Evaluation Lab, Inc.
Testing Evaluation Lab, Inc.
Testing Evaluation Lab, Inc.
Signed by
William Shelton, P.E.
Lyndon F. Schmidt, P.E.
Lyndon F. Schmidt, P.E.
William B. Shelton, P.E.
William B. Shelton, P.E.
William B. Shelton, P.E.
- Miami Dade NOA**
22-1116.01
21-0216.01
18-1108.10
Materials Testing
SentryGlas® Interlayer (Kuraray)
Saflex® PVB Interlayer (Eastman Chemical Company)
PVC Extrusions (Vision Extrusions Ltd.)
- Drawing No.**
No. FL-15768.11
Prepared by
RW Building Consultants, Inc. (#9813)
Signed & Sealed by
Lyndon F. Schmidt, P.E.
- Calculations**
Anchoring
ASTM E1300 Glass Load
Prepared by
RW Building Consultants, Inc. (#9813)
Lyndon F. Schmidt, P.E.
Signed & Sealed by
Lyndon F. Schmidt, P.E.
- Quality Assurance**
Certificate of Participation issued by Farabaugh Engineering and Testing, Inc. certifying that Soft-Lite LLC is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.

Digitally signed by Lyndon F Schmidt
Date: 2023.07.03 14:32:55 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 7-3-23.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA