

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

## Engineering Evaluation Report

**Report No.: 513511B**

**Manufacturer:** Slocomb Windows and Doors  
767 San Souci Parkway  
Hanover Township, PA 18706

**Product Line:** 500 Series Double Hung Window

**Compliance:**

The product listed herein complies with requirements of the Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-02727 revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: ATI E5079.03-501-47 signed by Lynn George  
Architectural Testing Inc., Springdale, PA  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure:  $\pm 55.14$ psf  
Water penetration resistance: 7.52psf
3. Anchor calculations with comparative analysis, report number 513511-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure: Refer to installation drawing
- Unit size: refer to installation drawing
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-02727, revision B.

**Certification of Independence:**

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

