

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609 (phone & fax)

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 513611B

Manufacturer: Slocomb Windows & Doors
767 San Souci Parkway
Hanover Township, PA 18706

Product Line: 100 Series Double Hung Window

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02819 Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No NCTL-110-24881-1 signed by Justin Bupp
National Certified Testing Laboratories, York, PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 30.08 psf
Water penetration resistance 4.59psf
3. Anchor calculations, report number 513611-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 30.0 psf
- Unit size: 40" x 63"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is non-impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-02819, Revision A.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

