



BUILDING DROPS

A Perfect Solution in Every Drop

Certificate of Authorization: 29578

398 E. Dania Beach Blvd.
Suite 338
Dania Beach, FL 33004
954.399.8478 PH
954.744.4738 FX
contact@buildingdrops.com

Product Evaluation Report *of*

NABCO Entrances, Inc.

**System GT 1175 Bipart Automatic Slider
With Fixed Sidelite (Non-Impact)**

for
Florida Product Approval

FL# FL16167

Report No. 3986


5th Edition Florida Building Code 2014

Method:	1 – A (Certificate)
Category:	Exterior Doors
Sub – Category:	Automatic Exterior Door Assemblies
Product:	<i>System GT 1175 Bipart Automatic Slider With Fixed Sidelite (Non-Impact)</i>
Material:	Aluminum
Product Dimensions:	<i>192" x 91.5" (Maximum)</i>

Prepared For:
NABCO Entrances, Inc.
S82 W18717 Gemini Dr.
Muskego, WI 53150

Prepared by:
Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 09/28/15

Contents:
Evaluation Report Pages 1 – 4
Digitally signed by Hermes F Norero, P.E.
Reason: I am approving this document
Date: 2015.11.02 07:36:16 -05'00'



Hermes F. Norero, P.E.
Florida No. 73778



BUILDING DROPS

A Perfect Solution in Every Drop

Certificate of Authorization: 29578

FL#: FL16167

Date: 09/28/15

Report No: 3986

Manufacturer: NABCO Entrances, Inc.

Product Category: Exterior Doors

Product Sub-Category: Automatic Exterior Door Assemblies

Compliance Method: State Product Approval Rule (1)(a)

Product Name: System GT 1175 Bipart Automatic Slider With Fixed Sidelite
192" x 91.5" (Maximum)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **NABCO Entrances, Inc.** based on Method 1a of the State of Florida Product Approval, Department of Business and Professional Regulations - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Florida Building Code.

See Installation Instructions **NAB002**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the Florida Building Code, including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the Florida Building Code and does require an impact resistant covering.
4. Site conditions that deviate from the details of drawing **NAB002** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **NAB002** for size and design pressure limitations.



BUILDING DROPS

A Perfect Solution in Every Drop

Certificate of Authorization: 29578

FL#: FL16167

Date: 09/28/15

Report No: 3986

Certification Agency:	The manufacturer has demonstrated compliance of door products in Accordance with the Florida Building Code and State Rules for manufacturing under a quality assurance program audited by an approved quality assurance entity through National Accreditation & Management Institute, Inc. (FBC Organization #QUA1789)
Performance Standards:	The product described herein has been tested per: • TAS 202-94
Referenced Data:	- Product Testing performed by Hurricane Engineering and Testing, Inc. (FBC Organization # TST1691) Report #: HETI-00-888, Report Date: 10/06/00 Report #: HETI-00-891, Report Date: 10/06/00 Report #: HETI-00-4166, Report Date: 12/01/00 Report #: HETI-00- T051, Report Date: 12/01/00 Report #: ATI-C2942.01-602-18, Report Date: 10/23/12 - Certification Agency National Accreditation & Management Institute, Inc. (FBC Organization #QUA1789)



BUILDING DROPS

A Perfect Solution in Every Drop

Certificate of Authorization: 29578

FL#: FL16167

Date: 09/28/15

Report No: 3986

Installation: 1. Approved anchor types and substrates are as follows:

Through Frame Installation:

- A. For concrete (Min. $f'c = 3000$ psi) or masonry substrate (CMU shall adhere to ASTM C90) substrate where one by (1X), non-structural, wood bucking is employed, use **1/4" diameter ITW Tapcon** type concrete screw anchors of sufficient length to achieve minimum embedment of 1.25" into concrete or masonry.
- B. For concrete (Min. $f'c = 3000$ psi) or masonry substrate (CMU shall adhere to ASTM C90) substrate where wood bucking is NOT employed, use **1/4" diameter ITW Tapcon** type concrete screw anchors of sufficient length to achieve minimum embedment of 1.25" into concrete or masonry.
- C. For steel substrate (Min. 18 ga. steel, min. $f_y = 33$ ksi), use **1/4" TEK Screw** type steel stud anchors of sufficient length to achieve minimum 3 threads penetration beyond steel structure.
- D. For aluminum substrate (Min. 1/8" 6063-T5 aluminum), use **1/4" TEK Screw** type steel stud anchors of sufficient length to achieve minimum 3 threads penetration beyond aluminum structure.

Refer to Installation Instructions (**NAB002**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Design Pressure	
Positive	60 PSF
Negative	60 PSF

Installation Methods:

Refer to Installation Instructions (**NAB002**) for installation methods, anchor locations, and more details of the installation requirements.