L. Roberto Lomas P.E.
1432 Woodford Rd.
Lewisville, NC 27023
434 – 688 - 0609
rllomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 512619A

Manufacturer: **Window Mart**
5760 Albert Pike
Royal, AR 71968

Product Line: 10300085 Aluminum Vertical Mullion Non-Reinforced LMI Wind Zone 3

Compliance:
The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:
1. Approval document: drawing number 08-01914, Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Mullion Analysis, report number 512619-1A, per AAMA 450-10 Option 3, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:
- Maximum design pressure: See chart in installation drawing
- This product is not rated to be used in the HVHZ.
- This product is impact resistant up to wind zone 3 and does not require impact protection in wind borne debris regions.
- Mullion material to be extruded Aluminum 6005-T5.
- Steel Mullion Bracket material to be formed 15GA. Galvanized Steel.
- Mull Clip material to be extruded Aluminum 6005-T5.
- All windows mulled to this product must be manufactured by Window Mart and must have their own Product Approval.

Installation: Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-01914, Revision A.

Certification of Independence: Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E.
FL No.: 62514
10/03/2016