

Product Evaluation Report

Report No.: **FL-16216.3**

Date: **July 1, 2026**

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Sliding Exterior Door Assemblies	Wincore Window Company, LLC. 250 Staunton Turnpike Parkersburg, WV 26104	8800 Series Vinyl Sliding Patio Door "Impact"

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for Wincore Window Company, LLC. based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

- This product has been evaluated and is in compliance with the 9th Edition (2026) Florida Building Code (FBC) structural requirements including the "High Velocity Hurricane Zone" (HVHZ).
- Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- When used in the "HVHZ" this product complies with Section 1626 of the FBC and does not require an impact resistant covering.
- For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
- Site conditions that deviate from the details of drawing FL-16216.3 require further engineering analysis by a licensed engineer or registered architect.
- This product meets the water infiltration requirements for the "HVHZ".
- See drawing FL-16216.3 for size and design pressure limitations.

Supporting Documents:

- Test Report No.**
TEL 02800585
 Test Standard
TAS 201, 202 & 203 - 94
 Testing Laboratory
Testing Evaluation Lab., Inc.
 Signed by
William B. Shelton, P.E.
- Miami-Dade NOA**
24-1016.02
26-0625.02
 Materials Testing
White Rigid PVC Exterior Extrusions (PH Tech, Inc.)
SentryGlas® Interlayer (Kuraray America., Inc.)
- Drawing No.**
No. FL-16216.3
 Prepared by
RW Building Consultants, Inc. (#9813)
 Signed & Sealed by
Lyndon F. Schmidt, P.E.
- Calculations**
Anchoring
ASTM E1300 Glass Load
 Prepared by
RW Building Consultants, Inc. (#9813)
RW Building Consultants, Inc. (#9813)
 Signed & Sealed by
Lyndon F. Schmidt, P.E.
- Quality Assurance**
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Wincore Window Company, LLC. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.

Digitally signed by Lyndon F Schmidt
 Date: 2026.07.27 12:59:08 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
 This item has been digitally signed and sealed by L. F. Schmidt on 7-27-26.
 Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA