

Product Evaluation Report**Report No.: FL-16259.2****Date: October 9, 2017**

Product Category	Sub Category	Manufacturer	Product Name
Windows	Single Hung	Window Technology, Inc. 201 Industrial Drive Monett, MO 65708 (417) 235-7821	Series S70 Vinyl Single Hung Window w/ Nail Fin "Non-Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Window Technology, Inc., Inc. based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.


RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 6th Edition (2017) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product is required to be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
4. Site conditions that deviate from the details of drawing FL-16259.2 require further engineering analysis by a licensed engineer or registered architect.

Supporting Documents:

- | | | | |
|--|---|---|--|
| 1. Test Report No.
ESP016420P.1
ESP016420P.2
ESP016420P.11 | Test Standard
AAMA/WDMA/101/I.S.2/A440-11
AAMA/WDMA/101/I.S.2/A440-11
AAMA/WDMA/101/I.S.2/A440-11 | Testing Laboratory
Element Materials Technology
Element Materials Technology
Element Materials Technology | Signed by
Brian S. Escherich
Brian S. Escherich
Brian S. Escherich |
| 2. Drawing No.
No. FL-6259.2 | Prepared by
RW Building Consultants, Inc. (CA #9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 3. Calculations
Anchoring | Prepared by
RW Building Consultants, Inc. (CA #9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 4. Quality Assurance
Certificate of Participation issued by Keystone Certifications, Inc., certifying that Window Technology, Inc., Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | | | |



Lyndon F. Schmidt, P.E.
FL PE No. 43409
10/9/2017