BUILDING DROPS
1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Product Evaluation Report

of

YKK AP America, Inc.
YOW 350 TUH Thermal Aluminum Project Out Window
(WZ3) (Impact)

for

Florida Product Approval

FL# FL16313

Report No. 6809

Current Florida Building Code

Method:	**1 – D (Engineering Evaluation)**
Category:	**Windows**
Sub – Category:	**Projected**
Product:	**YOW 350 TUH Thermal Aluminum Project Out Window**
Materials:	**Aluminum 6063-T5**
Product Dimensions:	**See Installation Instructions, YKK155**

Prepared for:
YKK AP America, Inc.
1229 Hwy 441 Bypass
Dublin, GA 31021

Prepared by:
Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 2/26/2024



Contents:

Evaluation Report Pages 1 – 4

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2024.02.28 11:05:41 -08'00'

Hermes F. Norero, P.E.
Florida No. 73778

Manufacturer: **YKK AP America, Inc.**

Product Category: Windows

Product Sub-Category: Projected

Compliance Method: State Product Approval Method (1)(d)

Product Name: **YOW 350 TUH Thermal Aluminum Project Out Window (WZ3) (Impact)**

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **YKK AP America, Inc.** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **YKK155**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does not require** an impact resistant covering Wind Zone 3 or less.
4. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does require** an impact resistant covering Wind Zone 4.
5. Site conditions that deviate from the details of installation instructions **YKK155** require further engineering analysis by a licensed engineer or registered architect.
6. See Installation Instructions **YKK155** for size and design pressure limitations.

Quality Assurance: The manufacturer has demonstrated compliance of manufacture of products in accordance with the current Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Architectural Testing, Inc., an Intertek Company.**
(FBC Organization # QUA1844)

Performance Standards: The product described herein has been evaluated per:

- AAMA/WDMA/CSA 101/I.S.2/A440-11/17
- TAS 201-94
- TAS 202-94
- TAS 203-94

Referenced Data:

1. Product Testing performed by **Hurricane Testing Laboratory, LLC.**
(FBC Organization # TST1527)

Report #:	Report Date:
0231-0810-02	12/12/02
0231-1210-02	05/09/03
G231-0608-07	09/14/07
G231-1001-10	10/22/10

2. Product Testing performed by **Architectural Testing, Inc. (an Intertek company) - Lithia Springs, GA / Atlanta**
(FBC Organization # TST3892)

Report #:	Report Date:
C3632.05-550-18	04/25/13
C3632.08-550-18	04/25/13
G8241.04-550-18	06/16/17
E3617.01-550-44	03/12/15
E3617.02-550-44	03/12/15
E3617.03-550-44	03/12/15
E3617.04-550-44	03/12/15
E3617.05-550-44	03/12/15
E3617.06-550-44	03/12/15
J4484.01-550-44	06/10/19
J4484.02-550-44	06/10/19
I5654.01-550-44	07/24/18
I9736.03-550-44	12/14/18

3. Quality Assurance
   Architectural Testing, Inc., an Intertek Company
   (FBC Organization # QUA1844)

Installation:

Refer to Installation Instructions (**YKK155**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions (**YKK155**) for design pressures based on size, configuration, and glass types.

954.399.8478
954.744.4738
BUILDINGDROPS.COM
CONTACT@BUILDINGDROPS.COM